

SLOVENSKI STANDARD
SIST EN 60598-2-19:1995/A2:1999
01-julij-1999

Svetilke - 2. del: Posebne zahteve - 19. oddelek: Prezračevalne svetilke (varnostne zahteve) - Dopolnilo A2 (IEC 60598-2-19:1981/A2:1997)

Luminaires - Part 2: Particular requirements - Section 19: Air-handling luminaires (safety requirements) (IEC 60598-2-19:1981/A2:1997)

Leuchten - Teil 2: Besondere Anforderungen - Hauptabschnitt 19: Luftführende Leuchten (Sicherheitsanforderungen) (IEC 60598-2-19:1981/A2:1997)

Luminaires - Partie 2: Règles particulières - Section 19: Luminaires à circulation d'air (règles de sécurité) (CEI 60598-2-19:1981/A2:1997)

<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

Ta slovenski standard je istoveten z: EN 60598-2-19:1989/A2:1998

ICS:

29.140.40 Svetila Luminaires

SIST EN 60598-2-19:1995/A2:1999 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60598-2-19:1995/A2:1999

<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

EUROPEAN STANDARD

EN 60598-2-19/A2

NORME EUROPÉENNE

EUROPÄISCHE NORM

January 1998

UDC 628.94-712-777.001.2.001.4.002.2(083.71) 614.825.001.25 628.84
ICS 29.140.40

Descriptors: Air-handling luminaires, requirements, testing, definitions, electrical safety requirements, air conditioning

English version

Luminaires
Part 2: Particular requirements
Section 19: Air-handling luminaires (safety requirements)
(IEC 60598-2-19:1981/A2:1997)

Luminaires

Partie 2: Règles particulières

Section 19: Luminaires à circulation

d'air (règles de sécurité)

(CEI 60598-2-19:1981/A2:1997)

Leuchten

Teil 2: Besondere Anforderungen

Hauptabschnitt 19: Luftführende

Leuchten (Sicherheitsanforderungen)

(IEC 60598-2-19:1981/A2:1997)

[SIST EN 60598-2-19:1995/A2:1999](https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999)<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

This amendment A2 modifies the European Standard EN 60598-2-19:1989; it was approved by CENELEC on 1998-01-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization

Comité Européen de Normalisation Electrotechnique

Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 34D/471/FDIS, future amendment 2 to IEC 60598-2-19:1981, prepared by SC 34D, Luminaires, of IEC TC 34, Lamps and related equipment, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A2 to EN 60598-2-19:1989 on 1998-01-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 1998-10-01
- latest date by which the national standards conflicting
with the amendment have to be withdrawn (dow) 1998-10-01

Endorsement notice

The text of amendment 2:1997 to the International Standard IEC 60598-2-19:1981 was approved by CENELEC as an amendment to the European Standard without any modification.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 60598-2-19:1995/A2:1999](https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999)
<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

**NORME
INTERNATIONALE
INTERNATIONAL
STANDARD**

**CEI
IEC**

60598-2-19

1981

AMENDEMENT 2
AMENDMENT 2

1997-12

Amendement 2

Luminaires –

Deuxième partie: Règles particulières –

**Section dix-neuf: Luminaires à circulation d'air
(règles de sécurité)**

iteh STANDARD PREVIEW
(standards.iteh.ai)

Amendment 2

<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

Luminaires –

Part 2: Particular requirements –

**Section Nineteen: Air-handling luminaires
(safety requirements)**

© IEC 1997 Droits de reproduction réservés — Copyright - all rights reserved

International Electrotechnical Commission
Telefax: +41 22 919 0300

3, rue de Varembé Geneva, Switzerland
IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

B

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

FOREWORD

This amendment has been prepared by subcommittee 34D: Luminaires, of IEC technical committee 34: Lamps and related equipment.

The text of this amendment is based on the following documents:

FDIS	Report on voting
34D/471/FDIS	34D/481/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

Page 13

19.12 Endurance tests and thermal tests

19.12.1.2

Replace the first paragraph by the following.

<https://standards.iteh.ai/catalog/standards/sist/0c57ca0f-4979-4871-8a67-261907970bb2/sist-en-60598-2-19-1995-a2-1999>

During the test, the temperature of upward facing surfaces within the main air path shall not exceed 100 °C, except that for glass surfaces of tubular fluorescent lamps, the temperature shall not exceed 150 °C.