

INTERNATIONAL STANDARD

**IEC
60071-1**

Eight edition
2006-01

Insulation co-ordination

Part 1: Definitions, principles and rules

iTech Standards
(<https://standards.itih.ai>)
Document Preview

IEC 60071-1:2006

<https://standards.itih.ai/standards/iec/b295a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>

This **English-language** version is derived from the original **bilingual** publication by leaving out all French-language pages. Missing page numbers correspond to the French-language pages.



Reference number
IEC 60071-1:2006(E)

Publication numbering

As from 1 January 1997 all IEC publications are issued with a designation in the 60000 series. For example, IEC 34-1 is now referred to as IEC 60034-1.

Consolidated editions

The IEC is now publishing consolidated versions of its publications. For example, edition numbers 1.0, 1.1 and 1.2 refer, respectively, to the base publication, the base publication incorporating amendment 1 and the base publication incorporating amendments 1 and 2.

Further information on IEC publications

The technical content of IEC publications is kept under constant review by the IEC, thus ensuring that the content reflects current technology. Information relating to this publication, including its validity, is available in the IEC Catalogue of publications (see below) in addition to new editions, amendments and corrigenda. Information on the subjects under consideration and work in progress undertaken by the technical committee which has prepared this publication, as well as the list of publications issued, is also available from the following:

- **IEC Web Site** (www.iec.ch)

- **Catalogue of IEC publications**

The on-line catalogue on the IEC web site (www.iec.ch/searchpub) enables you to search by a variety of criteria including text searches, technical committees and date of publication. On-line information is also available on recently issued publications, withdrawn and replaced publications, as well as corrigenda.

- **IEC Just Published**

This summary of recently issued publications (www.iec.ch/online_news/justpub) is also available by email. Please contact the Customer Service Centre (see below) for further information.

- **Customer Service Centre**

If you have any questions regarding this publication or need further assistance, please contact the Customer Service Centre:

Email: custserv@iec.ch
Tel: +41 22 919 02 11
Fax: +41 22 919 03 00

<https://standards.iteh.ai/catalog/standards-iec/6293a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>

INTERNATIONAL STANDARD

IEC 60071-1

Eight edition
2006-01

Insulation co-ordination

Part 1: Definitions, principles and rules

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 60071-1:2006

<https://standards.iteh.ai/catalog/standards/iec/b293a479-d71a-4232-a23c-cdb41d5936a0/iec-60071-1-2006>

© IEC 2006 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CONTENTS

FOREWORD.....	7
1 Scope.....	11
2 Normative references	11
3 Terms and definitions	13
4 Symbols and abbreviations	27
4.1 General	27
4.2 Subscripts	27
4.3 Letter symbols.....	27
4.4 Abbreviations	29
5 Procedure for insulation co-ordination	29
5.1 General outline of the procedure	29
5.2 Determination of the representative voltages and overvoltages (U_{rp})	33
5.3 Determination of the co-ordination withstand voltages (U_{cw})	35
5.4 Determination of the required withstand voltage (U_{rw})	37
5.5 Selection of the rated insulation level	37
5.6 List of standard rated short-duration power frequency withstand voltages	39
5.7 List of standard rated impulse withstand voltages	39
5.8 Ranges for highest voltage for equipment.....	39
5.9 Environmental conditions	41
5.10 Selection of the standard insulation level.....	41
5.11 Background of the standard insulation levels	49
6 Requirements for standard withstand voltage tests	51
6.1 General requirements.....	51
6.2 Standard short-duration power frequency withstand voltage tests	53
6.3 Standard impulse withstand voltage tests	53
6.4 Alternative test situation	55
6.5 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range I	55
6.6 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range II	57
Annex A (normative) Clearances in air to assure a specified impulse withstand voltage installation	59
Annex B (informative) Values of rated insulation levels for $1\text{ kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries	67
Bibliography.....	69
Figure 1 – Flow chart for the determination of rated or standard insulation level	31

Table 1 – Classes and shapes of overvoltages, Standard voltage shapes and Standard withstand voltage tests	33
Table 2 – Standard insulation levels for range I ($1\text{kV} < U_m \leq 245\text{ kV}$).....	45
Table 3 – Standard insulation levels for range II ($U_m > 245\text{ kV}$)	47
Table A.1 – Correlation between standard rated lightning impulse withstand voltages and minimum air clearances	61
Table A.2 – Correlation between standard rated switching impulse withstand voltages and minimum phase-to-earth air clearances.....	63
Table A.3 – Correlation between standard rated switching impulse withstand voltages and minimum phase-to-phase air clearances	65
Table B.1- Values of rated insulation levels for $1\text{kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries	67

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 60071-1:2006

<https://standards.iteh.ai/standards/iec/b295a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSULATION CO-ORDINATION –

Part 1: Definitions, principles and rules

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60071-1 has been prepared by IEC technical committee 28: Insulation co-ordination.

This eighth edition cancels and replaces the seventh edition published in 1993 and constitutes a technical revision.

The main changes from the previous edition are as follows:

- in the definitions (3.26, 3.28 and 3.29) and in the environmental conditions (5.9) taken into account clarification of the atmospheric and altitude corrections involved in the insulation co-ordination process;
- in the list of standard rated short-duration power frequency withstand voltages reported in 5.6 addition of 115 kV;

- in the list of standard rated impulse withstand voltages reported in 5.7, addition of 200 kV and 380 kV;
- in the standard insulation levels for range I ($1\text{kV} < U_m \leq 245\text{ kV}$) (Table 2) addition of the highest voltage for equipment $U_m = 100\text{ kV}$;
- in the standard insulation levels for range II ($U_m > 245\text{ kV}$) (Table 3) replacement of 525 kV by 550 kV and of 765 kV by 800 kV;
- in order to remove that part in the next revision of IEC 60071-2, addition of Annex A dealing with clearances in air to assure a specified impulse withstand voltage in installation;
- in Annex B, limitation at two U_m values for the values of rated insulation levels for $1\text{kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries.

The text of this standard is based on the following documents:

FDIS	Report on voting
28/176/FDIS	28/177/RVC

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The IEC 60071 comprises the following parts under the general title *Insulation co-ordination*:

- Part 1: Definitions, principles and rules
- Part 2: Application guide
- Part 4: Computational guide to insulation co-ordination and modelling of electrical networks
- Part 5: Procedures for high-voltage direct current (HVDC) converter stations

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

INSULATION CO-ORDINATION –

Part 1: Definitions, principles and rules

1 Scope

This part of IEC 60071 applies to three-phase a.c. systems having a highest voltage for equipment above 1 kV. It specifies the procedure for the selection of the rated withstand voltages for the phase-to-earth, phase-to-phase and longitudinal insulation of the equipment and the installations of these systems. It also gives the lists of the standard withstand voltages from which the rated withstand voltages should be selected.

This standard recommends that the selected withstand voltages should be associated with the highest voltage for equipment. This association is for insulation co-ordination purposes only. The requirements for human safety are not covered by this standard.

Although the principles of this standard also apply to transmission line insulation, the values of their withstand voltages may be different from the standard rated withstand voltages.

The apparatus committees are responsible for specifying the rated withstand voltages and the test procedures suitable for the relevant equipment taking into consideration the recommendations of this standard.

NOTE In IEC 60071-2, Application Guide, all rules for insulation co-ordination given in this standard are justified in detail, in particular the association of the standard rated withstand voltages with the highest voltage for equipment. When more than one set of standard rated withstand voltages is associated with the same highest voltage for equipment, guidance is provided for the selection of the most suitable set.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2002, *IEC standard voltages*

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-2, *Insulation co-ordination – Part 2: Application guide*

IEC 60099-4, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*

IEC 60507, *Artificial pollution tests on high-voltage insulators to be used on a.c. systems*

IEC 60633, *Terminology for high-voltage direct current (HVDC) transmission*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

insulation co-ordination

selection of the dielectric strength of equipment in relation to the operating voltages and overvoltages which can appear on the system for which the equipment is intended and taking into account the service environment and the characteristics of the available preventing and protective devices

[IEC 604-03-08:1987, modified]

NOTE By "dielectric strength" of the equipment, is meant here its rated or its standard insulation level as defined in 3.35 and 3.36 respectively.

3.2

external insulation

distances in atmospheric air, and the surfaces in contact with atmospheric air of solid insulation of the equipment which are subject to dielectric stresses and to the effects of atmospheric and other environmental conditions from the site, such as pollution, humidity, vermin, etc.

[IEC 604-03-02:1987, modified]

NOTE External insulation is either weather protected or non-weather protected, designed to operate inside or outside closed shelters respectively.

3.3

internal insulation

internal distances of the solid, liquid, or gaseous insulation of equipment which are protected from the effects of atmospheric and other external conditions

[IEC 604-03-03:1987]

3.4

self-restoring insulation

insulation which, after a short time, completely recovers its insulating properties after a disruptive discharge during test

[IEC 604-03-04:1987, modified]

NOTE Insulation of this kind is generally, but not necessary, external insulation

3.5

non self-restoring insulation

insulation which loses its insulating properties, or does not recover them completely, after a disruptive discharge during test

[IEC 604-03-05:1987, modified]

NOTE The definitions of 3.4 and 3.5 apply only when the discharge is caused by the application of a test voltage during a dielectric test. However, discharges occurring in service may cause a self-restoring insulation to lose partially or completely its original insulating properties.

3.6

insulation configuration terminal

any of the terminals between any two of which a voltage that stresses the insulation can be applied. The types of terminal are:

- (a) phase terminal, between which and the neutral is applied in service the phase-to-neutral voltage of the system;
- (b) neutral terminal, representing, or connected to, the neutral point of the system (neutral terminal of transformers, etc.);
- (c) earth terminal, always solidly connected to earth in service (tank of transformers, base of disconnectors, structures of towers, ground plane, etc.).

3.7

insulation configuration

complete geometric configuration of the insulation in service, consisting of the insulation and of all terminals. It includes all elements (insulating and conducting) which influence its dielectric behaviour. The following insulation configurations are identified:

3.7.1

three-phase insulation configuration

configuration having three phase terminals, one neutral terminal and one earth terminal

3.7.2

phase-to-earth (p-e) insulation configuration

three-phase insulation configuration where two phase terminals are disregarded and, except in particular cases, the neutral terminal is earthed

3.7.3

phase-to-phase(p-p) insulation configuration

three-phase insulation configuration where one phase terminal is disregarded. In particular cases, the neutral and the earth terminals are also disregarded

3.7.4

longitudinal(t-t) insulation configuration

insulation configuration having two phase terminals and one earth terminal. The phase terminals belong to the same phase of a three-phase system temporarily separated into two independently energized parts (e.g. open switching devices). The four terminals belonging to the other two phases are disregarded or earthed. In particular cases one of the two phase terminals considered is earthed

3.8

nominal voltage of a system

U_n

suitable approximate value of voltage used to designate or identify a system

[IEC 601-01-21:1985]

3.9

highest voltage of a system

U_s

highest value of the phase-to-phase operating voltage (r.m.s. value) which occurs under normal operating conditions at any time and at any point in the system

[IEC 601-01-23:1985, modified]

3.10

highest voltage for equipment

U_m

highest value of phase-to-phase voltage (r.m.s. value) for which the equipment is designed in respect of its insulation as well as other characteristics which relate to this voltage in the relevant equipment Standards. Under normal service conditions specified by the relevant apparatus committee this voltage can be applied continuously to the equipment

[IEC 604-03-01:1987, modified]

3.11**isolated neutral system**

system where the neutral point is not intentionally connected to earth, except for high impedance connections for protection or measurement purposes

[IEC 601-02-24:1985]

3.12**solidly earthed neutral system**

system whose neutral point(s) is(are) earthed directly

[IEC 601-02-25:1985]

3.13**impedance earthed (neutral) system**

system whose neutral point(s) is(are) earthed through impedances to limit earth fault currents

[IEC 601-02-26:1985]

3.14**resonant earthed (neutral) system**

system in which one or more neutral points are connected to earth through reactances which approximately compensate the capacitive component of a single-phase-to-earth fault current

[IEC 601-02-27:1985]

NOTE With resonant earthing of a system, the residual current in the fault is limited to such an extent that an arcing fault in air is usually self-extinguishing.

3.15**earth fault factor*****k***

at a given location of a three-phase system, and for a given system configuration, the ratio of the highest r.m.s. phase-to-earth power frequency voltage on a healthy phase during a fault to earth affecting one or more phases at any point on the system to the r.m.s. phase-to-earth power frequency voltage which would be obtained at the given location in the absence of any such fault

[IEC 604-03-06:1987]

3.16**overvoltage**

any voltage:

- between one phase conductor and earth or across a longitudinal insulation having a peak value exceeding the peak of the highest voltage of the system divided by $\sqrt{3}$;

[IEC 604-03-09, modified] or

- between phase conductors having a peak value exceeding the amplitude of the highest voltage of the system

[IEC 604-03-09:1987, modified]

NOTE Unless otherwise clearly indicated, such as for surge arresters, overvoltage values expressed in p.u. refer to $U_s \times \sqrt{2}/\sqrt{3}$