

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Insulation co-ordination –
Part 1: Definitions, principles and rules**

**Coordination de l'isolement –
Partie 1: Définitions, principes et règles**

IEC 60071-1:2006

<https://standards.iteh.ai/standards/iec/b295a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

■ Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

■ IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

■ Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

■ Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

■ Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

■ Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

■ Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

■ Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 60071-1

Edition 8.1 2011-03

®

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Insulation co-ordination –
Part 1: Definitions, principles and rules**

**Coordination de l'isolement –
Partie 1: Définitions, principes et règles**

<https://standards.iteh.ai/standards/iec/60071-1-2006>
<https://standards.iteh.ai/standards/iec/b293a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.080.30

ISBN 978-2-8891-4947-5

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references.....	6
3 Terms and definitions.....	7
4 Symbols and abbreviations.....	14
4.1 General.....	14
4.2 Subscripts.....	14
4.3 Letter symbols.....	14
4.4 Abbreviations.....	15
5 Procedure for insulation co-ordination.....	15
5.1 General outline of the procedure.....	15
5.2 Determination of the representative voltages and overvoltages (U_{rp}).....	17
5.3 Determination of the co-ordination withstand voltages (U_{cw}).....	18
5.4 Determination of the required withstand voltage (U_{rw}).....	18
5.5 Selection of the rated insulation level.....	19
5.6 List of standard rated short-duration power frequency withstand voltages.....	20
5.7 List of standard rated impulse withstand voltages.....	20
5.8 Ranges for highest voltage for equipment.....	20
5.9 Environmental conditions.....	20
5.10 Selection of the standard insulation level.....	21
5.11 Background of the standard insulation levels.....	25
6 Requirements for standard withstand voltage tests.....	27
6.1 General requirements.....	27
6.2 Standard short-duration power frequency withstand voltage tests.....	28
6.3 Standard impulse withstand voltage tests.....	28
6.4 Alternative test situation.....	29
6.5 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range I.....	29
6.6 Phase-to-phase and longitudinal insulation standard withstand voltage tests for equipment in range II.....	30
Annex A (normative) Clearances in air to assure a specified impulse withstand voltage installation.....	31
Annex B (informative) Values of rated insulation levels for $1\text{kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries.....	36
Bibliography.....	37
Figure 1 – Flow chart for the determination of rated or standard insulation level.....	16

Table 1 – Classes and shapes of overvoltages, Standard voltage shapes and Standard withstand voltage tests	17
Table 2 – Standard insulation levels for range I ($1\text{kV} < U_m \leq 245\text{ kV}$).....	23
Table 3 – Standard insulation levels for range II ($U_m > 245\text{ kV}$)	24
Table A.1 – Correlation between standard rated lightning impulse withstand voltages and minimum air clearances	32
Table A.2 – Correlation between standard rated switching impulse withstand voltages and minimum phase-to-earth air clearances.....	34
Table A.3 – Correlation between standard rated switching impulse withstand voltages and minimum phase-to-phase air clearances	35
Table B.1- Values of rated insulation levels for $1\text{kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries	36

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

<https://standards.iteh.ai> IEC 60071-1:2006

<https://standards.iteh.ai/standards/iec/b293a479-d71a-4232-a23e-cdb41d5936a0/iec-60071-1-2006>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSULATION CO-ORDINATION –

Part 1: Definitions, principles and rules

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 60071-1 consists of the eight edition (2006) [documents 28/176/FDIS and 28/177/RVC] and its amendment 1 (2010) [documents 28/198A/FDIS and 28/201/RVD]. It bears the edition number 8.1.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 60071-1 has been prepared by IEC technical committee 28: Insulation co-ordination.

The main changes from the previous edition are as follows:

- in the definitions (3.26, 3.28 and 3.29) and in the environmental conditions (5.9) taken into account clarification of the atmospheric and altitude corrections involved in the insulation co-ordination process;
- in the list of standard rated short-duration power frequency withstand voltages reported in 5.6 addition of 115 kV;
- in the list of standard rated impulse withstand voltages reported in 5.7, addition of 200 kV and 380 kV;
- in the standard insulation levels for range I ($1\text{kV} < U_m \leq 245\text{ kV}$) (Table 2) addition of the highest voltage for equipment $U_m = 100\text{ kV}$;
- in the standard insulation levels for range II ($U_m > 245\text{ kV}$) (Table 3) replacement of 525 kV by 550 kV and of 765 kV by 800 kV;
- in order to remove that part in the next revision of IEC 60071-2, addition of Annex A dealing with clearances in air to assure a specified impulse withstand voltage in installation;
- in Annex B, limitation at two U_m values for the values of rated insulation levels for $1\text{kV} < U_m \leq 245\text{ kV}$ for highest voltages for equipment U_m not standardized by IEC based on current practice in some countries.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The IEC 60071 comprises the following parts under the general title *Insulation co-ordination*:

Part 1: Definitions, principles and rules

Part 2: Application guide

Part 4: Computational guide to insulation co-ordination and modelling of electrical networks

Part 5: Procedures for high-voltage direct current (HVDC) converter stations

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INSULATION CO-ORDINATION –

Part 1: Definitions, principles and rules

1 Scope

This part of IEC 60071 applies to three-phase a.c. systems having a highest voltage for equipment above 1 kV. It specifies the procedure for the selection of the rated withstand voltages for the phase-to-earth, phase-to-phase and longitudinal insulation of the equipment and the installations of these systems. It also gives the lists of the standard withstand voltages from which the rated withstand voltages should be selected.

This standard recommends that the selected withstand voltages should be associated with the highest voltage for equipment. This association is for insulation co-ordination purposes only. The requirements for human safety are not covered by this standard.

Although the principles of this standard also apply to transmission line insulation, the values of their withstand voltages may be different from the standard rated withstand voltages.

The apparatus committees are responsible for specifying the rated withstand voltages and the test procedures suitable for the relevant equipment taking into consideration the recommendations of this standard.

NOTE In IEC 60071-2, Application Guide, all rules for insulation co-ordination given in this standard are justified in detail, in particular the association of the standard rated withstand voltages with the highest voltage for equipment. When more than one set of standard rated withstand voltages is associated with the same highest voltage for equipment, guidance is provided for the selection of the most suitable set.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:2002, *IEC standard voltages*

IEC 60060-1:1989, *High-voltage test techniques – Part 1: General definitions and test requirements*

IEC 60071-2, *Insulation co-ordination – Part 2: Application guide*

IEC 60099-4, *Surge arresters – Part 4: Metal-oxide surge arresters without gaps for a.c. systems*

IEC 60507, *Artificial pollution tests on high-voltage insulators to be used on a.c. systems*

IEC 60633, *Terminology for high-voltage direct current (HVDC) transmission*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

insulation co-ordination

selection of the dielectric strength of equipment in relation to the operating voltages and overvoltages which can appear on the system for which the equipment is intended and taking into account the service environment and the characteristics of the available preventing and protective devices

[IEC 604-03-08:1987, modified]

NOTE By "dielectric strength" of the equipment, is meant here its rated or its standard insulation level as defined in 3.35 and 3.36 respectively.

3.2

external insulation

distances in atmospheric air, and the surfaces in contact with atmospheric air of solid insulation of the equipment which are subject to dielectric stresses and to the effects of atmospheric and other environmental conditions from the site, such as pollution, humidity, vermin, etc.

[IEC 604-03-02:1987, modified]

NOTE External insulation is either weather protected or non-weather protected, designed to operate inside or outside closed shelters respectively.

3.3

internal insulation

internal distances of the solid, liquid, or gaseous insulation of equipment which are protected from the effects of atmospheric and other external conditions

[IEC 604-03-03:1987]

3.4

self-restoring insulation

insulation which, after a short time, completely recovers its insulating properties after a disruptive discharge during test

[IEC 604-03-04:1987, modified]

NOTE Insulation of this kind is generally, but not necessary, external insulation

3.5

non self-restoring insulation

insulation which loses its insulating properties, or does not recover them completely, after a disruptive discharge during test

[IEC 604-03-05:1987, modified]

NOTE The definitions of 3.4 and 3.5 apply only when the discharge is caused by the application of a test voltage during a dielectric test. However, discharges occurring in service may cause a self-restoring insulation to lose partially or completely its original insulating properties.

3.6

insulation configuration terminal

any of the terminals between any two of which a voltage that stresses the insulation can be applied. The types of terminal are:

- (a) phase terminal, between which and the neutral is applied in service the phase-to-neutral voltage of the system;
- (b) neutral terminal, representing, or connected to, the neutral point of the system (neutral terminal of transformers, etc.);
- (c) earth terminal, always solidly connected to earth in service (tank of transformers, base of disconnectors, structures of towers, ground plane, etc.).

3.7

insulation configuration

complete geometric configuration of the insulation in service, consisting of the insulation and of all terminals. It includes all elements (insulating and conducting) which influence its dielectric behaviour. The following insulation configurations are identified:

3.7.1

three-phase insulation configuration

configuration having three phase terminals, one neutral terminal and one earth terminal

3.7.2

phase-to-earth (p-e) insulation configuration

three-phase insulation configuration where two phase terminals are disregarded and, except in particular cases, the neutral terminal is earthed

3.7.3

phase-to-phase(p-p) insulation configuration

three-phase insulation configuration where one phase terminal is disregarded. In particular cases, the neutral and the earth terminals are also disregarded

3.7.4

longitudinal(t-t) insulation configuration

insulation configuration having two phase terminals and one earth terminal. The phase terminals belong to the same phase of a three-phase system temporarily separated into two independently energized parts (e.g. open switching devices). The four terminals belonging to the other two phases are disregarded or earthed. In particular cases one of the two phase terminals considered is earthed

3.8

nominal voltage of a system

U_n

suitable approximate value of voltage used to designate or identify a system

[IEC 601-01-21:1985]

3.9

highest voltage of a system

U_s

highest value of the phase-to-phase operating voltage (r.m.s. value) which occurs under normal operating conditions at any time and at any point in the system

[IEC 601-01-23:1985, modified]

3.10

highest voltage for equipment

U_m

highest value of phase-to-phase voltage (r.m.s. value) for which the equipment is designed in respect of its insulation as well as other characteristics which relate to this voltage in the relevant equipment Standards. Under normal service conditions specified by the relevant apparatus committee this voltage can be applied continuously to the equipment

[IEC 604-03-01:1987, modified]

3.11

isolated neutral system

system where the neutral point is not intentionally connected to earth, except for high impedance connections for protection or measurement purposes

[IEC 601-02-24:1985]

3.12**solidly earthed neutral system**

system whose neutral point(s) is(are) earthed directly

[IEC 601-02-25:1985]

3.13**impedance earthed (neutral) system**

system whose neutral point(s) is(are) earthed through impedances to limit earth fault currents

[IEC 601-02-26:1985]

3.14**resonant earthed (neutral) system**

system in which one or more neutral points are connected to earth through reactances which approximately compensate the capacitive component of a single-phase-to-earth fault current

[IEC 601-02-27:1985]

NOTE With resonant earthing of a system, the residual current in the fault is limited to such an extent that an arcing fault in air is usually self-extinguishing.

3.15**earth fault factor*****k***

at a given location of a three-phase system, and for a given system configuration, the ratio of the highest r.m.s. phase-to-earth power frequency voltage on a healthy phase during a fault to earth affecting one or more phases at any point on the system to the r.m.s. phase-to-earth power frequency voltage which would be obtained at the given location in the absence of any such fault

[IEC 604-03-06:1987]

3.16**overvoltage**

any voltage:

- between one phase conductor and earth or across a longitudinal insulation having a peak value exceeding the peak of the highest voltage of the system divided by $\sqrt{3}$;

[IEC 604-03-09, modified] or

- between phase conductors having a peak value exceeding the amplitude of the highest voltage of the system

[IEC 604-03-09:1987, modified]

NOTE Unless otherwise clearly indicated, such as for surge arresters, overvoltage values expressed in p.u. refer to $U_s \times \sqrt{2}/\sqrt{3}$

3.17**classification of voltages and overvoltages**

according to their shape and duration, voltages and overvoltages are divided in the following classes

NOTE More details on the following six first voltages and overvoltages are also given in Table 1.

3.17.1**continuous (power frequency) voltage**

power-frequency voltage, considered having constant r.m.s. value, continuously applied to any pair of terminals of an insulation configuration

3.17.2
temporary overvoltage
TOV

power frequency overvoltage of relatively long duration

[IEC 604-03-12:1987, modified]

NOTE The overvoltage may be undamped or weakly damped. In some cases its frequency may be several times smaller or higher than power frequency.

3.17.3
transient overvoltage

short-duration overvoltage of few milliseconds or less, oscillatory or non-oscillatory, usually highly damped

[IEC 604-03-13:1987]

NOTE Transient overvoltages may be immediately followed by temporary overvoltages. In such cases the two overvoltages are considered as separate events.

Transient overvoltages are divided into:

3.17.3.1
slow-front overvoltage
SFO

transient overvoltage, usually unidirectional, with time to peak $20 \mu\text{s} < T_p \leq 5\,000 \mu\text{s}$, and tail duration $T_2 \leq 20 \text{ms}$

3.17.3.2
fast-front overvoltage
FFO

transient overvoltage, usually unidirectional, with time to peak $0,1 \mu\text{s} < T_1 \leq 20 \mu\text{s}$, and tail duration $T_2 < 300 \mu\text{s}$

3.17.3.3
very-fast-front overvoltage
VFFO

transient overvoltage, usually unidirectional with time to peak $T_f \leq 0,1 \mu\text{s}$, and with or without superimposed oscillations at frequency $30 \text{kHz} < f < 100 \text{MHz}$

3.17.4
combined overvoltage

consisting of two voltage components simultaneously applied between each of the two phase terminals of a phase-to-phase (or longitudinal) insulation and earth. It is classified by the component of higher peak value (temporary, slow-front, fast-front or very-fast-front)

3.18
standard voltage shapes for test

the following voltage shapes are standardized:

NOTE More details on the following three first standard voltage shapes are given in IEC 60060-1 and also in Table 1.

3.18.1
standard short-duration power-frequency voltage

sinusoidal voltage with frequency between 48 Hz and 62 Hz, and duration of 60 s

3.18.2
standard switching impulse

impulse voltage having a time to peak of 250 μs and a time to half-value of 2 500 μs

3.18.3**standard lightning impulse**

impulse voltage having a front time of 1,2 μs and a time to half-value of 50 μs

3.18.4**standard combined switching impulse**

for phase-to-phase insulation, a combined impulse voltage having two components of equal peak value and opposite polarity.

The positive component is a standard switching impulse and the negative one is a switching impulse whose times to peak and half value should not be less than those of the positive impulse. Both impulses should reach their peak value at the same instant. The peak value of the combined voltage is, therefore, the sum of the peak values of the components

3.18.5**standard combined voltage**

for longitudinal insulation, a combined voltage having a standard impulse on one terminal and a power frequency voltage on the other terminal. The impulse component is applied at the peak of the power frequency voltage of opposite polarity

3.19**representative overvoltages** **U_{rp}**

overvoltages assumed to produce the same dielectric effect on the insulation as overvoltages of a given class occurring in service due to various origins.

They consist of voltages with the standard shape of the class, and may be defined by one value or a set of values or a frequency distribution of values that characterize the service conditions

NOTE This definition also applies to the continuous power frequency voltage representing the effect of the service voltage on the insulation.

3.20**overvoltage limiting device**

device which limits the peak values of the overvoltages or their durations or both. They are classified as preventing devices (e.g., a preinsertion resistor), or as protective devices (e.g., a surge arrester)

3.21**lightning [or switching] impulse protective level** **U_{pl} [or U_{ps}]**

maximum permissible peak voltage value on the terminals of a protective device subjected to lightning [or switching] impulses under specific conditions

[IEC 604-03-56:1987 and IEC 604-03-57:1987]

3.22**performance criterion**

basis on which the insulation is selected so as to reduce to an economically and operationally acceptable level the probability that the resulting voltage stresses imposed on the equipment will cause damage to equipment insulation or affect continuity of service. This criterion is usually expressed in terms of an acceptable failure rate (number of failures per year, years between failures, risk of failure, etc.) of the insulation configuration

3.23**withstand voltage**

value of the test voltage to be applied under specified conditions in a withstand voltage test, during which a specified number of disruptive discharges is tolerated. The withstand voltage is designated as:

- a) conventional assumed withstand voltage, when the number of disruptive discharges tolerated is zero. It is deemed to correspond to a withstand probability $P_w = 100\%$;
- b) statistical withstand voltage, when the number of disruptive discharges tolerated is related to a specified withstand probability. In this standard, the specified probability is $P_w = 90\%$.

NOTE In this standard, for non-self-restoring insulation are specified conventional assumed withstand voltages, and for self-restoring insulation are specified statistical withstand voltages.

3.24**co-ordination withstand voltage** U_{cw}

for each class of voltage, the value of the withstand voltage of the insulation configuration in actual service conditions, that meets the performance criterion

3.25**co-ordination factor** K_c

factor by which the value of the representative overvoltage must be multiplied in order to obtain the value of the co-ordination withstand voltage

3.26**standard reference atmospheric conditions**

atmospheric conditions to which the standardized withstand voltages apply (see 5.9)

3.27**required withstand voltage** U_{rw}

test voltage that the insulation must withstand in a standard withstand voltage test to ensure that the insulation will meet the performance criterion when subjected to a given class of overvoltages in actual service conditions and for the whole service duration. The required withstand voltage has the shape of the co-ordination withstand voltage, and is specified with reference to all the conditions of the standard withstand voltage test selected to verify it

3.28**atmospheric correction factor** K_t

factor to be applied to the co-ordination withstand voltage to account for the difference in dielectric strength between the average atmospheric conditions in service and the standard reference atmospheric conditions

It applies to external insulation only, for all altitudes

NOTE 1 The factor K_t allows the correction of test voltages taking into account the difference between the actual atmospheric conditions during test and the standard reference atmospheric conditions. For the factor K_t , the atmospheric conditions taken into account are air pressure, temperature and humidity.

NOTE 2 For insulation co-ordination purposes usually only the air pressure correction needs to be taken into account.

3.29**altitude correction factor** K_a

factor to be applied to the co-ordination withstand voltage to account for the difference in dielectric strength between the average pressure corresponding to the altitude in service and the standard reference pressure

NOTE The altitude correction factor K_a is part of the atmospheric correction factor K_t .