

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC
61478
2001

AMENDEMENT 1
AMENDMENT 1
2003-02

Amendment 1

**Travaux sous tension –
Echelles en matériau isolant**

iTeh STANDARD PREVIEW
Amendment 1 (standards.iteh.ai)

Live working <https://standards.iteh.ai/catalog/standard/ist/61478-2001/AMD1/2003>

Ladders of insulating material

© IEC 2003 Droits de reproduction réservés — Copyright - all rights reserved

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

B

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

AVANT-PROPOS

Le présent amendement a été établi par le comité d'études 78 de la CEI: Travaux sous tension.

Le texte de cet amendement est issu des documents suivants:

FDIS	Rapport de vote
78/493/FDIS	78/512/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cet amendement.

Le comité a décidé que le contenu de la publication de base et de ses amendements ne sera pas modifié avant 2008. A cette date, la publication sera

- reconduite;
- supprimée;
- remplacée par une édition révisée, ou
- amendée.

iTeh STANDARD PREVIEW (standards.iteh.ai)

Page 8

[IEC 61478:2001/AMD1:2003](#)

Ajouter la nouvelle référence suivante:
<https://standards.iteh.ai/catalog/standards/sist/e169edd4-4193-46f7-adaf-a14e7b31e3/iec-61478-2001-amd1-2003>

CEI 60417 (toutes les parties) [DB-2000]¹⁾, *Symboles graphiques utilisables sur le matériel*

Page 20

5.6 Marquage

Remplacer le dernier élément de la liste existante des marquages par les éléments suivants:

- le symbole IEC 60417-5216:2002-11 – Approprié aux travaux sous tension; double triangle;
 NOTE Pour le symbole, la proportion exacte de la hauteur de la figure à la base du triangle est de 1,43. Dans un souci pratique, la proportion peut se situer entre les valeurs de 1,4 et 1,5.
- le numéro de la norme CEI applicable, immédiatement adjacent au symbole avec l'année de publication (quatre chiffres), (IEC 61478:2001).

¹⁾ « DB » se réfère à la base de données « on-line » de la CEI.

FOREWORD

This amendment has been prepared by IEC technical committee 78: Live working.

The text of this amendment is based on the following documents:

FDIS	Report on voting
78/493/FDIS	78/512/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until 2008. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

Page 9

iTeh STANDARD PREVIEW (standards.iteh.ai)

2 Normative references

IEC 61478:2001/AMD1:2003

Add the following new reference:
standards.iteh.ai/catalog/standards/sist/e169edd4-4193-46f7-adaf-a14e7b131e3/iec-61478-2001-amd1-2003

IEC 60417 (all parts) [DB-2000]¹⁾, *Graphical symbols for use on equipment*

Page 21

5.6 Marking

Replace the last item of the existing list of markings by the following items:

- symbol IEC 60417–5216:2002-11 – Suitable for live working; double triangle;
 NOTE The exact ratio of the height of the figure to the base of the triangle is 1,43. For the purpose of convenience, this ratio can be between the values of 1,4 and 1,5.
- number of the relevant IEC standard immediately adjacent to the symbol, with year of publication (four digits), (IEC 61478:2001).

¹⁾ “DB” refers to the IEC on-line database.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 61478:2001/AMD1:2003](#)
<https://standards.iteh.ai/catalog/standards/sist/e169edd4-4193-46f7-adaf-a14e7b3131e3/iec-61478-2001-amd1-2003>

ISBN 2-8318-6876-9



9 782831 868769

ICS 13.260; 29.240; 29.260.99
