

TECHNICAL SPECIFICATION

**Recommendations for small renewable energy and hybrid systems for rural
electrification –
Part 2: From requirements to a range of electrification systems**

IEC TS 62257-2:2004

<https://standards.iteh.ai/en/standards/iec/as2c2053-cf1e-4289-b239-1faa5f876737/iec-ts-62257-2-2004>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2004 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00



https://standards.iteh.ai/ IEC TS 62257-2:2004
https://standards.iteh.ai/iec/ae2c2053-0f1e-4289-b239-1faa5f876737/iec-ts-62257-2-2004

TECHNICAL SPECIFICATION

**Recommendations for small renewable energy and hybrid systems for rural
electrification –
Part 2: From requirements to a range of electrification systems**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE **XB**

ICS 27.160; 27.180

ISBN 2-8318-7525-0

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references.....	8
3 Terms and definitions	9
4 Methodology for non technical preliminary studies.....	10
4.1 Place and role of preliminary studies in a decentralized rural electrification project.....	10
4.2 Specifications of the preliminary study	10
4.3 The stages of a socio-economic study.....	15
5 Classification of electrification systems	15
5.1 Introduction to a range of systems	15
5.2 Users requirements	16
5.3 Typology of qualitative requirements	16
5.4 Typology of quantitative requirements.....	17
5.5 Classification for electricity services provided.....	18
5.6 Assisted selection of production subsystem	18
5.7 Typology of decentralized electrification systems	18
6 Electrification systems architecture.....	21
6.1 General	21
6.2 General presentation of isolated electrification systems.....	21
6.3 Combining subsystems	22
6.4 Functional diagrams.....	24
6.5 Related references	25
6.6 Limits between production, distribution and demand/application subsystems	25
6.7 Summary of the different electrification system types	25
Annex A (informative) Stages of a socio-economic study (see Clause 4).....	26
A.1 General	26
A.2 Preparation phase	26
A.3 Drawing up of the questionnaires, choice of surveyors and choice of sample.....	27
A.4 Conducting the survey - Analysis of the results.....	27
A.5 Extrapolation of the results	27
Annex B (informative) Analysis of the type of receivers installed versus types of use and demonstrating seasonable variability (where applicable) (see Clause 5).....	28
B.1 Domestic use.....	28
B.2 Analysis of the type of receivers versus usage types	30
Annex C (informative) Supply quality indicators for isolated electrification systems (see Clause 5).....	32

Annex D (informative) Assisted selection of production subsystem (see Clause 5)	34
D.1 Characteristics of possible production subsystems	34
D.2 Assisted selection of a decentralized production system suited to the requirement.....	34
Annex E (informative) Functional diagrams (See Clause 6).....	36
E.1 Glossary of symbols.....	36
E.2 Architectures of systems.....	37
Figure 1 – Example of the content of a non technical preliminary study	11
Figure 2 – Systems architecture and dispatchable energy	19
Figure 3 – General configuration of an electrification system.....	23
Figure A.1 – Flowchart of the stages of a socio economic study.....	26
Figure D.1 – Better adequacy of production subsystems solutions with supply availability and daily duration of service	35
Figure E.1 – Type T ₁ I-a system	38
Figure E.2 – Type T ₁ I-b system	39
Figure E.3 – Type T ₁ I-c system	40
Figure E.4 – Type T ₁ I-d system	41
Figure E.5 – Type T ₂ I system	43
Figure E.6 – Type T ₃ I-a system	45
Figure E.7 – Type T ₃ I-b system	46
Figure E.8 – Type T ₄ I system	48
Figure E.9 – Type T ₅ I system	49
Figure E.10 – Type T ₆ I system	50
Figure E.11 – General architecture of a micropower plant supplying a microgrid	52
Figure E.12 – Type T ₂ C system	53
Figure E.13 – Type T ₃ C-a system	55
Figure E.14 – Type T ₃ C-b system	56
Figure E.15 – Type T ₄ C-a system	58
Figure E.16 – Type T ₄ C-b system	59
Figure E.17 – Type T ₅ C system	61
Figure E.18 – Type T ₆ C system	63
Table 1 – Application types and types of uses.....	16
Table 2 – Expected quality of the supply.....	17
Table 3 – Synthesis of quantitative requirements/category (examples of type of user and use)	17
Table 4 – Typology of decentralized electrification systems.....	18
Table 5 – Preliminary range of relevant (as a minimum) decentralized electrification systems	20
Table 6 – Recapitulation of characteristics of different types of isolated electrification systems	25
Table C.1 – Combined categorization	32
Table C.2 – Service specification (example)	33

Table D.1 – Principles and characteristics of production subsystems	34
Table E.1 – Glossary of symbols	36
Table E.2 – List of cases, type T ₁ I	37
Table E.3 – List of cases, type T ₃ I	44
Table E.4 – List of cases, type T ₃ C	54
Table E.5 – List of cases, type T ₄ C	57

Withdrawing

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

IEC TS 62257-2:2004

<https://standards.iteh.ai/catalog/standards/iec/a62c2053-cf1e-4289-b239-1faa5f876737/iec-ts-62257-2-2004>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**RECOMMENDATIONS FOR SMALL RENEWABLE ENERGY
AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –****Part 2: From requirements to a range of electrification systems**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 62257-2, which is a technical specification, has been prepared by IEC technical committee 82: Solar photovoltaic energy systems.

This technical specification is to be used in conjunction with IEC 62257 series.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
82/302/DTS	82/320/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2. It was developed in cooperation with other IEC technical committees and subcommittees dealing with renewable energies and related matters, namely technical committee 21 ("Secondary cells and batteries"), subcommittee 21A ("Secondary cells and batteries containing alkaline or other non-acid electrolytes"), technical committee 64 ("Electrical installations and protection against electric shock"), technical committee 88 ("Wind turbines"), and others.

This document is based on IEC/PAS 62111(1999); it cancels and replaces the relevant parts of IEC/PAS 62111.

The committee has decided that the contents of this publication will remain unchanged until 2007. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

INTRODUCTION

The IEC 62257 series intends to provide to different players involved in rural electrification projects (such as project implementers, project contractors, project supervisors, installers, etc.) documents for the setting up of renewable energy and hybrid systems with AC voltage below 500 V, DC voltage below 50 V and power below 50 kVA.

These documents are recommendations:

- a) to choose the right system for the right place,
- b) to design the system,
- c) to operate and maintain the system.

These documents are focused only on rural electrification concentrating on but not specific to developing countries. They shall not be considered as all inclusive to rural electrification. The documents try to promote the use of renewable energies in rural electrification; they do not deal with clean mechanisms development at this time (CO₂ emission, carbon credit, etc.). Further developments in this field could be introduced in future steps.

This consistent set of documents is best considered as a whole with different parts corresponding to items for safety, sustainability of systems and at the lowest life cycle cost as possible. One of the main objectives is to provide the minimum sufficient requirements, relevant to the field of application that is: small renewable energy and hybrid off-grid systems.

The purpose of this part of the IEC 62257 series is to propose a range of renewable energy based electrification systems able to meet the requirements of customers identified in the field of decentralized rural electrification projects.

RECOMMENDATIONS FOR SMALL RENEWABLE ENERGY AND HYBRID SYSTEMS FOR RURAL ELECTRIFICATION –

Part 2: From requirements to a range of electrification systems

1 Scope

The scope of this part of the IEC 62257 series is to propose a methodological approach for the setting up and carrying out of socio-economic studies as part of the framework of decentralized rural electrification projects. It is addressed to project teams and in particular to experts in charge of socio-economic studies in international projects.

The amount of detail gathered and the requisite number of experts needed would depend on the scale of the proposed project. For large projects involving many households, a detailed study would be required, for a project which involves a single or few households, the study could be truncated.

The information coming from such preliminary studies could be used for several purposes, such as more complete economic and financial studies of the electrification project.

This part of IEC 62257 also provides some structures as technical solutions that could be recommended, depending on the qualitative and quantitative energy demands, consistent with the needs and financial situation of the customers.

Then, in relation with each model of the proposed range of systems, electrical architectures are proposed to technical project managers to assist in designing the systems.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60617 (all parts)[DB]¹, *Graphical symbols for diagrams*

IEC 62257-1, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 1: General introduction to rural electrification*

IEC 62257-3, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 3: Project development and management*²

IEC 62257-4, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 4: System selection and design*²

IEC 62257-5, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 5: Safety rules*²

¹ "DB" refers to the IEC on-line database.

² Under consideration.

IEC 62257-6, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 6: Acceptance, operation, maintenance and replacement*²

IEC 62257-7, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 7: Technical specifications: generators*²

IEC 62257-8, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 8: Technical specifications: batteries and converters*²

IEC 62257-9, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 9: Technical specifications: integrated systems*²

IEC 62257-10, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 10: Technical specifications: energy manager*²

IEC 62257-11, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 11: Technical specifications: considerations for grid connection*²

IEC 62257-12, *Recommendations for small renewable energy and hybrid systems for rural electrification – Part 12: Other topics*²

3 Terms and definitions

For the purposes of this part of the IEC 62257 series, the following terms and definitions apply.

3.1

REN

renewable energy

3.2

hybrid system

multi-sources system with at least two kinds of technologies

3.3

dispatchable power system

source, generator, system is dispatchable if delivered power is available at any specified time (for example, a genset is a dispatchable system, REN generator is usually a non dispatchable power system)

3.4

non dispatchable power system

a non dispatchable system is resource dependent; power might not be available at a specified time

3.5

storage

storage of energy produced by one of the generators of the system and which can be reconverted through the system to electricity

3.6

micropower plant

power plant that produces less than 50 kVA through the use of a single resource or hybrid system

² Under consideration.

3.7**microgrid**

grid that transfers a capacity level less than 50 kVA and powered by a micropower plant

3.8**Individual Electrification System****IES**

micropower plant system that supplies electricity to one consumption point usually with a single energy resource point

3.9**Collective Electrification System****CES**

micropower plant and microgrid that supplies electricity to multiple consumption points using a single or multiple energy resource points

3.10**isolated site**

electric characteristic to define a specific location not currently connected to a national/regional grid

3.11**remote site/area**

geographic characteristic to define a specific location far from developed infrastructures, specifically energy distribution

4 Methodology for non technical preliminary studies**4.1 Place and role of preliminary studies in a decentralized rural electrification project**

It is strongly recommended that it is unwise to launch an electrification project against the wishes of the local institutions and populations. A good understanding of the needs and wishes of the local populations is recommended, to know what is their demand, their capacity and willingness to pay for a modern energy service.

If all the socio-economic data are available, they have to be properly collected and processed for this purpose.

If not, a preliminary study is recommended that will be the first stage in the establishment of a feasibility study for a decentralized rural electrification project. Its role is to allow a better understanding of the areas concerned by the various project experts and such a study would make available some of the data needed for technical evaluations, economic, financial and legal analyses, and for the carrying out of the project in general.

In this Clause, a method is suggested to obtain the various information needed.

Some of the information described in the following section might be obtained from governmental organizations prior to specific sites visits.

4.2 Specifications of the preliminary study**4.2.1 General**

A socio-economic study shall provide a certain amount of data to the experts in charge of the financial, techno-economic and organizational studies. It also allows a better understanding of the global environment of the project and can provide information to the community about the scope of the project.

The following subclauses suggest some considerations concerning data to be collected and analyzed in consideration with:

- general information on the environment of the project,
- techno economic study,
- organizational study,
- financial analysis.

Figure 1 is an illustration of the main topics that should be investigated in the socio-economic study.




Figure 1 – Example of the content of a non technical preliminary study

4.2.2 General data for a better understanding of the project environment

The following topics should be considered by project contractors. It's their role to determine the relevant importance of each of these categories in regard to a specific project or programme.

4.2.2.1 Sociological data

This data is important for an understanding of the local population. It is essential to look at the organizational, cultural and ethnological structures of the society. In particular, one should investigate the way of life, the sanitary conditions, the national and local languages, the level of education and literacy, the technical sophistication level and the presence of organizations and associations. In addition, the role of male and female in the social organization of the village shall be taken into account.

4.2.2.2 The communities' priorities for development

It is important to understand the population's opinions of their village. What are their priorities for improvement in their daily life? (Such as water pumping, construction of a hospital, of a school, communications infrastructure, electricity, etc.).

In the case of a rural electrification project, what are the priorities for the village as expressed by the population and the local authorities?

4.2.2.3 Economic activities and possible development

Knowledge of the economic activities in the community allows a better general understanding of the environment of the project; it also helps in understanding the dynamics of local development, in order to evaluate the evolution of demand in energy in the coming years.

One can compile the economic activities of the village (commerce, handicrafts, animal husbandry, agriculture, etc.) and look at their relative importance. It would also be useful to look at potential activities due to electricity.

4.2.2.4 The development projects under way in the region

One should look at the local development projects under way, who are the instigators and who are the beneficiaries, what are the impacts on the population, and what would be the impacts on a future electrification project.

4.2.2.5 Environmental considerations

One of the clear drivers in the use of renewable technology is the favorable impact of these systems on the environment as compared to the conventional sources, primarily diesel and grid extension. The impact of any technology choice on the environment, from a carbon, plant footprint, noise and visual impact should be assessed. Understanding the desires of the local participants will be important in this endeavor.

4.2.3 Necessary data for the techno-economic study

Although this information is not strictly in the domain of the socio-economic expert, it shall be collected in the initial phases of any analysis as it is essential to the techno-economic study. The socio-economic expert is therefore asked to collect this data, being usually the first project person to visit a rural community.

4.2.3.1 Geographic and demographic data

In particular one shall obtain the geographical coordinates of the village, its topography, local fauna, and the geographical distribution of the inhabitants. The geographic layout of the community is important because it impacts the economics of meeting the power requirements for the community. If the community is widely dispersed, the cost of a local distribution network may be prohibitive, at which point individual home systems or small cluster systems may be the most cost-effective solutions. The analysis will require specification of the location, power, and energy requirements of each load. It is also important to obtain an understanding of the acceptance of different qualities of service that these electrification options offer. If possible, one should collect data on the climate, local natural resources, site transportation issues and other important sighting issues such as land ownership and right of way issues.

4.2.3.2 Human resources

The personnel resources available in the community, region and country shall be considered when conducting an analysis for renewable based power systems. The infrastructure required for the project installation, long term operation, and system maintenance shall be in place to insure its long-term sustainability. In most cases, a multi layer infrastructure is required, a local system operator who is able to address short term incidents, a regional service center capable of conducting system repair and component assessment and a country or globally regional center that can provide timely replacement of major components and detailed service. Without a specified institutional framework, it will be impossible to provide a quality level of service at a cost that can be sustainable over the life of the project. The whole infrastructure framework relies on people with the right level of training and equipment to perform their specified tasks in the right geographic area with enough systems to guarantee a successful business model. If the infrastructure is not currently in place, care shall be taken to investigate whether the resources are available to create one.