

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Protection against lightning –
Part 4: Electrical and electronic systems within structures**

**Protection contre la foudre –
Partie 4: Réseaux de puissance et de communication dans les structures**

IEC 62305-4:2006

<https://standards.iteh.ai/standards/iec/568457f-7b42-4aae-8f11-e9f2a44948fe/iec-62305-4-2006>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2006 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Protection against lightning –
Part 4: Electrical and electronic systems within structures**

**Protection contre la foudre –
Partie 4: Réseaux de puissance et de communication dans les structures**

IEC 62305-4:2006

<https://standards.iteh.ai/catalog/standards/iec/568457f-7b42-4aac-8f11-e9f2a44948fe/iec-62305-4-2006>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XD

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	9
2 Normative references	9
3 Terms and definitions	10
4 Design and installation of a LEMP protection measures system (LPMS).....	23
4.1 Design of an LPMS.....	16
4.2 Lightning protection zones (LPZ).....	16
4.3 Basic protection measures in an LPMS	20
5 Earthing and bonding	20
5.1 Earth termination system.....	21
5.2 Bonding network.....	23
5.3 Bonding bars	28
5.4 Bonding at the boundary of an LPZ	28
5.5 Material and dimensions of bonding components.....	28
6 Magnetic shielding and line routing.....	29
6.1 Spatial shielding.....	29
6.2 Shielding of internal lines	29
6.3 Routing of internal lines.....	29
6.4 Shielding of external lines	30
6.5 Material and dimensions of magnetic shields.....	30
7 Coordinated SPD protection	30
8 Management of an LPMS	31
8.1 LPMS management plan	31
8.2 Inspection of an LPMS	33
8.3 Maintenance.....	34
Annex A (informative) Basics for evaluation of electromagnetic environment in a LPZ	35
Annex B (informative) Implementation of LEMP protection measures for electronic systems in existing structures	61
Annex C (informative) SPD coordination	78
Annex D (informative) Selection and installation of a coordinated SPD protection.....	96
Bibliography.....	101
Figure 1 – General principle for the division into different LPZ	13
Figure 2 – Protection against LEMP – Examples of possible LEMP protection measures systems (LPMS)	15
Figure 3 – Examples for interconnected LPZ.....	18
Figure 4 – Examples for extended lightning protection zones	19
Figure 5 – Example of a three-dimensional earthing system consisting of the bonding network interconnected with the earth termination system.....	21
Figure 6 – Meshed earth termination system of a plant	22

Figure 7 – Utilization of reinforcing rods of a structure for equipotential bonding	24
Figure 8 – Equipotential bonding in a structure with steel reinforcement	25
Figure 9 – Integration of electronic systems into the bonding network	26
Figure 10 – Combinations of integration methods of electronic systems into the bonding network	27
Figure A.1 – LEMP situation due to lightning flash	37
Figure A.2 – Simulation of the rise of magnetic field by damped oscillations	39
Figure A.3 – Large volume shield built by metal reinforcement and metal frames	40
Figure A.4 – Volume for electrical and electronic systems inside an inner LPZ n	41
Figure A.5 – Reducing induction effects by line routing and shielding measures	43
Figure A.6 – Example of an LPMS for an office building	44
Figure A.7 – Evaluation of the magnetic field values in case of a direct lightning flash	46
Figure A.8 – Evaluation of the magnetic field values in case of a nearby lightning flash	48
Figure A.9 – Distance s_a depending on rolling sphere radius and structure dimensions	51
Figure A.10 – Types of grid-like large volume shields	53
Figure A.11 – Magnetic field strength $H_{1/\max}$ inside a grid-like shield Type 1	54
Figure A.12 – Magnetic field strength $H_{1/\max}$ inside a grid-like shield Type 1	54
Figure A.13 – Low-level test to evaluate the magnetic field inside a shielded structure	56
Figure A.14 – Voltages and currents induced into a loop built by lines	57
Figure B.1 – Upgrading of LEMP protection measures and electromagnetic compatibility in existing structures	63
Figure B.2 – Possibilities to establish LPZs in existing structures	69
Figure B.3 – Reduction of loop area using shielded cables close to a metal plate	71
Figure B.4 – Example of a metal plate for additional shielding	72
Figure B.5 – Protection of aerials and other external equipment	74
Figure B.6 – Inherent shielding provided by bonded ladders and pipes	75
Figure B.7 – Ideal positions for lines on a mast (cross-section of steel lattice mast)	76
Figure C.1 – Example for the application of SPD in power distribution systems	79
Figure C.2 – Basic model for energy coordination of SPD	81
Figure C.3 – Combination of two voltage-limiting type SPDs	82
Figure C.4 – Example with two voltage-limiting type MOV 1 and MOV 2	84
Figure C.5 – Combination of voltage-switching type spark gap and voltage-limiting type MOV	85
Figure C.6 – Example with voltage-switching type spark gap and voltage-limiting type MOV	86
Figure C.7 – Determination of decoupling inductance for 10/350 μ s and 0,1kA/ μ s surges	87
Figure C.8 – Example with spark gap and MOV for a 10/350 μ s surge	89

Figure C.9 – Example with spark gap and MOV for 0,1kA/μs surge 91

Figure C.10 – Coordination variant I – Voltage-limiting type SPD 92

Figure C.11 – Coordination variant II – Voltage-limiting type SPD 93

Figure C.12 – Coordination variant III – Voltage-switching type SPD and voltage-limiting type SPD 93

Figure C.13 – Coordination variant IV – Several SPDs in one element 94

Figure C.14 – Coordination according to the “let through energy” method 94

Figure D.1 – Surge voltage between live conductor and bonding bar 97

Withstand

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 62305-4:2006
<https://standards.iteh.ai/catalog/standards/iec/568457f-7b42-4aae-8f11-e9f2a44948fe/iec-62305-4-2006>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

PROTECTION AGAINST LIGHTNING –

Part 4: Electrical and electronic systems within structures

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62305-4 has been prepared by IEC technical committee 81: Lightning protection.

The IEC 62305 series (Parts 1 to 5), is produced in accordance with the New Publications Plan, approved by National Committees (81/171/RQ (2001-06-29)), which restructures in a more simple and rational form and updates the publications of the IEC 61024 series, IEC 61312 series and the IEC 61663 series.

The text of this first edition of IEC 62305-4 is compiled from and replaces

- IEC 61312-1, first edition (1995);
- IEC 61312-2, first edition (1998);
- IEC 61312-3, first edition (2000);
- IEC 61312-4, first edition (1998).

The text of this standard is based on the following documents:

FDIS	Report on voting
81/265/FDIS	81/270/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted, as close as possible, in accordance with the ISO/IEC Directives, Part 2.

IEC 62305 consists of the following parts, under the general title *Protection against lightning*:

Part 1: General principles

Part 2: Risk management

Part 3: Physical damage to structures and life hazard

Part 4: Electrical and electronic systems within structures

Part 5: Services¹

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

IEC 62305-4:2006

<https://standards.iteh.ai/standards/iec/568457f-7b42-4aac-8f11-e9f2a44948fe/iec-62305-4-2006>

¹ To be published.

INTRODUCTION

Lightning as a source of harm is a very high-energy phenomenon. Lightning flashes release many hundreds of mega-joules of energy. When compared with the milli-joules of energy that may be sufficient to cause damage to sensitive electronic equipment in electrical and electronic systems within a structure, it is clear that additional protection measures will be necessary to protect some of this equipment.

The need for this International Standard has arisen due to the increasing cost of failures of electrical and electronic systems, caused by electromagnetic effects of lightning. Of particular importance are electronic systems used in data processing and storage as well as process control and safety for plants of considerable capital cost, size and complexity (for which plant outages are very undesirable for cost and safety reasons).

Lightning can cause different types of damage in a structure, as defined in IEC 62305-2:

- D1 injuries to living beings due to touch and step voltages;
- D2 physical damage due to mechanical, thermal, chemical and explosive effects;
- D3 failures of electrical and electronic systems due to electromagnetic effects.

IEC 62305-3 deals with the protection measures to reduce the risk of physical damage and life hazard, but does not cover the protection of electrical and electronic systems.

This Part 4 of IEC 62305 therefore provides information on protection measures to reduce the risk of permanent failures of electrical and electronic systems within structures.

Permanent failure of electrical and electronic systems can be caused by the lightning electromagnetic impulse (LEMP) via:

- a) conducted and induced surges transmitted to apparatus via connecting wiring;
- b) the effects of radiated electromagnetic fields directly into apparatus itself.

Surges to the structure can be generated externally or internally:

- surges external to the structure are created by lightning flashes striking incoming lines or the nearby ground, and are transmitted to electrical and electronic systems via these lines;
- surges internal to the structure are created by lightning flashes striking the structure or the nearby ground.

The coupling can arise from different mechanisms:

- resistive coupling (e.g. the earth impedance of the earth termination system or the cable shield resistance);
- magnetic field coupling (e.g. caused by wiring loops in the electrical and electronic system or by inductance of bonding conductors);
- electric field coupling (e.g. caused by rod antenna reception).

NOTE The effects of electric field coupling are generally very small when compared to the magnetic field coupling and can be disregarded.

Radiated electromagnetic fields can be generated via

- the direct lightning current flowing in the lightning channel,
- the partial lightning current flowing in conductors (e.g. in the down conductors of an external LPS according to IEC 62305-3 or in an external spatial shield according to this standard).

Withdrawing

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 62305-4:2006
<https://standards.iteh.ai/catalog/standards/iec/568457f-7b42-4aae-8f11-e9f2a44948fe/iec-62305-4-2006>

PROTECTION AGAINST LIGHTNING –

Part 4: Electrical and electronic systems within structures

1 Scope

This part of IEC 62305 provides information for the design, installation, inspection, maintenance and testing of a LEMP protection measures system (LPMS) for electrical and electronic systems within a structure, able to reduce the risk of permanent failures due to lightning electromagnetic impulse.

This standard does not cover protection against electromagnetic interference due to lightning, which may cause malfunctioning of electronic systems. However, the information reported in Annex A can also be used to evaluate such disturbances. Protection measures against electromagnetic interference are covered in IEC 60364-4-44 and in the IEC 61000 series [1]².

This standard provides guidelines for cooperation between the designer of the electrical and electronic system, and the designer of the protection measures, in an attempt to achieve optimum protection effectiveness.

This standard does not deal with detailed design of the electrical and electronic systems themselves.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60364-4-44:2001, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*

IEC 60364-5-53:2001, *Electrical installations of building – Part 5-53: Selection and erection of electrical equipment – Isolation, switching and control*

IEC 60664-1:2002, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 61000-4-5:1995, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*

IEC 61000-4-9:1993, *Electromagnetic compatibility (EMC) – Part 4-9: Testing and measurement techniques – Pulse magnetic field immunity test*

IEC 61000-4-10:1993, *Electromagnetic compatibility (EMC) – Part 4-10: Testing and measurement techniques – Damped oscillatory magnetic field immunity test*

² Figures in square brackets refer to the bibliography.

IEC 61000-5-2:1997, *Electromagnetic compatibility (EMC) – Part 5: Installation and mitigation guidelines – Section 2: Earthing and cabling*

IEC 61643-1:1998, *Surge protective devices connected to low-voltage power distribution systems – Part 1: Performance requirements and testing methods*

IEC 61643-12:2002, *Low-voltage surge protective devices – Part 12: Surge protective devices connected to low-voltage power distribution systems – Selection and application principles*

IEC 61643-21:2000, *Low voltage surge protective devices – Part 21: Surge protective devices connected to telecommunications and signalling networks – Performance requirements and testing methods*

IEC 61643-22:2004, *Low voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Part 22: Selection and application principles*

IEC 62305-1, *Protection against lightning. Part 1: General principles*

IEC 62305-2, *Protection against lightning. Part 2: Risk management*

IEC 62305-3, *Protection against lightning. Part 3: Physical damage to structures and life hazard*

ITU-T Recommendation K.20:2003, *Resistibility of telecommunication equipment installed in a telecommunications centre to overvoltages and overcurrents*

ITU-T Recommendation K.21:2003, *Resistibility of telecommunication equipment installed in customer premises to overvoltages and overcurrent*

3 Terms and definitions

For the purposes of this document, the following terms and definitions, as well as those given in other parts of IEC 62305, apply.

3.1

electrical system

system incorporating low-voltage power supply components

3.2

electronic system

system incorporating sensitive electronic components such as communication equipment, computer, control and instrumentation systems, radio systems, power electronic installations

3.3

internal systems

electrical and electronic systems within a structure

3.4

lightning electromagnetic impulse

LEMP

electromagnetic effects of lightning current

NOTE It includes conducted surges as well as radiated impulse electromagnetic field effects.

3.5**surge**

transient wave appearing as overvoltage and/or overcurrent caused by LEMP

NOTE Surges caused by LEMP can arise from (partial) lightning currents, from induction effects in installation loops and as a remaining threat downstream of SPD.

3.6**rated impulse withstand voltage level** U_w

impulse withstand voltage assigned by the manufacturer to the equipment or to a part of it, characterizing the specified withstand capability of its insulation against overvoltages

NOTE For the purposes of this standard, only withstand voltage between live conductors and earth is considered.

3.7**lightning protection level**

LPL

number related to a set of lightning current parameters values relevant to the probability that the associated maximum and minimum design values will not be exceeded in naturally occurring lightning

NOTE Lightning protection level is used to design protection measures according to the relevant set of lightning current parameters.

3.8**lightning protection zone**

LPZ

zone where the lightning electromagnetic environment is defined

NOTE The zone boundaries of an LPZ are not necessarily physical boundaries (e.g. walls, floor and ceiling).

3.9**LEMP protection measures system**

LPMS

complete system of protection measures for internal systems against LEMP

3.10**grid-like spatial shield**

magnetic shield characterized by openings

NOTE For a building or a room, it is preferably built by interconnected natural metal components of the structure (e.g. rods of reinforcement in concrete, metal frames and metal supports).

3.11**earth-termination system**

part of an external LPS which is intended to conduct and disperse lightning current into the earth

3.12**bonding network**

interconnecting network of all conductive parts of the structure and of internal systems (live conductors excluded) to the earth-termination system

3.13**earthing system**

complete system combining the earth-termination system and the bonding network

3.14**surge protective device**

SPD

device intended to limit transient overvoltages and divert surge currents. It contains at least one non linear component

3.15**SPD tested with I_{imp}**

SPDs which withstand the partial lightning current with a typical waveform 10/350 μ s require a corresponding impulse test current I_{imp}

NOTE For power lines, a suitable test current I_{imp} is defined in the Class I test procedure of IEC 61643-1.

3.16**SPD tested with I_n**

SPDs which withstand induced surge currents with a typical waveform 8/20 μ s require a corresponding impulse test current I_n

NOTE For power lines a suitable test current I_n is defined in the Class II test procedure of IEC 61643-1.

3.17**SPD tested with a combination wave**

SPDs that withstand induced surge currents with a typical waveform 8/20 μ s and require a corresponding impulse test current I_{sc}

NOTE For power lines a suitable combination wave test is defined in the Class III test procedure of IEC 61643-1 defining the open circuit voltage U_{oc} 1,2/50 μ s and the short-circuit current I_{sc} 8/20 μ s of an 2 Ω combination wave generator.

3.18**voltage switching type SPD**

SPD that has a high impedance when no surge is present, but can have a sudden change in impedance to a low value in response to a voltage surge

NOTE 1 Common examples of components used as voltage switching devices include spark gaps, gas discharge tubes (GDT), thyristors (silicon controlled rectifiers) and triacs. These SPD are sometimes called "crowbar type".

NOTE 2 A voltage switching device has a discontinuous voltage/current characteristic.

3.19**voltage-limiting type SPD**

SPD that has a high impedance when no surge is present, but will reduce it continuously with increased surge current and voltage

NOTE 1 Common examples of components used as non-linear devices are varistors and suppressor diodes. These SPDs are sometimes called "clamping type".

NOTE 2 A voltage-limiting device has a continuous voltage/current characteristic.

3.20**combination type SPD**

SPD that incorporates both voltage-switching and voltage-limiting type components and which may exhibit voltage-switching, voltage-limiting or both voltage-switching and voltage-limiting behaviour, depending upon the characteristics of the applied voltage

3.21**coordinated SPD protection**

set of SPD properly selected, coordinated and installed to reduce failures of electrical and electronic systems