

INTERNATIONAL ELECTROTECHNICAL COMMISSION
COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

IEC 60071-11
Edition 1.0 2022-11

IEC 60071-11
Édition 1.0 2022-11

INSULATION CO-ORDINATION

COORDINATION DE L'ISOLEMENT

**Part 11: Definitions, principles and rules for
HVDC system**

**Partie 11: Définitions, principes et règles
relatifs au réseau CCHT**

CORRIGENDUM 1

Corrections to the French version appear after the English text.

Les corrections à la version française sont données après le texte anglais.

(<https://standards.iteh.ai>)

Table C.1 – Typical DC voltages and switching/lightning impulse withstand voltage

In Table C.1, modify the first row below the column headings as shown below:

Typical DC voltage	Presumed rated switching impulse withstand voltage	Presumed rated lightning impulse withstand voltage
kV	kV (peak value)	kV (peak value)
200	550	550
		650

Table C.3 – Correlation between presumed rated lightning impulse withstand voltages and minimum phase-to-earth air clearances

Replace the word “switching” by “lightning” in the heading of the first column of Table C.3.