



SLOVENSKI STANDARD
SIST EN 60947-7-1:1995/A1:2000
01-september-2000

Nadomešča:
SIST EN 60947-7-1:1995/A11:1999

Nizkonapetostne stikalne in krmilne naprave – 7. del: Pomožna oprema – 1. oddelek: Vrstne sponke za priključevanje bakrenih vodnikov – Dopolnilo A1

Low-voltage switchgear and controlgear -- Part 7-1: Ancillary equipment - Terminal blocks for copper conductors

Niederspannungsschaltgeräte -- Teil 7-1: Hilfseinrichtungen - Reihenklemmen für Kupferleiter

Appareillage à basse tension -- Partie 7-1: Matériels accessoires - Blocs de jonction pour conducteurs en cuivre

ITeH STANDARD PREVIEW
(standards.iteh.ai)

Ta slovenski standard je istoveten z: EN 60947-7-1:1991/A1:1999

ICS:

29.130.20	Nizkonapetostne stikalne in krmilne naprave	Low voltage switchgear and controlgear
-----------	---	--

SIST EN 60947-7-1:1995/A1:2000 **en**

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60947-7-1:1995/A1:2000

<https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000>

EUROPEAN STANDARD
NORME EUROPÉENNE
EUROPÄISCHE NORM

EN 60947-7-1/A1

August 1999

ICS 29.130.20
UDC 621.316.54.027.2-034.3

Supersedes EN 60947-7-1:1991/A1:1997

English version

Low-voltage switchgear and controlgear
Part 7-1: Ancillary equipment
Section 1: Terminal blocks for copper conductors
(IEC 60947-7-1:1989/A1:1999)

Appareillage à basse tension
Partie 7: Matériels accessoires
Section 1: Blocs de jonction pour
conducteurs en cuivre
(CEI 60947-7-1:1989/A1:1999)

Niederspannungsschaltgeräte
Teil 7: Hilfseinrichtungen
Hauptabschnitt 1: Reihenklammern für
Kupferleiter
(IEC 60947-7-1:1989/A1:1999)

ITh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 60947-7-1:1995/A1:2000](https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000)

<https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000>

This European Standard was approved by CENELEC on 1999-08-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 17B/980/FDIS, future amendment 1 to IEC 60947-7-1, prepared by SC 17B, Low-voltage switchgear and controlgear, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as amendment A1 to EN 60947-7-1:1991 on 1999-08-01.

This amendment A1 supersedes EN 60947-7-1:1991/A11:1997.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2000-05-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2002-08-01

Endorsement notice

The text of amendment 1:1999 to the International Standard IEC 60947-7-1:1989 was approved by CENELEC as an amendment to the European Standard without any modification.

(standards.iteh.ai)

SIST EN 60947-7-1:1995/A1:2000

<https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000>

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC

60947-7-1

1989

AMENDEMENT 1
AMENDMENT 1
1999-06

Amendement 1

Appareillage à basse tension –

Partie 7:

Matériels accessoires –

**Section 1: Blocs de jonction
pour conducteurs en cuivre**

<https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-199321b0511/sist-en-60947-7-1-1995-a1-2000>

Amendment 1

Low-voltage switchgear and controlgear –

Part 7:

Ancillary equipment –

**Section 1: Terminal blocks
for copper conductor**

© IEC 1999 Droits de reproduction réservés — Copyright - all rights reserved

International Electrotechnical Commission
Telefax: +41 22 919 0300

3, rue de Varembe Geneva, Switzerland
e-mail: inmail@iec.ch IEC web site <http://www.iec.ch>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

B

*Pour prix, voir catalogue en vigueur
For price, see current catalogue*

FOREWORD

This amendment has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

The text of this amendment is based on the following documents:

FDIS	Report on voting
17B/980/FDIS	17B/992/RVD

Full information on the voting for the approval of this amendment can be found in the report on voting indicated in the above table.

Page 19

Add, after subclause 7.2.5, the following new subclause 7.3:

7.3 Electromagnetic compatibility (EMC)

Subclause 7.3 of IEC 60947-1 applies.

Page 35

[SIST EN 60947-7-1:1995/A1:2000
https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000](https://standards.iteh.ai/catalog/standards/sist/3d1aea0e-f763-41d7-8fb2-d9f12a3b0511/sist-en-60947-7-1-1995-a1-2000)

Add, after subclause 8.3.5, the following new subclause 8.4:

8.4 EMC tests

Terminal blocks within the scope of this standard are not sensitive to electromagnetic disturbances, and therefore no immunity tests are necessary.

Terminal blocks within the scope of this standard do not generate electromagnetic disturbances, and therefore no emission tests are necessary.