

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Electricity metering (AC) – Tariff and load control –
Part 21: Particular requirements for time switches

(standards.iteh.ai)

Équipement de comptage d'électricité (C.A.) – Tarification et contrôle
de charge –

Partie 21: Exigences particulières pour les horloges de tarification



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2004 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms, containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Electricity metering (AC) – Tariff and load control –
Part 21: Particular requirements for time switches
(standards.iteh.ai)

Équipement de comptage d'électricité (C.A.) – Tarification et contrôle
de charge – <https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-3789-28322-3789-2>
Partie 21: Exigences particulières pour les horloges de tarification

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 91.140.50

ISBN 978-2-8322-3789-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	6
4 Standard electrical values	7
5 Mechanical requirements and tests	7
5.1 Dials.....	7
5.2 Digital display.....	7
6 Climatic conditions, requirements and tests	7
7 Electrical requirements and tests	7
7.1 Supply voltage.....	7
7.2 Heating	8
7.3 Insulation	8
7.4 Output elements	9
7.5 Functional requirements and tests – accuracy	9
7.6 Electromagnetic compatibility (EMC)	12
7.7 Radio interference suppression.....	15
8 Test conditions and type test.....	15
Annex A (informative) Acceptance tests.....	16

[IEC 62054-21:2004](#)

<https://standards.iteh.ai/catalog/standards/sist/c09c1cf3-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004>

STANDARD PREVIEW
(standards.iteh.ai)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRICITY METERING (AC) –
TARIFF AND LOAD CONTROL –****Part 21: Particular requirements for time switches**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62054-21 has been prepared by IEC technical committee 13: Equipment for electrical energy measurement and load control.

This bilingual version (2016-12) corresponds to the monolingual English version, published in 2004-05.

This standard, in conjunction with IEC 62052-21, cancels and replaces IEC 61038:1990, *Electricity metering – Tariff and load control – Particular requirements for time switches* and all amendments.

This standard is to be used in conjunction with IEC 62052-21 and the relevant parts of the IEC 62059 series.

The text of this standard is based on the following documents:

FDIS	Report on voting
13/1308/FDIS	13/1317/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

IEC 62054 consists of the following parts, under the general title: *Electricity metering (a.c.) Tariff and load control*:

IEC 62054-11: Particular requirements for electronic ripple control receivers
(Replaces the particular requirements of IEC 61037.)

IEC 62054-21: Particular requirements for time switches
(Replaces the particular requirements of IEC 61038.)

The committee has decided that the contents of this publication will remain unchanged until 2013. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or [IEC 62054-21:2004](#)
- amended. <https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004>

ITEH STANDARD PREVIEW
(standards.iteh.ai)

INTRODUCTION

This standard distinguishes between protective class I and protective class II equipment

The test levels are regarded as minimum values to guarantee the proper functioning of the equipment under normal working conditions. For special application, other test levels might be necessary and should be agreed on between the user and the manufacturer.

For information, the relevant parts of IEC 62052, IEC 62054 and IEC 62059 are listed below.

- IEC 62052-21 Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 21: Tariff and load control equipment
(Replaces the general requirements of IEC 61037 and IEC 61038.)
- IEC 62054-11 Electricity metering (a.c.) – Tariff and load control – Part 11: Particular requirements for electronic ripple control receivers
(Replaces the particular requirements of IEC 61037.)
- IEC 62054-21 Electricity metering (a.c.) – Tariff and load control – Part 21: Particular requirements for time switches
(Replaces the particular requirements of IEC 61038.)
- IEC 62059-11 Electricity metering equipment – Dependability – Part 11: General concepts
- IEC 62059-21 Electricity metering equipment – Dependability – Part 21: Collection of meter dependability data from the field
- IEC 62059-41 Electricity metering equipment – Dependability – Part 41: Reliability prediction¹

[IEC 62054-21:2004](https://standards.iteh.ai/catalog/standards/sist/c09c1c3b-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004)

<https://standards.iteh.ai/catalog/standards/sist/c09c1c3b-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004>

¹ To be published.

ELECTRICITY METERING (AC) – TARIFF AND LOAD CONTROL –

Part 21: Particular requirements for time switches

1 Scope

This part of IEC 62054 specifies particular requirements for the type test of newly manufactured indoor time switches with operation reserve that are used to control electrical loads, multi-tariff registers and maximum demand devices of electricity metering equipment.

The time switch keeps the real time, it may keep the date, it may be capable of handling leap years, it may support daylight saving, i.e. it modifies the deviation of local time to GMT according to the relevant regulations. The time switch may have a synchronization capability. The time switch also holds a schedule of switching actions, which may be specified in terms of time, day of the week, date within a month or a year. The time switch controls the output elements depending on the time and the schedule of switching actions stored.

This standard gives no requirements for constructional details internal to the time switch.

In the case where time switch functionality is integrated into multifunction electricity metering equipment, the relevant parts of this standard apply.

This standard covers time switches with analogue mechanical dials or electronic digital displays that are

- synchronous; or
- crystal-controlled.

<https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004>

This standard does not cover the acceptance tests and the conformity tests. Nevertheless, an example of what could be an acceptance test is given in Annex A .

The dependability aspect is covered by the documents of the IEC 62059 series.

When using this standard in conjunction with IEC 62052-21, the requirements of this standard take precedence over those of IEC 62052-21 with regard to any item already covered in it.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 62052-21:200X *Electricity metering equipment (a.c.) – General requirements, tests and test conditions – Part 21: Tariff and load control equipment*²

3 Terms and definitions

For the purposes of this document, the definitions of IEC 62052-21 apply.

² To be published.

4 Standard electrical values

The values given in IEC 62052-21 apply.

5 Mechanical requirements and tests

The requirements and tests specified in IEC 62052-21 and the following apply.

5.1 Dials

For time switches with analogue mechanical dials:

- the direction of rotation of the dials shall be marked by an arrow;
- the hour dial (if any) shall be capable of being read to the nearest minute;
- when required, the hours on the day dial and the days on the week dial should be marked in a different colour;
- all markings shall be indelible and easy to read.

5.2 Digital display

For time switches with electronic digital display:

- the display shall be easy to read. If the same display is used for displaying different values, then a code or other indication shall be displayed to enable each value to be identified;
- the display time of each displayed value shall be at least 6 s.

[IEC 62054-21:2004](https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-25f7d5404b79/iec-62054-21-2004)

[https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-](https://standards.iteh.ai/catalog/standards/sist/c09c1c3-aa2b-4dd2-8516-25f7d5404b79/iec-62054-21-2004)

6 Climatic conditions, requirements and tests

The conditions, requirements and tests specified in IEC 62052-21 apply.

7 Electrical requirements and tests

7.1 Supply voltage

7.1.1 Supply voltage range

The values specified in IEC 62052-21 apply.

7.1.2 Supply frequency range

IEC 62052-21 applies.

7.1.3 Power consumption

IEC 62052-21 applies.

7.1.4 Voltage dips and short interruptions

See 7.6.8.

7.1.5 Long interruptions of supply voltage

7.1.5.1 Requirements

During an interruption of the supply voltage not exceeding the operation reserve, the time switch shall keep the time within the prescribed accuracy (see 7.5.2).

The output elements shall take up the position determined by the time switch programme within 5 s after the restoration of the nominal supply voltage.

If the length of the interruption of the supply voltage exceeds the operation reserve, the time may need to be re-adjusted. The time switch shall begin to execute the time switch programme within 6 h following the restoration of the supply. However, the user and the supplier may agree that, after a prolonged interruption of the supply voltage, the time switch does not restart, the outputs take up a pre-determined position and the time switch displays a special flag.

7.1.5.2 Test of effect of a long interruption of the supply voltage

For testing the time-keeping accuracy on operation reserve, see 7.5.2.3.

The test of the behaviour of the output elements consists of verifying that, after interrupting the supply voltage for an agreed length of time and when the supply is restored to the time switch, the output elements take up the position as determined by the time-switch programme, according to the indicated time.

This test shall be carried out for all possible positions of the output element(s).

The restoration of the supply voltage shall be made with the switching device free from bounce.

<https://standards.iteh.ai/catalog/standards/sist/c09c1c3b-aa2b-4dd2-8516-2317d3404679/iec-62054-21-2004>

7.1.6 Operation reserve

7.1.6.1 Requirements

IEC 62052-21 applies.

7.1.6.2 Tests

For the test of time-keeping accuracy, see 7.5.2.

For the test of required behaviour of the output elements, see 7.1.5.2.

7.1.7 Life of back-up power supply

IEC 62052-21 applies.

7.1.8 Back-up power supply replacement

IEC 62052-21 applies.

7.2 Heating

IEC 62052-21 applies.

7.3 Insulation

IEC 62052-21 applies.

7.4 Output elements

IEC 62052-21 applies.

7.5 Functional requirements and tests – accuracy

7.5.1 Time setting and programming

7.5.1.1 Time switches with mechanical analogue dials

On a day dial, it shall be possible to set the time with an accuracy better than $\pm 7,5$ min. It shall be possible to programme the switching operations with a resolution of 15 min or smaller and it shall be possible to programme a minimum of two successive switching operations at least within 60 min.

On a week dial, it shall be possible to set the day of the week and the time with an accuracy better than 1 h. It shall be possible to programme the switching operations with a resolution of 2 h or smaller and it shall be possible to programme a minimum of 2 successive switching operations at least within 8 h.

On a year dial, it shall be possible to set the date and time with an accuracy better than 2 days. It shall be possible to programme the switching operations with a resolution of 4 days or smaller and it shall be possible to programme a minimum of 2 successive switching operations at least within 16 days.

7.5.1.2 Time switches with digital displays

It shall be possible to set the date and time (day, month, year, hours and minutes) with an accuracy of 5 s. The setting of the time shall reset the seconds to zero. If setting of the seconds is also available, then the setting of the time shall not reset the seconds to zero, but to the intended value.

NOTE In this case, it is preferable to display also the seconds.

If a daylight saving function is available, the time switch shall display the official time according to the regulations.

It shall be possible to set the switching operations with a resolution of 1 minute, 1 hour, 1 day, 1 month and 1 year.

7.5.2 Time-keeping accuracy

7.5.2.1 Requirements for synchronous time switches

Synchronous time switches shall have a time-keeping accuracy under normal operating conditions better than ± 5 s/30 days assuming that the supply frequency keeps its average on the nominal value.

On operation reserve, at reference temperature, the time-keeping accuracy shall be better than ± 120 s/day, if operation reserve is provided by a spring and better than ± 1 s/day if operation reserve is provided by a supercapacitor, rechargeable battery or primary cell.

7.5.2.2 Requirements for crystal controlled time switches

At reference voltage and reference temperature, crystal-controlled time switches shall have a time-keeping accuracy better than $\pm 0,5$ s/day. The variation of the time-keeping accuracy with the temperature shall be less than ($\pm 0,15$ s/ $^{\circ}$ C/24 h).

On operation reserve, at reference temperature, the time-keeping accuracy shall be better than ± 1 s /day.

NOTE In applications where the time switch is used as part of a system providing time synchronization, the manufacturer and the purchaser may agree on relaxed time-keeping accuracy specifications for the time switch when it is operating in stand-alone mode. In this case, the system time is maintained by the time switch and the synchronization performed at the necessary intervals.

7.5.2.3 Test of time-keeping accuracy

7.5.2.3.1 General test conditions

Place the time switch under test in its normal operating position and, if necessary, in a climatic chamber, and supply it from an apparatus free of voltage dips and short interruptions. Unless otherwise indicated, the reference conditions shown in Annex B of IEC 62052-21 shall be maintained.

NOTE The manufacturer should provide a suitable means for testing the time-keeping accuracy. This could be, for example, an electrical or optical output, or, in the case of capacitor calibrated crystal-controlled time switches, an electromagnetic coupling picking up the signal from the crystal could be used.

7.5.2.3.2 Test of synchronous time switches

7.5.2.3.2.1 Test of synchronous time switches supplied by mains

The time switch under test is supplied together with and synchronised to a reference mains-controlled clock. After a testing period of 30 days, the time indication discrepancy between the reference clock and the time switch under test must be less than ± 5 s.

7.5.2.3.2.2 Test of synchronous time switches on operation reserve

The time switch to be tested is supplied together with and synchronized to, a reference clock. Before the test, the time switch shall be powered for a suitable length of time, so that the operation reserve is fully available.

NOTE The manufacturer should specify the time necessary for keeping the time switch powered up before the test of operation reserve may commence.

The power supply of the time switch under test is switched off for 36 h. When the power supply is restored, the time-indication discrepancy between the reference clock and the time switch under test shall not be more than that calculated from the time-keeping accuracy on operation reserve multiplied by the length of the operating reserve.

NOTE Consequently, the time indication discrepancy should be less than

- ± 180 s for a spring reserve operated synchronous time switch;
- $\pm 1,5$ s for a battery, a primary cell or a supercapacitor reserve operated synchronous time switch.

The restoration of the voltage shall be made with the switching device free from bounce.

7.5.2.3.3 Test of crystal-controlled time switches

7.5.2.3.3.1 Test of crystal-controlled time switches supplied by mains

The time switch under test is supplied together with, and synchronized to, a reference crystal-controlled clock. After a testing period of 30 days, the time-indication discrepancy between the reference clock and the time switch under test must be less than ± 15 s.

7.5.2.3.3.2 Test of crystal-controlled time switches on operation reserve

The time switch to be tested is powered together with a reference clock. Before the test, the time switch shall be powered for a suitable length of time, so that the operation reserve is fully available.