

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Mineral oil-filled electrical equipment – Application of dissolved gas analysis (DGA) to factory tests on electrical equipment

Matériels électriques imprégnés d'huile minérale – Application de l'analyse des gaz dissous (AGD) lors d'essais en usine de matériels électriques

[IEC 61181:2007](https://standards.iteh.ai/)

<https://standards.iteh.ai/catalog/standards/iec/ed40e1cb-0f4f-4b5d-8c9c-f9d52761fd4e/iec-61181-2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 61181

Edition 2.1 2012-03
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Mineral oil-filled electrical equipment – Application of dissolved gas analysis (DGA) to factory tests on electrical equipment

Matériels électriques imprégnés d'huile minérale – Application de l'analyse des gaz dissous (AGD) lors d'essais en usine de matériels électriques

IEC 61181:2007

<https://standards.iteh.ai/catalog/standards/iec/ed40e1cb-0f4f-4b5d-8c9c-f9d52761fd4e/iec-61181-2007>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.040

ISBN 978-2-8322-0051-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 Scope.....	6
2 Normative references	6
3 General caution, health, safety and environmental protection	6
4 Oil sampling	7
4.1 General.....	7
4.2 Sample containers.....	7
4.3 Sampling location.....	7
4.4 Sampling frequency.....	7
4.5 Sample labelling.....	8
4.6 Sample storage	8
4.7 Disposal of waste oil	8
5 Factors affecting gassing rate during thermal tests.....	8
6 Dissolved gas extraction and analysis	9
7 Report.....	10
Annex A (informative) Gas formation rates during thermal tests on power transformers	11
Annex B (informative) Gas formation rates during chopped-lightning impulse tests on instrument transformers [6].....	13
Bibliography.....	14
Table 1 – Required detection limits for factory tests.....	9
Table A.1 – Ranges of 90 % typical rates of gas formation in modern, mineral oil- filled power transformers during thermal tests, in $\mu\text{l/l/h}$	11
Table A.2 – Survey of cases followed by problems in core-type, mineral oil- filled power transformers, for various rates of gas formation observed during the thermal tests, (values in $\mu\text{l/l/h}$).....	12
Table B.1 – 90 % typical gas concentration increases observed between the beginning and the end of chopped lightning-impulse tests on instrument transformers	13

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**MINERAL OIL-FILLED ELECTRICAL EQUIPMENT –
APPLICATION OF DISSOLVED GAS ANALYSIS (DGA)
TO FACTORY TESTS ON ELECTRICAL EQUIPMENT**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61181 edition 2.1 contains the second edition (2007) [documents 10/675/FDIS and 10/688/RVD] and its amendment 1 (2012) [documents 10/881/FDIS and 10/886/RVD].

A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 61181 has been prepared by IEC technical committee 10: Fluids for electrotechnical applications.

This edition includes the following significant technical changes with respect to the previous edition:

- a) the specific procedures used during factory tests (sampling location, sampling frequency, gas extraction and chromatographic analysis in the laboratory) are described in more detail;
- b) information is provided in Annex A concerning the residual gas contents recommended before thermal tests on power transformers, typical gas values observed during the tests and cases where gas formation during the tests was followed by problems in the transformers;
- c) typical values observed during chopped lightning-impulse tests on instrument transformers are indicated in Annex B.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh Standards
(<http://standards.itih.ai>)
Document Preview

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

IEC technical committee 10, responsible for IEC 61181, has prepared guidelines for performing DGA measurements during factory testing on equipment filled with mineral insulating oil in order to ensure consistency in the industry and improve the confidence with which the results will be used.

DGA is used routinely as a standard quality control procedure during and after factory tests on electrical equipment, for example during temperature-rise and chopped lightning-impulse tests, to indicate that a design meets specified requirements. Due to the small quantities of gases generated during factory tests, specific requirements are necessary for the sampling and analysis of oil samples and the interpretation of results.

Acceptance criteria are beyond the scope of TC 10. Attention is drawn, however, to the fact that the guidelines issued by CIGRE in 1993-1995 [1]¹ do not apply any more to transformers manufactured today, the design of which having been improved. Examples of values actually observed today are indicated in Annexes A and B.

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61181:2007](#)

<https://standards.iteh.ai/catalog/standards/iec/ed40e1cb-0f4f-4b5d-8c9c-f9d52761fd4e/iec-61181-2007>

¹ Figures in square brackets refer to the bibliography.

MINERAL OIL-FILLED ELECTRICAL EQUIPMENT – APPLICATION OF DISSOLVED GAS ANALYSIS (DGA) TO FACTORY TESTS ON ELECTRICAL EQUIPMENT

1 Scope

This International Standard specifies oil-sampling procedures, analysis requirements and procedures, and recommends sensitivity, repeatability and accuracy criteria for the application of dissolved gas analysis (DGA) to factory testing of new power transformers, reactors and instrument transformers filled with mineral insulating oil when DGA testing has been specified.

The most effective and useful application of DGA techniques to factory testing is during the performance of long-term tests, typically temperature-rise (heat run) and overloading tests on power transformers and reactors, also impulse tests on instrument transformers. DGA may also be valuable for over-excitation tests run over an extended period of time.

Experience with DGA results, before and after short-time dielectric tests, indicates that DGA is normally less sensitive than electrical and acoustic methods for detecting partial discharges. However, DGA will indicate when these partial discharges become harmful to the insulation and may be detected by inspection [2].

2 Normative references

The following referenced document is indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

~~IEC 60567: Guide for the sampling of gases and of oil from oil-filled electrical equipment and for the analysis of free and dissolved gases~~

IEC 60475:2011, *Method of sampling insulating liquids*

IEC 60567:2011, *Oil-filled electrical equipment – Sampling of gases and analysis of free and dissolved gases – Guidance*

3 General caution, health, safety and environmental protection

This standard does not purport to address all the safety problems associated with its use. It is the responsibility of the user of the standard to establish appropriate health and safety practices and determine the applicability of regulatory limitations prior to use.

The mineral insulating oils which are the subject of this standard should be handled with due regard to personal hygiene. Direct contact with the eyes may cause irritation. In the case of eye contact, irrigation with copious quantities of clean running water should be carried out and medical advice sought. Some of the tests specified in this standard involve the use of processes that could lead to a hazardous situation. Attention is drawn to the relevant standard for guidance.

This standard is applicable to mineral insulating oils and used sample containers, the disposal or decontamination of which must be done according to local regulations. Every precaution should be taken to prevent release of mineral oil into the environment.

4 Oil sampling

4.1 General

Sampling of oil shall be carried out using apparatus and methods complying with IEC-~~60567~~ 60475:2011.

It is recommended that samples be taken by qualified personnel, trained to operate in accordance with IEC-~~60567~~ 60475:2011.

Samples shall be taken in duplicate (test sample and spare sample).

4.2 Sample containers

The most appropriate container is a gas-tight glass syringe of suitable capacity and fitted with a three-way sampling cock. For storage and transportation, stainless steel caps may also be used.

Alternative sample containers conforming to IEC-~~60567~~ 60475:2011 are acceptable.

4.3 Sampling location

Oil samples shall be representative of the bulk of the oil in the equipment. In power transformers, oil samples shall be taken from the main oil stream (e.g. at the ground level of the pipes circulating the oil through the radiators, when the pump is in operation, or using a metal pipe to bring the oil from the top oil valve to the ground). Points outside the main oil stream (e.g. from the bottom valve of the tank) shall be disregarded. For instrument transformers, follow the indications of manufacturers.

When using syringes, draining of at least 2 l of oil is recommended before sampling (when using bottles, twice the volume of the bottle or 5 l). When using bottles, a piece of oil-compatible tubing should be used from the oil valve to the bottom of the bottle, and the bottle filled with oil from the bottom up.

NOTE These provisions are not applicable to electrical equipment of small oil volume.

4.4 Sampling frequency

4.4.1 Thermal tests on power transformers

Irrespective of the type and duration of the test, oil samples for DGA shall be taken before the test begins and after the conclusion of the test.

Intermediate samples may be taken during the test depending on its duration and nature as they may be essential to improve the precision of the data and the reliability of their evaluation. Practices to that respect vary widely, and it is left to the user to decide the number of samples to be taken.

Oil sampling at the followings stages of the thermal tests has been found useful:

- after filling the transformer with degassed oil (for quality control of the drying and filling process);
- one day to one week later, depending on the transformer (when impregnation of oil in paper is completed);
- before start of thermal test;
- every 2 h during the tests, or at different test intervals depending on test duration and transformer design;
- at the end of test only;

- 24 h or more after the test is completed (to allow for equilibrium to be completed);
- some users recommend analysis of the duplicate and intermediate samples only if found necessary later.

If the cooling system of the unit under test includes oil pumps, they should be operated 2 h before the first oil sample is taken and kept running until the last oil sample is taken, except for any period the test conditions require the pumps to be turned off.

NOTE In the case of dielectric tests on power transformers, oil sampling may be performed:

- before first HV test.
- after all dielectric tests.

4.4.2 Impulse tests on instrument transformers

An oil sample shall be taken before the chopped lightning-impulse test. A second oil sample shall be taken 72 h after the test to assure the diffusion of the small quantities of gas generated during the test.

NOTE 1 During dielectric tests, the oil in an instrument transformer is virtually stationary and even convective movement is restricted. Consequently, the diffusion of small quantities of gas generated to the sampling point may take a considerable time. It is essential that the manufacturer and purchaser reach an agreement on the time the last sample should be taken.

NOTE 2 Between the beginning and the end of impulse tests, instrument transformers should not be subjected to other tests.

4.5 Sample labelling

Oil samples should be properly labelled before dispatch to the laboratory with the following minimum information:

- identification of equipment;
- date and time of sampling;
- nature of factory test;
- sampling point;
- top oil temperature.

4.6 Sample storage

To prevent oxidation, the samples shall be shielded from direct light by wrapping the container in aluminium foil or by storing in an opaque enclosure.

4.7 Disposal of waste oil

Waste oil shall be disposed of according to local regulations.

5 Factors affecting gassing rate during thermal tests

Gas measurements are used to detect the effect of abnormal temperatures in windings, leads, magnetic circuit, structural elements, or from abnormal leakage flux. The design of these transformer parts therefore has an influence on gas production rate. Other important design aspects that may affect production rate are:

- oil to cellulose mass ratio: if there is less oil to absorb the gas produced, higher gassing rates will be observed;
- paper type or quality (thermally upgraded or not, Nomex);
- oil type or brand (stray gassing tendency);
- in some transformers: paints, glues, stainless steel and other materials;

- cooling method and cooling efficiency;
- test duration.

Gassing rate is strongly dependent on temperature and air content. It should be noted that there is always some gassing, although very low, during all thermal tests.

Oxygen concentration is normally low since the oil is initially degassed. Sometimes the oil can be oxygenated to a given range of concentrations, such as 8 000 $\mu\text{l/l}$ to 12 000 $\mu\text{l/l}$, to increase gas formation. In case of a nitrogen-cushioned transformer, considerable amounts of gases may diffuse from the oil.

6 Dissolved gas extraction and analysis

Gases dissolved in oil should be extracted and analysed by gas chromatography in accordance with IEC 60567:2011, with the detection limits of the overall determination indicated in Table 1.

Table 1 – Required detection limits for factory tests

Gas	Concentrations	
	$\mu\text{l/l}$	$\mu\text{mol/l}$
Hydrogen	2	0,08
Hydrocarbons	0,1	0,004
Carbon monoxide	5	0,2
Carbon dioxide	10	0,4
Oxygen	500	21
Nitrogen	2000	84

IEC 61181:2007

Oil samples should be analysed as soon as possible after being taken and in no case later than seven days afterwards.

The recommended methods of gas extraction for factory tests, as indicated in IEC 60567:2011, are the Toepler and partial degassing methods, including their Mercury Free versions, since they allow a higher gas extraction efficiency at the low gas concentration levels observed during factory tests. Head space may be used if a sufficient sensitivity and accuracy can be reached.

When using partial degassing, the following adaptations for factory tests are recommended:

- use a gas burette of smaller volume;
- run a blank (with no oil injected) to check for vacuum leaks in the extraction system;
- use an extraction system dedicated to factory tests (to avoid contamination by routine oil samples containing high levels of fault gases);
- if this is not possible, perform a full extraction procedure on a sample of degassed oil before running the factory test samples;
- if a better precision is desired, use a larger volume of oil (e.g., a 50 ml or 100 ml syringe).