

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 4-42: Protection for safety – Protection against thermal effects**

**Installations électriques basse tension –
Partie 4-42: Protection pour assurer la sécurité – Protection contre les effets
thermiques**

IEC 60364-4-42:2010

<https://standards.iteh.ai/catalog/standards/iec/036c8f9d-2b02-4d3a-9c2f-11ebaa0534e9/iec-60364-4-42-2010>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 60364-4-42

Edition 3.1 2014-11
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 4-42: Protection for safety – Protection against thermal effects**

**Installations électriques basse tension –
Partie 4-42: Protection pour assurer la sécurité – Protection contre les effets
thermiques**

IEC 60364-4-42:2010

<https://standards.iteh.ai/catalog/standards/iec/036c8f9d-2b02-4d3a-9c2f-11ebaa0534e9/iec-60364-4-42-2010>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50; 91.140.50

ISBN 978-2-8322-1929-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**Low-voltage electrical installations –
Part 4-42: Protection for safety – Protection against thermal effects**

**Installations électriques basse tension –
Partie 4-42: Protection pour assurer la sécurité – Protection contre les effets
thermiques**

[IEC 60364-4-42:2010](#)

<https://standards.iteh.ai/catalog/standards/iec/036c8f9d-2b02-4d3a-9c2f-11ebaa0534e9/iec-60364-4-42-2010>



CONTENTS

FOREWORD.....	3
420.1 Scope.....	5
420.2 Normative references	5
420.3 Terms and definitions	5
421 Protection against fire caused by electrical equipment.....	6
421.1 General requirements	6
422 Precautions where particular risks of fire exist	8
422.1 General	8
422.2 Conditions of evacuation in an emergency.....	8
422.3 Locations with risks of fire due to the nature of processed or stored materials	9
422.4 Locations with combustible constructional materials	12
422.5 Fire propagating structures.....	13
422.6 Selection and erection of installations in locations with endangering of irreplaceable goods	13
423 Protection against burns	13
424 Protection against overheating.....	14
424.1 Forced air heating systems.....	14
424.2 Appliances producing hot water or steam.....	14
424.3 Space heating appliances.....	14
Annex A (informative) List of notes concerning certain countries.....	15
Annex B (informative) Arc fault detection devices (AFDD).....	20
Bibliography.....	21
<u>IEC 60364-4-42:2010</u>	
Table 42.1 – Temperature limits in normal service for accessible parts of equipment within arm’s reach.....	14

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

**Part 4-42: Protection for safety –
Protection against thermal effects**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60364-4-42 edition 3.1 contains the third edition (2010-05) [documents 64/1725/FDIS and 64/1729/RVD] and its amendment 1 (2014-11) [documents 64/1974/FDIS and 64/1982/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60364-4-42 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

The main changes with respect to the previous edition of this standard are listed below:

- The scope now includes protection against all thermal effects and flames in case of a fire hazard being propagated from electrical installations to other fire compartments segregated by barriers which are in the vicinity.
- Requirements associated with escape routes for evacuation in an emergency have been expanded/modified.
- Requirements associated with the nature of processed or stored materials have been expanded/modified.
- Requirements associated with combustible constructional materials have been expanded/modified.
- Requirements associated with fire propagating structures have been modified slightly.
- New requirements for the selection and erection of installations in locations which might endanger precious goods have been added.
- Protection against overheating now includes space heating appliances.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex A lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all parts in the IEC 60364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

<https://standards.iteh.ai/catalog/standards/iec/036c8f9d-2b02-4d3a-9c2f-11ebaa0534e9/iec-60364-4-42-2010>

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 4-42: Protection for safety – Protection against thermal effects

420.1 Scope

This part of IEC 60364 applies to electrical installations with regard to measures for the protection of persons, livestock and property against

- thermal effects, combustion or degradation of materials, and risk of burns caused by electrical equipment,
- flames in case of a fire hazard being propagated from electrical installations to other fire compartments segregated by barriers which are in the vicinity, and
- the impairment of the safe functioning of electrical equipment including safety services.

NOTE 1 For protection against thermal effects, national statutory requirements may be applicable.

NOTE 2 Protection against overcurrent is dealt with in IEC 60364-4-43.

420.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60332 (all parts), *Tests on electric and optical fibre cables under fire conditions*

IEC 60364-4-41:2005, *Low-voltage electrical installations – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-5-51:2005, *Electrical installations of buildings – Part 5-51: Selection and erection of electrical equipment – Common rules*

IEC 61084 (all parts), *Cable trunking and ducting systems for electrical installations*

IEC 61386 (all parts), *Conduit systems for cable management*

IEC 61534 (all parts), *Power track systems*

IEC 61537, *Cable management – Cable tray systems and cable ladder systems*

IEC 60598-2-24, *Luminaires – Part 2-24: Particular requirements – Luminaires with limited surface temperatures*

IEC 62606, *General requirements for arc fault detection devices*

420.3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

420.3.1

combustible

capable of burning

420.3.2

fire

- a process of combustion characterized by the emission of heat and effluent accompanied by smoke, and/or flame and/or glowing
- rapid combustion spreading uncontrolled in time and space

420.3.3

flammability

ability of a material or product to burn with a flame under specified test conditions

420.3.4

ignitability

measure of the ease with which a specimen can be ignited due to the influence of an external source, under specified test conditions

420.3.5

ignition

initiation of combustion

NOTE For more information see IEC 60695-4.

420.3.6

non-flame propagating component

component which is liable to ignite, as a result of an applied flame, but in which the flame does not propagate and which extinguishes itself within a limited time after the flame is removed

[IEC 60050-442:1998, 442-01-12]

IEC 60364-4-42:2010

<https://standards.iteh.ai/catalog/standards/iec/036c8f9d-2b02-4d3a-9c2f-11ebaa0534e9/iec-60364-4-42-2010>

421 Protection against fire caused by electrical equipment

421.1 General requirements

Persons, livestock and property shall be protected against damage or injury caused by heat or fire which may be generated or propagated in electrical installations by taking into account the requirements of this standard and the instructions of equipment manufacturers.

The heat generated by electrical equipment shall not cause danger or harmful effects to adjacent fixed material or to material which may foreseeably be in proximity to such equipment. Electrical equipment shall not present a fire hazard to adjacent materials.

NOTE Damage, injury or ignition may be caused by effects such as

- heat accumulation, heat radiation, hot elements,
- reduction of the safe function of electrical equipment, e.g. protective devices such as protective switchgear, thermostats, temperature limiters, seals of cable penetrations and wiring systems,
- overcurrent,
- insulation faults and/or arcs causing interference,
- harmonic currents,
- lightning strikes, see the IEC 62305 series,
- overvoltages, see Clause 443 of IEC 60364-4-44:2007,
- inappropriate selection or erection of equipment.

Any relevant manufacturer's erection instructions shall be taken into account in addition to the requirements of the IEC 60364 series.

421.2 Where fixed equipment may attain surface temperatures which could cause a fire hazard to adjacent materials, the equipment shall either

- be mounted on or within materials that will withstand such temperatures and are of low thermal conductance, or
- be screened from elements of building construction by materials which will withstand such temperatures and are of low thermal conductance, or
- be mounted so as to allow safe dissipation of heat at a sufficient distance from any material on which such temperatures could have deleterious thermal effects, any means of support being of low thermal conductance.

421.3 Where arcs or sparks may be emitted by permanently connected equipment in normal service, the equipment shall either

- be totally enclosed in arc-resistant material, or
- be screened by arc-resistant material from materials on which the emission could have harmful effects, or
- be mounted so as to allow safe extinction of the emissions at a sufficient distance from material upon which the emissions could have harmful effects.

Arc-resistant material used for this protective measure shall be non-ignitable, of low thermal conductivity, and of adequate thickness to provide mechanical stability.

NOTE For example, a sheet made of fibreglass silicone of 20 mm thickness may be considered as arc-resistant.

421.4 Fixed equipment causing a concentration of heat shall be at a sufficient distance from any fixed object or building element so that the object or element, in normal conditions, is not subjected to a dangerous temperature. For example, a temperature in excess of its ignition temperature.

NOTE Any information from the manufacturer of the equipment should be taken into account.

421.5 Where electrical equipment in a single location contains flammable liquid in significant quantity, adequate precautions shall be taken to prevent the spread of liquid, flame and the products of combustion.

NOTE 1 Examples of such precautions include:

- a retention pit to collect any leakage of liquid and ensure extinction in the event of fire;
- installation of the equipment in a chamber of adequate fire resistance and the provision of sills or other means of preventing liquid spreading to other parts of the building, such a chamber being ventilated solely to the external atmosphere.

NOTE 2 The generally accepted lower limit for a significant quantity is 25 l.

NOTE 3 For quantities less than 25 l, it is sufficient to take precautions to prevent the escape of liquid.

NOTE 4 Products of combustion of liquid are considered to be flame, smoke and gas.

NOTE 5 It is desirable to switch off the supply at the onset of a fire.

421.6 The materials of enclosures installed around electrical equipment during erection shall withstand the highest temperature likely to be produced by the electrical equipment.

Combustible materials are not suitable for the construction of these enclosures unless preventive measures against ignition are taken, such as covering with non-combustible or not readily combustible material of low thermal conductivity.

421.7 It is recommended that special measures be taken to protect against the effects of arc faults in final circuits:

- in premises with sleeping accommodation;
- in locations with risks of fire due to the nature of processed or stored materials, i.e. BE2 locations, (e.g. barns, wood-working shops, stores of combustible materials);
- in locations with combustible constructional materials, i.e. CA2 locations (e.g. wooden buildings);
- in fire propagating structures, i.e. CB2 locations;
- in locations with endangering of irreplaceable goods.

NOTE 1 A material is considered to be non-combustible if, in compliance with ISO 1182 [31] and ISO 1716 [32], it does not support combustion.

In a.c. circuits, the use of arc fault detection devices (AFDD) in compliance with IEC 62606 will satisfy the above-mentioned recommendation.

If used, an AFDD shall be placed at the origin of the circuit to be protected.

NOTE 2 An AFDD is a device intended to mitigate the effects of arcing faults by initiating disconnection of the circuit when an arc fault is detected, see Annex B.

The use of AFDDs does not obviate the need to apply one or more measures provided in other clauses in this standard.

NOTE 3 National committees may decide if the use of AFDDs is made a requirement or a recommendation in their national standard.

422 Precautions where particular risks of fire exist

422.1 General

422.1.1 Electrical equipment shall be restricted to that necessary for the use of these locations, except wiring systems according to 422.3.5.

422.1.2 Electrical equipment shall be so selected and erected that its temperature in normal use and foreseeable temperature rise during a fault cannot cause a fire.

These arrangements may be effected by the construction of equipment or its conditions of installation.

Special measures are not necessary where the temperature of surfaces is unlikely to cause ignition of nearby substances.

422.1.3 Thermal cut-out devices shall have manual resetting only.

422.2 Conditions of evacuation in an emergency

Condition	BD2: Low density occupation, difficult conditions of evacuation
	BD3: High density occupation, easy conditions of evacuation
	BD4: High density occupation, difficult conditions of evacuation
	(according to Table 51A of IEC 60364-5-51:2005).

NOTE Authorities responsible for building construction, public gatherings, fire prevention, etc. may specify which BD condition is applicable.

422.2.1 In conditions BD2, BD3 and BD4, wiring systems shall not encroach on escape routes unless the wiring in the wiring system is provided with sheaths or enclosures, provided by the cable management system itself or by other means.

Wiring systems encroaching on escape routes shall not be within arm's reach unless they are provided with protection against mechanical damage likely to occur during an evacuation.

Wiring systems in escape routes shall be as short as practicable and shall be non-flame propagating.

NOTE 1 Compliance with this requirement may be achieved by using the following products:

- cables fulfilling tests under fire conditions of IEC 60332-1-2, and appropriate fire conditions as follows: IEC 60332-3-21, IEC 60332-3-22, IEC 60332-3-23, IEC 60332-3-24 and IEC 60332-3-25;
- conduit systems classified as non-flame propagating according to IEC 61386-1;
- cable trunking systems classified as non-flame propagating according to IEC 61084-1;
- cable tray systems and cable ladder systems classified as non-flame propagating according to IEC 61537;
- for powertrack systems: the IEC 61534 series.

In conditions BD2, BD3 and BD4, wiring systems that are supplying safety circuits shall have a resistance to fire rating of either the time authorized by regulations for building elements or 1 h in the absence of such a regulation.

NOTE 2 For the requirements for maintaining the function of wiring systems of safety services under fire conditions, refer to Part 56.

Wiring within escape routes shall have a limited rate of smoke production.

NOTE 3 In the absence of any detailed requirement provided by cable standards, it is recommended that a value of 60 % light transmittance is adopted as a minimum for any cable tested against IEC 61034-2.

422.2.2 In conditions BD2, BD3 and BD4, switchgear and controlgear devices, except certain devices to facilitate evacuation, shall be accessible only to authorized persons. If they are placed in passages, they shall be enclosed in cabinets or boxes constructed of non-combustible or not readily combustible material.

NOTE This clause does not prohibit plastic enclosures that are not readily combustible.

422.2.3 In conditions BD3 and BD4 and in escape routes, electrical equipment containing flammable liquids shall not be installed.

NOTE Individual capacitors incorporated in equipment are not subject to this requirement. This exception principally concerns discharge luminaires and capacitors of motor starters.

422.3 Locations with risks of fire due to the nature of processed or stored materials

Condition BE2: Fire risk (according to Table 51A of IEC 60364-5-51:2005).

NOTE 1 Quantities of flammable materials or the surface or volume of the location may be regulated by national authorities.

NOTE 2 For explosion risks, see IEC 60079-14.

422.3.1 Luminaires shall be kept at an adequate distance from combustible materials. If no other information is given by manufacturers, spotlights and projectors shall be installed at the following minimum distances from combustible materials:

≤ 100 W	0,5 m
> 100 W to 300 W	0,8 m
> 300 W to 500 W	1,0 m

> 500 W greater distances can be necessary.

NOTE In the absence of manufacturers' instructions, the above distances imply all directions.

Lamps and other components of luminaires shall be protected against foreseeable mechanical stresses. Such protective means shall not be fixed on lampholders unless they form an integral part of the luminaire. Modifications to luminaires are not acceptable.


A luminaire with a lamp that could eject flammable materials in case of failure shall be installed with a safety protective shield for the lamp in accordance with the manufacturer's instructions.

NOTE Luminaires suitable for direct mounting on normally flammable surfaces were earlier marked with the symbol



according to IEC 60598-1:2003 (sixth edition).

With the publication of IEC 60598-1:2008¹⁾, luminaires suitable for direct mounting have no special marking and only luminaires not suitable for mounting on normally flammable surfaces are marked with symbols



(see Clause N.4 of IEC 60598-1:2008 for further explanations).

422.3.2 Measures shall be taken to prevent an electrical enclosure of equipment such as a heater or resistor from exceeding the following temperatures:

- 90 °C under normal conditions, and
- 115 °C under fault conditions.

Where materials such as dust or fibres sufficient to cause a fire hazard could accumulate on an enclosure of electrical equipment, adequate measures shall be taken to prevent that enclosure from exceeding the temperatures stated above.

NOTE Luminaires marked  in compliance with IEC 60598-2-24 are designed to provide limited surface temperature.

IEC 60364-4-42:2010

422.3.3 Switchgear for protection, control and isolation shall be placed outside locations presenting condition BE2, unless it is in an enclosure providing a degree of protection appropriate for such a location of at least IP4X or, in the presence of dust, IP5X or, in the presence of conductive dust, IP6X, except where 422.3.11 applies.

422.3.4 Except where wiring and wiring systems are embedded in non-combustible material, only non-flame-propagating wiring systems shall be used.

As a minimum, equipment shall be selected in accordance with the following requirements:

- cables shall satisfy the test under fire conditions specified in the IEC 60332 series;
- conduit systems shall satisfy the test for resistance to flame propagation specified in the IEC 61386 series;
- cable trunking systems and cable ducting systems shall satisfy the test for resistance to flame propagation specified in the IEC 61084 series;
- cable tray systems and cable ladder systems shall satisfy the test for resistance to flame propagation specified in the IEC 61537 series;
- powertrack systems shall satisfy the test for resistance to flame propagation specified in the IEC 61534 series.

NOTE 1 Where the risk of flame propagation is high, e.g. in long vertical runs of bunched cables, cables should meet the flame propagation characteristics of the appropriate part in the IEC 60332-3 series.

1) This seventh edition cancelled and replaced the sixth edition.