

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for  
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable-terminations**

**Appareillage à haute tension –  
Partie 209: Raccordement de câbles pour appareillage sous enveloppe  
métallique à isolation gazeuse de tension assignée supérieure à 52 kV –  
Câbles remplis d'un fluide ou à isolation extrudée – Extrémité de câble sèche  
ou remplie d'un fluide**



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tél.: +41 22 919 02 11  
Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

**High-voltage switchgear and controlgear –  
Part 209: Cable connections for gas-insulated metal-enclosed switchgear for  
rated voltages above 52 kV – Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable terminations**

**Appareillage à haute tension –  
Partie 209: Raccordement de câbles pour appareillage sous enveloppe  
métallique à isolation gazeuse de tension assignée supérieure à 52 kV –  
Câbles remplis d'un fluide ou à isolation extrudée – Extrémité de câble sèche  
ou remplie d'un fluide**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

## CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references .....	5
3 Terms and definitions .....	6
4 Limits of supply .....	7
4.1 General.....	7
4.2 Over-voltage protection .....	7
5 Rating .....	7
5.1 General.....	7
5.2 Rated voltage .....	7
5.3 Rated insulation level .....	8
5.4 Rated normal current and temperature rise.....	8
5.5 Rated short-time and peak withstand currents and rated duration of short circuit.....	8
5.6 Rated filling pressure of insulating gas in the cable connection enclosure .....	8
6 Design and construction requirements.....	9
6.1 Pressure withstand requirements.....	9
6.2 Mechanical forces on cable-terminations.....	9
7 Standard dimensions.....	10
7.1 Fluid-filled cable-terminations.....	10
7.2 Dry-type cable-terminations.....	10
7.3 Three-phase cable-termination enclosure.....	10
8 Tests.....	10
8.1 General.....	10
8.2 Dielectric type tests of cable-terminations .....	11
8.2.1 General .....	11
8.2.2 Dielectric type test of cable-terminations in a single phase enclosure .....	11
8.2.3 Dielectric type test of cable-termination in a three phase enclosure .....	11
8.3 Tests after cable system installation.....	11
9 Information to be given with enquiries, tenders and orders .....	12
10 Rules for transport, storage, erection, operation and maintenance .....	12
Figure 1 – Operating pressure of the gas insulation in the cable connection enclosure .....	9
Figure 2 – Fluid-filled cable connection assembly – Typical arrangement.....	13
Figure 3 – Fluid-filled cable connection – Assembly dimensions .....	14
Figure 4 – Dry-type cable connection assembly – Typical arrangement.....	15
Figure 5 – Dry-type cable connection assembly – Assembly dimensions.....	16

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

**Part 209: Cable connections for gas-insulated metal-enclosed  
switchgear for rated voltages above 52 kV –  
Fluid-filled and extruded insulation cables –  
Fluid-filled and dry-type cable-terminations**

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-209 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This first edition of IEC 62271-209 cancels and replaces the second edition of IEC/TS 60859 and constitutes a technical revision. The changes from IEC/TS 60859 are as follows:

- the minimum voltage rating was changed from "72,5 kV" to "above 52 kV";
- the current rating was increased to 3150 A;

- simplifications and modifications of the dimension tables in Figure 2 and Figure 4 such as diameters for 123 kV to 170 kV have been adopted in order to accommodate larger cable cross-sections; new dimensions accept old terminations, new terminations may not meet old GIS standards;
- the following dimensions have been deleted: I1, I3 as well as note 3 on Figure 4;
- in Figure 4, new dimensions have been adopted for the voltage range from 245 kV to 300 kV, interchangeability for 245 kV to 300 kV is not maintained due to reduction in GIS cable termination housing;
- the lengths I7 and I8 have been modified;
- changes in the text in relation to minimum functional pressure for insulation  $p_{me}$  (Table 1 has been removed);
- the limit of 170 kV for 3-phase application was deleted (Subclause 5.2);
- Figure 5 was deleted.

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/405/FDIS	17C/412/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 62271 series, under the general title *High-voltage switchgear and controlgear*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 209: Cable connections for gas-insulated metal-enclosed switchgear for rated voltages above 52 kV – Fluid-filled and extruded insulation cables – Fluid-filled and dry-type cable-terminations

#### 1 Scope

This standard covers the connection assembly of fluid-filled and extruded cables to gas-insulated metal enclosed switchgear (GIS), in single- or three-phase arrangements where the cable-terminations are fluid-filled or dry type and there is a separating insulating barrier between the cable insulation and the gas insulation of the switchgear.

The purpose of this standard is to establish electrical and mechanical interchangeability between cable-terminations and the gas-insulated metal-enclosed switchgear and to determine the limits of supply. It complements and amends, if necessary, the relevant IEC standards. For the purpose of this standard the term "switchgear" is used for "gas-insulated metal enclosed switchgear".

It does not cover directly immersed cable terminations, as described in CIGRE brochure 89.

#### 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:1983, *IEC standard voltages*<sup>1</sup>  
Amendment 1 (1994)  
Amendment 2 (1997)

IEC 60141 (all parts), *Tests on oil-filled and gas-pressure cables and their accessories*

IEC 60141-1:1993, *Tests on oil-filled and gas-pressure cables and their accessories – Part 1: Oil-filled, paper-insulated, metal-sheathed cables and accessories for alternating voltages up to and including 400 kV*

IEC 60141-2:1963, *Tests on oil-filled and gas-pressure cables and their accessories – Part 2: Internal gas-pressure cables and accessories for alternating voltages up to 275 kV*

IEC 60694:1996, *Common specifications for high-voltage switchgear and controlgear standards*

IEC 60840:2004, *Power cables with extruded insulation and their accessories for rated voltages above 30 kV ( $U_m = 36$  kV) up to 150 kV ( $U_m = 170$  kV) – Test methods and requirements*

<sup>1</sup> There exists a consolidated version (2002) including Amendment 1 and 2.



IEC 62067:2001, *Power cables with extruded insulation and their accessories for rated voltages above 150 kV ( $U_m = 170$  kV) up to 500 kV ( $U_m = 550$  kV) – Test methods and requirements*

Amendment 1 (2006)

IEC 62271-203:2003, *High-voltage switchgear and controlgear – Part 203: Gas-insulated metal-enclosed switchgear for rated voltages above 52 kV*

Report of CIGRE WG 23-10, ELECTRA 151, December 1993, *Earthing of GIS – An Application Guide*

CIGRE brochure 89: *Accessories for HV Extruded Cables, CIGRE WG 21.06, 1995, Chapter 2.1.5 Directly Immersed Metal Enclosed GIS Termination*

### 3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

#### 3.1

##### **cable-termination**

equipment fitted to the end of a cable to ensure electrical connection with other parts of the system and to maintain the insulation up to the point of connection. Two types are described in this standard.

##### 3.1.1

##### **fluid-filled cable-termination**

cable-termination which comprises of a separating insulating barrier between the cable insulation and the gas insulation of switchgear. The cable-termination includes an insulating fluid as part of the cable connection assembly.

##### 3.1.2

##### **dry-type cable-termination**

cable-termination which comprises an elastomeric electrical stress control component in intimate contact with a separating insulating barrier (insulator) between the cable insulation and the gas insulation of the switchgear. The cable-termination does not require any insulating fluid.

#### 3.2

##### **main-circuit end terminal**

part of the main circuit of a gas-insulated metal enclosed switchgear forming part of the connection interface

#### 3.3

##### **cable connection enclosure**

part of the gas-insulated metal-enclosed switchgear which houses the cable-termination and the main-circuit end terminal

#### 3.4

##### **cable connection assembly**

combination of a cable-termination, a cable connection enclosure and a main-circuit end terminal, which mechanically and electrically connects the cable to the gas-insulated metal enclosed switchgear

#### 3.5

##### **design pressure**

pressure used to determine the thickness of the enclosure and the components of the cable termination subjected to that pressure (according to IEC 62271-203:2003)



### 3.6

#### **fluid/insulating fluid**

the term "fluid" means a liquid or a gas for insulation purposes

### 3.7

#### **cable system**

a cable with installed accessories

## 4 Limits of supply

### 4.1 General

The limits of supply of gas-insulated metal-enclosed switchgear and the cable-termination shall be in accordance with Figure 2 for fluid-filled cable terminations and Figure 4 for dry-type cable-terminations.

### 4.2 Over-voltage protection

If a metallic earth connection between parts 6 or 11 and part 13 of Figure 2 for fluid-filled cable terminations and Figure 4 for dry-type cable-terminations is not feasible, non-linear resistors (part 15) may be connected across the insulated junction to limit the voltage under transient conditions. The number and characteristics of the non-linear resistors shall be determined and supplied by the cable termination manufacturer, taking into consideration the requirements of the user and the switchgear manufacturer. For further details refer to report of CIGRE WG 23-10: ELECTRA 151, 1993.

## 5 Rating

### 5.1 General

When dimensioning the cable connection assembly, the following rated values shall apply:

- a) the rated voltage;
- b) the number of phases in one enclosure;
- c) the rated insulation level;
- d) the rated normal current and temperature rise;
- e) the rated short-time and peak withstand currents;
- f) the rated duration of the short circuit.

### 5.2 Rated voltage

The rated voltage for the equipment ( $U_r$ ) of the cable connection is equal to the lowest of the values for the cable and the gas-insulated metal-enclosed switchgear and shall be selected from the following standard values:

72,5 kV – 100 kV – 123 kV – 145 kV – 170 kV – 245 kV – 300 kV – 362 kV – 420 kV – 550 kV

For cables, the rated voltage  $U_r$  corresponds to the highest voltage for equipment  $U_m$ .

### 5.3 Rated insulation level

The rated insulation level for the cable connection assembly shall be selected from the values given in IEC 60038 (IEC standard voltages) as well as IEC 62271-203:2003.

### 5.4 Rated normal current and temperature rise

The connection interface of the main circuit shown in Figures 2 and 3 for fluid-filled cable-terminations and Figures 4 and 5 for dry-type cable-terminations is applicable at rated normal currents up to 3 150 A. The normal current-carrying contact surfaces of the connection interface shall be silver- or copper-coated or solid copper.

For full interchangeability of the cable-termination, the connection interface shall be designed so that at a current equal to the cable rated current corresponding to a maximum temperature of 90 °C, no heat transfer from the GIS main circuit end terminal to the cable-termination will occur.

NOTE As the maximum conductor temperature for cables is limited by the maximum operating temperature for the insulation, there are certain cable dielectrics which cannot withstand the maximum temperature specified for gas-insulated metal-enclosed switchgear if there is heat transfer across the connection interface to the cable terminations.

For cases when the design value of 90 °C at rated normal current of the cable system cannot be achieved, the manufacturer of the switchgear should provide the necessary data on temperature rise of the main-circuit end terminal and of the insulating gas (SF<sub>6</sub>) as a function of current.


### 5.5 Rated short-time and peak withstand currents and rated duration of short circuit

Short-time and peak withstand currents as well as the duration of short circuit shall refer to the levels provided by the cable system, not exceeding the values given in IEC 60694.

### 5.6 Rated filling pressure of insulating gas in the cable connection enclosure

If SF<sub>6</sub> is used as the insulating gas, the minimum functional pressure for insulation  $p_{me}$  used to determine the design of the cable-termination insulation shall not exceed  $p_{me} = 0,35$  MPa (absolute) at 20 °C for maximum rated voltages up to 300 kV. For maximum rated voltages exceeding 300 kV the minimum functional pressure for insulation  $p_{me}$  used to determine the design of the cable-termination insulation shall not exceed  $p_{me} 0,4$  MPa (absolute) at 20 °C.

The rated filling pressure  $p_{re}$  of gas for insulating is assigned by the switchgear manufacturer but shall in no case be lower than  $p_{me}$ . If a gas other than SF<sub>6</sub> is used, the minimum functional pressure shall be chosen to give the same dielectric strength while being lower than the maximum recommended operating pressure as per 6.1.



$p_{re}$  rated filling pressure of gas for insulating (not lower than  $p_{me}$ )

$p_{me}$  minimal functional pressure for insulation

NOTE 0,35 MPa for voltages up to 300 kV

0,40 MPa for voltages exceeding 300 kV

**Figure 1 – Operating pressure of the gas insulation in the cable connection enclosure**

## 6 Design and construction requirements

### 6.1 Pressure withstand requirements

The design pressure (absolute) for the outside of the cable termination is 0,85 MPa at 20 °C. The cable-termination shall be capable of withstanding the vacuum conditions when the cable connection enclosure is evacuated as part of the gas filling process.

### 6.2 Mechanical forces on cable terminations

The manufacturer of the cable-termination in a three-phase connection shall take into account the total dynamic forces generated during short-circuit conditions. These forces consist of those generated within the cable-termination and those coming from the main circuit of the switchgear. The maximum additional force applied from the switchgear to the connection interface (Figure 2 or 4) transversely and then being transferred from the main circuit end terminal shall not exceed 5 kN. For single-phase connections, taking into account lack of symmetry, it is considered that this additional force is small. However, a total mechanical force of 2 kN applied to the connection interface transversely, should be assumed. It is the responsibility of the manufacturer of the switchgear to ensure that the specified forces are not exceeded.

For both single-phase and three-phase connections, additional forces and movements from the switchgear can be experienced due to temperature variations and vibrations in service. These forces can act on both switchgear and cable-termination and depend largely on the switchgear layout, termination installation, cable design and the methods of mechanical support. The design of any support structure shall take into account these forces and movements. It is particularly important that the support for the switchgear shall not be affixed to the insulator collar and/or clamping flange, parts 9 and 11 of Figure 2 or 4.