

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Lamp controlgear –
Part 1: General and safety requirements**

**Appareillages de lampes –
Partie 1: Exigences générales et exigences de sécurité**

IEC 61347-1:2007

<https://standards.iteh.ai/standards/iec/61347-1/2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2012 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente. un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Lamp controlgear –
Part 1: General and safety requirements**

**Appareillages de lampes –
Partie 1: Exigences générales et exigences de sécurité**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.140.99

ISBN 978-2-8322-0504-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION (to amendment 2)	6
INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms and definitions	10
4 General requirements	15
5 General notes on tests	15
6 Classification.....	16
7 Marking	16
8 Terminals	19
9 Provisions for protective Earthing	19
10 Protection against accidental contact with live parts	21
11 Moisture resistance and insulation.....	22
12 Electric strength	23
13 Thermal endurance test for windings of ballasts.....	24
14 Fault conditions	28
15 Construction.....	32
16 Creepage distances and clearances	33
17 Screws, current-carrying parts and connections.....	35
18 Resistance to heat, fire and tracking.....	36
19 Resistance to corrosion	36
20 No-load output voltage	37
Annex A (normative) Test to establish whether a conductive part is a live part which may cause an electric shock	38
Annex B (normative) Particular requirements for thermally protected lamp controlgear	39
Annex C (normative) Particular requirements for electronic lamp controlgear with means of protection against overheating.....	48
Annex D (normative) Requirements for carrying out the heating tests of thermally protected lamp controlgear	51
Annex E (normative) Use of constant S other than 4 500 in t_w tests	54
Annex F (normative) Draught-proof enclosure.....	57
Annex G (normative) Explanation of the derivation of the values of pulse voltages	58
Annex H (normative) Tests	64
Annex I (normative) Additional requirements for built-in magnetic ballasts with double or reinforced insulation	70
Annex J (normative) Schedule of more onerous requirements.....	73
Annex K (informative) Conformity testing during manufacture	74
Annex L (normative) Particular additional requirements for controlgears providing SELV	76

Annex M (informative) Dielectric strength test voltages for controlgear intended for the use in impulse withstand Category III	86
Annex N (normative) Requirements for insulation materials used for double or reinforced insulation	87
Annex O (normative) Additional requirements for built-in electronic controlgear with double or reinforced insulation	91
Bibliography.....	94
Figure 1 – Relation between winding temperature and endurance test duration	26
Figure 2 – Creepage distances between conductors on printed boards not conductively connected to the supply mains.....	30
Figure 3 – Test circuit for controlgear	32
Figure B.1 – Test circuit for thermally protected lamp controlgear.....	46
Figure D.1 – Example of heating enclosure for thermally protected ballasts	53
Figure E.1 – Assessment of claimed value of S.....	56
Figure G.1 – Circuit for measuring short-duration pulse energy.....	61
Figure G.2 – Suitable circuit for producing and applying long-duration pulses	63
Figure H.1 – Test arrangement for heating test.....	69
Figure N.1a – Mandrel	90
Figure N.1b – Position of mandrel.....	90
Figure N.1c – Position of metal foil on paper.....	90
Figure N.1 – Test arrangement for checking mechanical withstanding of insulating materials in thin sheet layers	90
Table 1 – Electric strength test voltage	23
Table 2 – Theoretical test temperatures for ballasts subjected to an endurance test duration of 30 days	27
Table 3 – Minimum distances for a.c. (50/60 Hz) sinusoidal voltages	34
Table 4 – Minimum distances for non-sinusoidal pulse voltages	35
Table 5 – Working voltage and U_{out} steps	18
Table B.1 – Thermal protection operation	43
Table B.2 – Thermal protection operation	44
Table G.1 – Component values for measurement of pulse energy.....	62
Table K.1 – Minimum values for electrical tests	75
Table L.1 – Symbols for marking if marking is used	78
Table L.2 – Values of temperatures in normal use	79
Table L.3 – Values of insulation resistances	80
Table L.4 – Table of dielectric strength test voltages for controlgears intended for use in impulse withstand Category II	81
Table L.5 – Creepage distances (cr), clearances (cl) and distances through insulation (dti) for the impulse withstand category II material group III a ($175 < CTI < 400$)	83
Table M.1 – Table of dielectric strength test voltages for controlgears intended for use in impulse withstand Category III	86
Table N.1 – Electric strength test voltage required during the mandrel test	89

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LAMP CONTROLGEAR –

Part 1: General and safety requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 61347-1 consists of the second edition (2007) [documents 34C/776/FDIS and 34C/779/RVD], its amendment 1 (2010) [documents 34C/916/FDIS and 34C/918/RVD] and its amendment 2 (2012) [documents 34C/1023/FDIS and 34C/1029/RVD]. It bears the edition number 2.2.

The technical content is therefore identical to the base edition and its amendments and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendments 1 and 2. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 61347-1 has been prepared by subcommittee 34C: Auxiliaries for lamps, of IEC technical committee 34: Lamps and related equipment.

The definition clause has been extended (rated no-load output voltage, controllable ballasts, control terminals, control signal). General requirements for lamp control gear which do not have their own enclosure have been added. The informative information (for ballasts in lamp standards) is now transformed into a normative requirement (in ballast standards). The test schedule has been minimised where possible, see 5.7 and Annex J. For printed circuit boards, the (non-) inflammability requirements have been specified. An Annex on conformity testing during manufacture has been added.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part 1 is to be used in conjunction with the appropriate part 2, which contains clauses to supplement or modify the corresponding clauses in Part 1, to provide the relevant requirements for each type of product.

NOTE In this standard, the following print types are used:

- Requirements proper: in roman type.
- *Test specifications: in italic type.*
- Explanatory matter: in smaller roman type.

A list of all parts of the IEC 61347 series, published under the general title *Lamp controlgear*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION (to amendment 2)

Work is currently underway to modify creepage distances and clearances requirements regarding:

- working voltages with operating frequencies up to 30 kHz and with higher operating frequencies then 30 kHz;
- impulse and resonance ignition;
- basic, supplementary and reinforced insulation;
- insulation between circuits;
- coated or potted controlgear.

This information is expected to be incorporated into the future Edition 3 of IEC 61347-1.

Withdrawing

iTech Standards
(<https://standards.itih.ai>)
Document Preview

IEC 61347-1:2007
<https://standards.itih.ai/standards/iec/61347-1-2007>

INTRODUCTION

This part of IEC 61347 provides a set of general and safety requirements and tests which are considered to be generally applicable to most types of lamp controlgear and which can be called up as required by the different parts that make up IEC 61347-2. This Part 1 is thus not to be regarded as a specification in itself for any type of lamp controlgear, and its provisions apply only to particular types of lamp controlgear, to the extent determined by the appropriate part 2 of IEC 61347.

The parts which make up IEC 61347-2, in referring to any of the clauses of this part, specify the extent to which such a clause is applicable and the order in which the tests are to be performed; they also include additional requirements as necessary. The order in which the clauses of this part are numbered has no particular significance, as the order in which their provisions apply is determined for each type of lamp controlgear by the appropriate part 2 of IEC 61347-2 series. All such parts are self-contained and therefore do not contain references to each other.

Where the requirements of any of the clauses of this part of IEC 61347 are referred to in the various parts that make up IEC 61347-2 by the phrase "The requirements of clause n of IEC 61347-1 apply", this phrase will be interpreted as meaning that all requirements of the clause in question of Part 1 apply, except any which are clearly inapplicable to the particular type of lamp controlgear covered by the part 2 concerned.

Lamp controlgear which complies with the text of this standard will not necessarily be judged to comply with the safety principles of the standard if, when examined and tested, it is found to have other features which impair the level of safety covered by these requirements.

Lamp controlgear employing materials or having forms of construction differing from those detailed in the requirements of this standard may be examined and tested according to the intent of the requirement and, if found to be substantially equivalent, may be judged to comply with the safety principles of the standard.

Performance requirements for lamp controlgear are the subject of IEC 60921, IEC 60923, IEC 60925, IEC 60927, IEC 60929, IEC 61047 and IEC 62384 (in preparation) as appropriate for the type of lamp controlgear.

NOTE Safety requirements ensure that electrical equipment constructed in accordance with these requirements does not endanger the safety of persons, domestic animals or property when properly installed and maintained and used in applications for which it was intended.

Requirements for electronic lamp controlgear for other types of lamps will be the subject of a separate standard, as the need arises.

NOTE Controlgear can consist of a printed circuit board and may incorporate the following:

- controlgear;
- lampholder(s);
- switch(es);
- supply terminals.

The lamp controlgear should comply with this standard.

The lampholders(s), switch(es) and supply terminals should comply with their own standards.

LAMP CONTROLGEAR –

Part 1: General and safety requirements

1 Scope

This part of IEC 61347 specifies general and safety requirements for lamp controlgear for use on d.c. supplies up to 250 V and/or a.c. supplies up to 1 000 V at 50 Hz or 60 Hz.

This standard also covers lamp controlgear for lamps which are not yet standardized.

Tests dealt with in this standard are type tests. Requirements for testing individual lamp controlgear during production are not included.

Requirements for semi-luminaires are given in IEC 60598-1 (see definition 1.2.60).

~~In addition to the requirements given in this Part 1 of IEC 61347, Annex B sets out general and safety requirements applicable to thermally protected lamp controlgear.~~

~~Annex C sets out additional general and safety requirements as they apply to electronic lamp controlgear with means of protection against overheating.~~

~~Additional requirements for built-in ballasts with double or reinforced insulation are given in Annex L.~~

Particular requirements for controlgears providing safety extra low voltage (from now on SELV) are given in Annex L.

NOTE It can be expected that lamp control gear which comply with this standard will not compromise safety between 90 % and 110 % of their rated supply voltage in independent use and when operated in luminaires complying with the safety standard IEC 60598-1 and the relevant part IEC 60598-2-xx and with lamps complying with the relevant lamp standards. Performance requirements may require tighter limits.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60065:2001, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60081, *Double-capped fluorescent lamps – Performance specifications*

IEC 60085:1987, *Electrical insulation – Thermal classification and designation*

IEC 60216 (all parts), *Electrical insulating materials – Properties of thermal endurance*

IEC 60317-0-1:1997 2008, *Specifications for particular types of windings wires – Part 0-1: General requirements – Section 1: Enamelled round copper wire*¹⁾

~~Amendment 1 (1999)~~

~~Amendment 2 (2005)~~

¹⁾ There exists a consolidated edition 2.2 (2005) including the base publication and its Amendments 1 and 2.

IEC 60384-14, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60417, *Graphical symbols for use on equipment*

IEC 60529:1989 , *Degrees of protection provided by enclosures (IP Code)*²⁾
Amendment 1 (1999)

IEC 60598-1:2003 2008, *Luminaires – Part 1: General requirements and tests*

IEC 60598-2 (all Parts 2), *Luminaires – Part 2: Particular requirements.*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60691:2002, *Thermal-links – Requirements and application guide*

IEC 60695-2-10, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-11-5, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60730-2-3, *Automatic electrical controls for household and similar use – Part 2: Particular requirements for thermal protectors for ballasts for tubular fluorescent lamps*

IEC 60884-2-4, *Plugs and socket-outlets for household and similar purposes – Part 2-4: Particular requirements for plugs and socket outlets for SELV*

IEC 60901, *Single-capped fluorescent lamps – Performance specifications*

IEC 60906-3, *IEC System of plugs and socket-outlets for household and similar purposes – Part 3: SELV plugs and socket-outlets, 16 A 6 V, 12 V, 24 V, 48 V, a.c. and d.c.*

IEC 60921:2004, *Ballasts for tubular fluorescent lamps – Performance requirements*

IEC 60923:2005, *Auxiliaries for lamps – Ballasts for discharge lamps (excluding tubular fluorescent lamps) – Performance requirements*

IEC 60929:2006, *AC-supplied electronic ballasts for tubular fluorescent lamps – Performance requirements*

IEC 60950-1, *Information technology equipment – Safety – Part 1: General requirements*

IEC 60990:1999, *Methods of measurement of touch current and protective conductor current*

IEC 61189-2: *Test methods for electrical materials, printed boards and other interconnection structures and assemblies – Part 2: Test methods for materials for interconnection structures*

IEC 61249-2 (all parts), *Materials for printed boards and other interconnecting structures*

IEC 61347-2 (all parts), *Lamp controlgear – Part 2: Particular requirements*

IEC 61347-2-8, *Lamp controlgear – Part 2-8: Particular requirements for ballasts for fluorescent lamps*

²⁾ There exists a consolidated edition 2.1 (2001) including the base publication and its Amendment 1.

IEC 61347-2-9:2000, *Lamp controlgear – Part 2-9: Particular requirements for ballasts for discharge lamps (excluding fluorescent lamps)*

Amendment 1 (2003)

Amendment 2 (2006)

IEC 61558-1:2005, *Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests*

IEC 61558-2-6:2009, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-6: Particular requirements and tests for safety isolating transformers and power supply units incorporating safety isolating transformers*

IEC 61558-2-16:2009, *Safety of transformers, reactors, power supply units and similar products for supply voltages up to 1 100 V – Part 2-16: Particular requirements and tests for switch mode power supply units and transformers for switch mode power supply units*

ISO 4046-4:2002, *Paper, board, pulp and related terms – Vocabulary – Part 4: Paper and board grades and converted products*

3 Terms and definitions

For the purposes of document, the following terms and definitions apply.

3.1

lamp controlgear

one or more components between the supply and one or more lamps which may serve to transform the supply voltage, limit the current of the lamp(s) to the required value, provide starting voltage and preheating current, prevent cold starting, correct power factor or reduce radio interference.

3.1.1

built-in lamp controlgear

lamp controlgear generally designed to be built into a luminaire, a box, an enclosure or the like and not intended to be mounted outside a luminaire, etc. without special precautions.

NOTE The controlgear compartment in the base of a road lighting column is considered to be an enclosure.

3.1.2

independent lamp controlgear

lamp controlgear consisting of one or more separate elements so designed that it can be mounted separately outside a luminaire, with protection according to the marking of the lamp controlgear and without any additional enclosure.

NOTE This may consist of a built-in lamp controlgear housed in a suitable enclosure which provides all the necessary protection according to its markings.

3.1.3

integral lamp controlgear

lamp controlgear which forms a non-replaceable part of a luminaire and which cannot be tested separately from the luminaire

3.2

ballast

unit inserted between the supply and one or more discharge lamps which by means of inductance, capacitance, or a combination of inductance and capacitance, serves mainly to limit the current of the lamp(s) to the required value.

NOTE It may also include means for transforming the supply voltage and arrangements which help provide starting voltage and pre-heating current.

3.2.1

d.c. supplied electronic ballast

d.c. to a.c inverter using semiconductor devices which may include stabilizing elements for supplying power to one or more fluorescent lamps

3.2.2

reference ballast

special inductive ballast designed for the purpose of providing comparison standards for use in testing ballasts and for the selection of reference lamps, and essentially characterized by a stable voltage-to-current ratio, which is relatively uninfluenced by variations in current, temperature and magnetic surroundings (see also Annex C of IEC 60921 and Annex A of IEC 60923)

3.2.3

controllable ballast

electronic ballast whose lamp operating characteristics can be changed by means of a signal via mains or extra control input

3.3

reference lamp

lamp selected for testing ballasts which, when associated with a reference ballast, has electrical characteristics which are close to the rated values as stated in the relevant lamp standard

3.4

calibration current of a reference ballast

value of the current on which are based the calibration and control of the reference ballast

NOTE Such a current should preferably be approximately equal to the rated running current of the lamps for which the reference ballast is suitable.

3.5

supply voltage

voltage applied to the complete circuit of lamp(s) and lamp controlgear

3.6

working voltage

highest r.m.s. voltage which may occur across any insulation at rated supply voltage, transients being neglected, in open-circuit conditions or during normal operation

3.7

design voltage

voltage declared by the manufacturer to which all the lamp controlgear characteristics are related. This value is not less than 85 % of the maximum value of the rated voltage range

3.8

voltage range

range of supply voltage over which the ballast is intended to be operated

3.9

rated no-load output voltage

the output voltage when the ballast is connected to rated supply voltage at rated frequency, with no load on the output, transient and starting phase being neglected

3.10

supply current

current supplied to the complete circuit of lamp(s) and lamp controlgear

3.11

live part

conductive part which may cause an electric shock in normal use. The neutral conductor is, however, regarded as a live part

NOTE The test to determine whether or not a conductive part is a live part which may cause an electric shock is given in Annex A.

3.12

type test

test or series of tests made on a type-test sample for the purpose of checking compliance of the design of a given product with the requirements of the relevant standard

3.13

type-test sample

sample consisting of one or more similar units submitted by the manufacturer or responsible vendor for the purpose of a type test

3.14

circuit power factor

λ

power factor of the combination of lamp controlgear and the lamp or lamps for which the lamp controlgear is designed

3.15

high power factor ballast

ballast having a circuit power factor of at least 0,85 (leading or lagging)

NOTE 1 The value 0,85 takes into account the distortion of the current waveform.

NOTE 2 For North America, a high power factor is defined as a power factor of at least 0,9.

3.16

rated maximum temperature

t_c

highest permissible temperature which may occur on the outer surface (at the indicated place, if marked) under normal operating conditions and at the rated voltage or the maximum of the rated voltage range

3.17

rated maximum operating temperature of a lamp controlgear winding

t_w

winding temperature assigned by the manufacturer as the highest temperature at which 50 Hz/60 Hz lamp controlgear may be expected to have a service life of at least 10 years' continuous operation

3.18

rectifying effect

effect which may occur at the end of lamp life when one cathode is either broken or has insufficient electron emission, resulting in the arc current being constantly unequal in consecutive half-cycles

3.19

test duration of endurance test

D

optional duration of the endurance test on which the temperature conditions are based

3.20

degradation of insulation of a ballast winding

S

constant which determines the degradation of ballast insulation