

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 4-44: Protection for safety – Protection against voltage disturbances and
electromagnetic disturbances**

**Installations électriques à basse tension –
Partie 4-44: Protection pour assurer la sécurité – Protection contre les
perturbations de tension et les perturbations électromagnétiques**

<https://standards.iteh.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2018 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - webstore.iec.ch/advsearchform

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 21 000 terms and definitions in English and French, with equivalent terms in 16 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

67 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: sales@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - webstore.iec.ch/advsearchform

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 21 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 16 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

67 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: sales@iec.ch.



IEC 60364-4-44

Edition 2.2 2018-01
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Low-voltage electrical installations –
Part 4-44: Protection for safety – Protection against voltage disturbances and
electromagnetic disturbances**

**Installations électriques à basse tension –
Partie 4-44: Protection pour assurer la sécurité – Protection contre les
perturbations de tension et les perturbations électromagnétiques**

<https://standards.iteh.ai/catalog/standards/iec/191dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 33.100.10; 33.100.20; 91.140.50

ISBN 978-2-8322-5286-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



**Low-voltage electrical installations –
Part 4-44: Protection for safety – Protection against voltage disturbances and
electromagnetic disturbances**

**Installations électriques à basse tension –
Partie 4-44: Protection pour assurer la sécurité – Protection contre les
perturbations de tension et les perturbations électromagnétiques**

<https://standards.iteh.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007>

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
440.1 Scope.....	8
440.2 Normative references.....	8
441 (Vacant)	10
442 Protection of low-voltage installations against temporary overvoltages due to earth faults in the high-voltage system and due to faults in the low-voltage system	10
442.1 Field of application.....	10
442.1.1 General requirements	10
442.1.2 Symbols	10
442.2 Overvoltages in LV-systems during a high-voltage earth fault	11
442.2.1 Magnitude and duration of power-frequency fault voltage	13
442.2.2 Magnitude and duration of power-frequency stress voltages	14
442.2.3 Requirements for calculation of limits.....	15
442.3 Power-frequency stress voltage in case of loss of the neutral conductor in a TN and TT system.....	15
442.4 Power-frequency stress voltage in the event of an earth fault in an IT system with distributed neutral	15
442.5 Power-frequency stress voltage in the event of a short-circuit between a line conductor and the neutral conductor	16
443 Protection against transient overvoltages of atmospheric origin or due to switching	16
443.1 General	16
443.2 Void.....	17
443.3 Terms and definitions.....	17
443.4 Overvoltage control.....	18
443.5 Risk assessment method	18
443.26 Classification of rated impulse voltages (overvoltage categories)	20
443.26.1 Purpose of classification of rated impulse voltages (overvoltage categories)	20
443.26.2 Relationship between impulse withstand Rated impulse voltages of equipment and overvoltage categories	21
443.3 Arrangements for overvoltage control.....	
 443.3.1 Inherent overvoltage control	
 443.3.2 Protective overvoltage control.....	
443.4 Required impulse withstand voltage of equipment.....	
444 Measures against electromagnetic influences.....	24
444.1 General	24
444.2 (void).....	25
444.3 Definitions	25
444.4 Mitigation of electromagnetic interference (EMI)	26
444.4.1 Sources of EMI.....	26
444.4.2 Measures to reduce EMI	26
444.4.3 TN-system.....	28
444.4.4 TT system	32
444.4.5 IT system	33
444.4.6 Multiple-source supply	34
444.4.7 Transfer of supply.....	37

444.4.8	Services entering a building	39
444.4.9	Separate buildings	40
444.4.10	Inside buildings	40
444.4.11	Protective devices	42
444.4.12	Signal cables	42
444.5	Earthing and equipotential bonding.....	42
444.5.1	Interconnection of earth electrodes	42
444.5.2	Interconnection of incoming networks and earthing arrangements	43
444.5.3	Different structures for the network of equipotential conductors and earthing conductors	43
444.5.4	Equipotential bonding networks in buildings with several floors.....	45
444.5.5	Functional earthing conductor	46
444.5.6	Commercial or industrial buildings containing significant amounts of information technology equipment.....	47
444.5.7	Earthing arrangements and equipotential bonding of information technology installations for functional purposes.....	47
444.6	Segregation of circuits	48
444.6.1	General	48
444.6.2	Design guidelines requirements	48
444.6.3	Installation guidelines Conditions for zero segregation	51
444.7	Cable management systems	52
444.7.1	General	52
444.7.2	Design guidelines	52
444.7.3	Installation guidelines	53
445	Protection against undervoltage	54
445.1	General requirements	54
Annex A (informative) Explanatory notes concerning 442.1 and 442.2.....		54
Annex A (informative) Examples of calculated risk level CRL for the use of SPDs.....		58
Annex B (informative) Guidance for on overvoltage control by SPDs applied to overhead lines		60
Annex C (normative) Determination of the conventional length, d.....		64
Annex C (informative) List of notes concerning certain countries.....		64
Figure 44.A1 – Representative schematic sketch for possible connections to earth in substation and LV-installation and occurring overvoltages in case of faults		12
Figure 44.A2 – Tolerable fault voltage due to an earth-fault in the HV system		14
Figure 443.1 – Illustration of an installation showing the lengths to consider		20
Figure 44.R1 – By-pass conductor for screen reinforcement to provide a common equipotential bonding system		27
Figure 44.R2 – Example of a substitute or by-pass equipotential bonding conductor in a TT-system.....		28
Figure 44.R3A – Avoidance of neutral conductor currents in a bonded structure by using the TN-S system from the origin of the public supply up to and including the final circuit within a building		29
Figure 44.R3B – Avoidance of neutral conductor currents in a bonded structure by using a TN-S system downstream of a consumer's private supply transformer		30
Figure 44.R4 – TN-C-S system within an existing building installation		31
Figure 44.R5 – TT system within a building installation		32
Figure 44.R6 – IT system within a building installation		33

Figure 44.R7A – TN multiple-source power supply with a non-suitable multiple connection between PEN and earth	34
Figure 44.R7B – TN multiple source power supplies to an installation with connection to earth of the star points at one and the same point	35
Figure 44.R8 – TT multiple-source power supplies to an installation with connection to earth of the star points at one and the same point	36
Figure 44.R9A – Three-phase alternative power supply with a 4-pole switch	37
Figure 44.R9B – Neutral current flow in a three-phase alternative power supply with an unsuitable 3-pole switch	38
Figure 44.R9C – Single-phase alternative power supply with 2-pole switch.....	39
Figure 44.R10 – Armoured cables and metal pipes entering the buildings (examples)	40
Figure 44.R11 – Illustration of measures in an existing building	41
Figure 44.R12 – Interconnected earth electrodes	42
Figure 44.R13 – Examples of protective conductors in star network	43
Figure 44.R14 – Example of multiple meshed bonding star network	44
Figure 44.R15 – Example of a common meshed bonding star network	45
Figure 44.R16 – Example of equipotential bonding networks in structures without lightning protection systems	46
Figure 44.R17 – Example of cable separation distance	51
Figure 44.R17A – Separation between power and information technology cables for cable route lengths ≤ 35 m	51
Figure 44.R17B – Separation between power and information technology cables for cable route lengths > 35 m	51
Figure 44.R18 – Separation of cables in wiring systems	51
Figure 44.R19 – Cable arrangements in metal cable-trays	53
Figure 44.R20 – Continuity of metallic system components	53
Figure 44.R21 – Location of cables inside metallic construction elements	54
Figure 44.R22 – Connection of metallic sections.....	54
Figure 44.Q – Examples of how to apply d_1, d_2 and d_3 for the determination of d	54
Bibliography	66
Table 44.A1 – Power-frequency stress voltages and power-frequency fault voltage in low-voltage system.....	13
Table 44.A2 – Permissible power-frequency stress voltage	15
Table 443.1 – Calculation of f_{env}	19
Table 44.B 443.2 – Required rated impulse withstand voltage of equipment U_W	24
Table 444.1 – Summary of minimum separation distances where the specification and/or intended application of the information and communication technology cable is not available	50
Table B.1 – Different possibilities for IT systems.....	50

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60364-4-44 edition 2.2 contains the second edition (2007-08) [documents 64/1600/FDIS and 64/1609/RVD] and its corrigenda 1 (2010-05) and 2 (2011-10), its amendment 1 (2015-09) [documents 64/2032/FDIS and 64/2073/RVD] and its corrigendum (2016-08), and its amendment 2 (2018-01) [documents 65C/684/FDIS and 65C/691/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendments 1 and 2. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60364-4-44 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

The document 64/1600/FDIS, circulated to the National Committees as Amendment 3, led to the publication of the new edition.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The reader's attention is drawn to the fact that Annex C lists all of the “in-some-country” clauses on differing practices of a less permanent nature relating to the subject of this standard.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iteh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 60364-4-44:2007](https://standards.iteh.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007)

<https://standards.iteh.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007>

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

INTRODUCTION

Part 4-44 of IEC 60364 covers the protection of electrical installations and measures against voltage disturbances and electromagnetic disturbances.

The requirements are arranged into four clauses as follows:

- Clause 442 Protection of low-voltage installations against temporary overvoltages due to earth faults in the high-voltage system and due to faults in the low-voltage system
- Clause 443 Protection against overvoltages of atmospheric origin or due to switching
- Clause 444 Measures against electromagnetic influences
- Clause 445 Protection against undervoltage

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 60364-4-44:2007](https://standards.itih.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007)

<https://standards.itih.ai/catalog/standards/iec/1f91dcf3-83f0-47a7-97b8-d77b26f641ab/iec-60364-4-44-2007>

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances

440.1 Scope

The rules of this Part of IEC 60364 are intended to provide requirements for the safety of electrical installations in the event of voltage disturbances and electromagnetic disturbances generated for different specified reasons.

The rules of this part are not intended to apply to systems for distribution of energy to the public, or power generation and transmission for such systems (see the scope of IEC 60364-1) although such disturbances may be conducted into or between electrical installations via these supply systems.

440.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:~~1983~~ 2009, *IEC standard voltages*

IEC 60050-604:1987, *International Electrotechnical Vocabulary – Chapter 604: Generation, transmission and distribution of electricity – Operation*

IEC 60364-1, *Low-voltage electrical installations – Part 1: Fundamental principles, assessment of general characteristics, definitions*

IEC 60364-4-41:2005, *Electrical installations of buildings – Part 4-41: Protection for safety – Protection against electric shock*

IEC 60364-5-52, *Low-voltage electrical installations – Part 5-52: Selection and erection of electrical equipment – Wiring systems*

IEC 60364-5-53:2001, *Electrical installations of buildings - Part 5-53: Selection and erection of electrical equipment - Isolation, switching and control*

IEC 60364-5-53:2001/AMD1:2002

IEC 60364-5-53:2001/AMD2:2015

IEC 60364-5-54:2002, *Electrical installations of buildings – Part 5-54: Selection and erection of electrical equipment – Earthing arrangements and protective bonding conductors*¹

IEC 60479-1:2005, *Effects of current on human beings and livestock – Part 1: General aspects*

IEC 60664-1:2007, *Insulation co-ordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60950-1, *Information technology equipment – Safety – Part 1: General requirements*

IEC 61000-2-5:1995, *Electromagnetic compatibility (EMC) – Part 2: Environment – Section 5: Classification of electromagnetic environments – Basic EMC publication*

¹ A third edition is currently in preparation.

IEC 61000-6-1, *Electromagnetic compatibility (EMC) – Part 6-1: Generic standards – Immunity for residential, commercial and light-industrial environments*

IEC 61000-6-2, *Electromagnetic compatibility (EMC) – Part 6-2: Generic standards – Immunity for industrial environments*

IEC 61000-6-3, *Electromagnetic compatibility (EMC) – Part 6-3: Generic standards – Emission standard for residential, commercial and light-industrial environments*

IEC 61000-6-4, *Electromagnetic compatibility (EMC) – Part 6-4: Generic standards – Emission standard for industrial environments*

IEC 61156 (all parts), *Multicore and symmetrical pair/quad cables for digital communication*

IEC 61196-7, *Coaxial communication cables – Part 7: Sectional specification for cables for BCT cabling in accordance with ISO/IEC 15018 – Indoor drop cables for systems operating at 5 MHz – 3 000 MHz*

IEC 61558-2-1, *Safety of power transformers, power supplies, reactors and similar products – Part 2-1: Particular requirements for tests for separating transformers and power supplies incorporating separating transformers for general applications*

IEC 61558-2-4, *Safety of power transformers, power supply units and similar – Part 2-4: Particular requirements for isolating transformers for general use*

IEC 61558-2-6, *Safety of power transformers, power supply units and similar – Part 2-6: Particular requirements for safety isolating transformers for general use*

IEC 61558-2-15, *Safety of power transformers, power supply units and similar – Part 2-15: Particular requirements for isolating transformers for the supply of medical locations*

IEC 61643 (all parts), *Low-voltage surge protective devices*

IEC 61643-11:2011, *Low-voltage surge protective devices – Part 11: Surge protective devices connected to low-voltage power systems – Requirements and test methods*

IEC 61643-22, *Low-voltage surge protective devices – Part 22: Surge protective devices connected to telecommunications and signalling networks – Selection and application principles*

IEC 61936-1, *Power installations exceeding 1 kV a.c. – Part 1: Common rules*

IEC 62305 (all parts), *Protection against lightning*

IEC 62305-1, *Protection against lightning – Part 1: General principles*

IEC 62305-3, *Protection against lightning – Part 3: Physical damage to structures and life hazard*

IEC 62305-4, *Protection against lightning – Part 4: Electrical and electronic systems within structures*

ISO/IEC 11801-1, *Information technology – Generic cabling for customer premises – Part 1: General requirements*

ISO/IEC 14763-2:2012, *Information technology – Implementation and operation of customer premises cabling – Part 2: Planning and installation*

ISO/IEC 14763-2:2012/AMD1:2015

ISO/IEC TR 29106, *Information technology – Generic cabling – Introduction to the MICE environmental classification*

441 (Vacant)**442 Protection of low-voltage installations against temporary overvoltages due to earth faults in the high-voltage system and due to faults in the low-voltage system****442.1 Field of application**

The rules of this clause provide requirements for the safety of low-voltage installation in the event of

- a fault between the high-voltage system and earth in the transformer substation that supplies the low-voltage installation,
- a loss of the supply neutral in the low-voltage system,
- a short-circuit between a line conductor and neutral,
- an accidental earthing of a line conductor of a low-voltage IT-system.

The requirements for the earthing arrangement at the transformer substation are given in IEC 61936-1.

442.1.1 General requirements

As Clause 442 covers faults between a high-voltage line and the earth in the HV/LV substation, it gives rules for the designer and installer of the substation. It is necessary to have the following information concerning the high-voltage system:

- quality of the system earthing;
- maximum level of earth fault current;
- resistance of the earthing arrangement.

The following subclauses consider four situations as proposed in 442.1, which generally cause the most severe temporary overvoltages such as defined in IEC 60050-604:

- fault between the high-voltage system(s) and earth (see 442.2);
- loss of the neutral in a low-voltage system (see 442.3);
- accidental earthing of a low-voltage IT system (see 442.4);
- short-circuit in the low-voltage installation (see 442.5).

442.1.2 Symbols

In Clause 442 the following symbols are used (see Figure 44.A1):

- | | |
|-------|--|
| I_E | part of the earth fault current in the high-voltage system that flows through the earthing arrangement of the transformer substation. |
| R_E | resistance of the earthing arrangement of the transformer substation. |
| R_A | resistance of the earthing arrangement of the exposed-conductive-parts of the equipment of the low-voltage installation. |
| R_B | resistance of the earthing arrangement of the low-voltage system neutral, for low-voltage systems in which the earthing arrangements of the transformer substation and of the low-voltage system neutral are electrically independent. |
| U_0 | in TN- and TT-systems: nominal a.c. r.m.s. line voltage to earth |