

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Automatic electrical controls for household and similar use –
Part 2-15: Particular requirements for automatic electrical air flow, water flow
and water level sensing controls**

**Dispositifs de commande électrique automatiques à usage domestique et
analogue –**

**Partie 2-15: Exigences particulières pour les dispositifs de commande électrique
automatiques détecteurs de débit d'air, de débit d'eau et de niveau d'eau**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2008 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Automatic electrical controls for household and similar use –
Part 2-15: Particular requirements for automatic electrical air flow, water flow
and water level sensing controls**

**Dispositifs de commande électrique automatiques à usage domestique et
analogue –
Partie 2-15: Exigences particulières pour les dispositifs de commande
électrique automatiques détecteurs de débit d'air, de débit d'eau et de niveau
d'eau**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

U

CONTENTS

FOREWORD.....	3
1 Scope and normative references.....	5
2 Definitions.....	6
3 General requirements.....	8
4 General notes on tests.....	8
5 Rating.....	9
6 Classification.....	9
7 Information.....	10
8 Protection against electric shock.....	11
9 Provision for protective earthing.....	11
10 Terminals and terminations.....	11
11 Constructional requirements.....	11
12 Moisture and dust resistance.....	13
13 Electric strength and insulation resistance.....	14
14 Heating.....	14
15 Manufacturing deviation and drift.....	14
16 Environmental stress.....	15
17 Endurance.....	15
18 Mechanical strength.....	17
19 Threaded parts and connections.....	18
20 Creepage distances, clearances and distances through solid insulation.....	18
21 Fire hazard testing.....	18
22 Resistance to corrosion.....	18
23 Electromagnetic compatibility (EMC) requirements – emission.....	18
24 Components.....	18
25 Normal operation.....	18
26 Electromagnetic compatibility (EMC) requirements – immunity.....	19
27 Abnormal operation.....	19
28 Guidance on the use of electronic disconnection.....	19
Annex H (normative) Requirements for electronic controls.....	20
Annex AA (normative) Number of cycles for independently mounted controls for boiler applications.....	25
Annex BB (normative) Requirements for response delay.....	26
Annex CC (informative) Number of cycles for independently mounted air flow and water flow sensing controls.....	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**AUTOMATIC ELECTRICAL CONTROLS
FOR HOUSEHOLD AND SIMILAR USE –****Part 2-15: Particular requirements for automatic electrical air flow, water
flow and water level sensing controls**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60730-2-15 has been prepared by IEC technical committee 72: Automatic controls for household use.

This second edition cancels and replaces the first edition published in 1994 and its Amendment 1 (1997), the first edition of IEC 60730-2-16 published in 1995 and its Amendments 1 (1997) and 2 (2001) and the first edition of IEC 60730-2-18 published in 1997. This second edition constitutes a technical revision.

This second edition is a consolidation of three standards IEC 60725-2-15, IEC 60730-2-16 and IEC 60730-2-18. The title and scope were revised to reflect the additional topics covered by the standard.

The text of this standard is based upon the following documents:

FDIS	Report on voting
72/757A/FDIS	72/761/RVD

Full information on the voting for the approval of this part can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This Part 2-15 is intended to be used in conjunction with IEC 60730-1. It was established on the basis of the third edition of that standard (1999) and its Amendments 1 (2003) and 2 (2007). Consideration may be given to future editions of, or amendments to, IEC 60730-1.

This Part 2-15 supplements or modifies the corresponding clauses in IEC 60730-1 so as to convert that publication into the IEC standard: Particular requirements for automatic electrical air flow, water flow and water level sensing controls.

Where this Part 2-15 states "addition", "modification" or "replacement", the relevant requirement, test specification or explanatory matter in Part 1 should be adapted accordingly.

Where no change is necessary, this Part 2-15 indicates that the relevant clause or subclause applies.

In the development of a fully international standard, it has been necessary to take into consideration the differing requirements resulting from practical experience in various parts of the world and to recognize the variation in national electrical systems and wiring rules.

The "in some countries" notes regarding differing national practice are contained in the following subclauses:

- 10.1.4
- 12.1.1.101

In this publication:

- 1) The following print types are used:
 - Requirements proper: in roman type.
 - *Test specifications: in italic type.*
 - Explanatory matter: in smaller roman type.
- 2) Subclauses or figures which are additional to those in Part 1 are numbered starting from 101.

A list of all parts of the IEC 60730 series, under the general title: *Automatic electrical controls for household and similar use*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

AUTOMATIC ELECTRICAL CONTROLS FOR HOUSEHOLD AND SIMILAR USE –

Part 2-15: Particular requirements for automatic electrical air flow, water flow and water level sensing controls

1 Scope and normative references

This clause of Part 1 is replaced as follows:

1.1 This part of IEC 60730 applies to automatic electrical air flow, water flow and water level sensing controls for use in, or in association with, boilers with a maximum pressure rating of 2 000 kPA (20 bar) and equipment for general household and similar use including controls for heating, air-conditioning and similar applications.

Examples are water flow and water level sensing controls of the float or electrode-sensor type used in boiler applications and air flow, water flow and water level sensing controls for swimming pool pumps, water tank pumps, cooling towers, dishwashers, washing machines, air conditioning chillers and ventilation applications.

1.1.1 This standard applies to the inherent safety, to the operating values, operating sequences where such are associated with equipment protection, and to the testing of automatic electrical air flow, water flow and water level sensing controls used in, or in association with, household and similar equipment.

This standard is also applicable to controls for appliances within the scope of IEC 60335-1 and IEC 60364-7-702.

Automatic electrical air flow, water flow and water level sensing controls for equipment not intended for normal household use, but which nevertheless may be used by the public, such as equipment intended to be used by laymen in shops, in light industry and on farms, are within the scope of this standard.

This standard is also applicable to individual controls utilized as part of a control system or controls which are mechanically integral with multifunctional controls having non-electrical outputs.

This standard is not applicable to pressure-operated air flow, water flow and water level sensing controls, requirements for which are contained in IEC 60730-2-6¹⁾.

This standard does not apply to air flow, water flow and water level sensing controls designed exclusively for industrial applications.

Throughout this standard, the word "equipment" means "appliance and equipment".

1.1.2 This standard applies to automatic electrical controls, mechanically or electrically operated, responsive to or controlling air flow, water flow and water level.

¹⁾ IEC 60730-2-6, *Automatic electrical controls for household and similar use – Part 2-6: Particular requirements for automatic electrical pressure sensing controls including mechanical requirements*

1.1.3 This standard contains requirements for electrical features of air flow, water flow and water level sensing controls and requirements for mechanical features that may affect their intended operation and electrical safety.

1.1.4 This standard applies to manual controls when such are electrically and/or mechanically integral with air flow, water flow and water level sensing controls.

Requirements for manual switches not forming part of an automatic control are contained in IEC 60669 and IEC 61058-1.

1.1.5 In general, these air flow, water flow and water level sensing controls are integrated or incorporated with the equipment or are intended to be integrated or incorporated in or on the equipment. This standard also covers controls when they are independently mounted or of in-line cord construction.

1.2 This standard applies to controls with a rated voltage not exceeding 690 V and a rated current not exceeding 63 A.

1.3 This standard takes into account the response value of an automatic action of a control where such a response value is dependent upon the method of mounting the control. Where a response value is of significant purpose for the protection of the user, or surroundings, the value defined in the appropriate household equipment standard or as determined by the manufacturer shall apply.

1.4 This standard applies also to controls incorporating electronic devices, requirements for which are contained in Annex H.

This standard applies also to controls using NTC and PTC thermistors, requirements for which are contained in Annex J.

1.5 Normative references

This subclause of Part 1 is applicable except as follows:

Addition:

IEC 60364-7-702, *Electrical installation of buildings – Part 7: Requirements for special installations or locations – Section 702: Swimming pools and other basins*

IEC 60669 (all parts), *Switches for household and similar fixed-electrical installations*

2 Definitions

This clause of Part 1 is applicable except as follows:

2.2 Definitions of types of control according to purpose

2.2.19

Addition:

See 2.2.103, 2.2.104, 2.2.106 and 2.2.107.

2.2.20

Addition:

See 2.2.101, 2.2.105, 2.2.108 and 2.2.109.

Additional definitions:

2.2.101

boiler water level cut-out

water level sensing control of the float or electrode-sensor type for boiler applications intended to respond to a low water level during abnormal operating conditions and which has no provision for setting by the user

A water level cut-out may be of the automatic or of the manual reset type. A boiler water level cutout is a type of water level protective control (see 2.2.105).

2.2.102

boiler water level limiter

water level sensing control of the float or electrode-sensor type for boiler applications which is intended to keep a water level below or above one particular value during normal operating conditions and which may have provision for setting by the user

A boiler water level limiter is normally of the automatic reset type.

2.2.103

boiler water feed control

water level sensing control of the float or electrode-sensor type for boiler applications which is intended to keep the water level in a boiler above one particular value during normal operating conditions and which may have provision for setting by the user

A boiler water feed control is of the automatic reset type. A boiler water feed control is used on a boiler to cycle a feeder pump or feeder water valve. For the purposes of this standard, a Type 2 boiler water feed control is considered to be a boiler water level limiter.

2.2.104

water level operating control

control which is intended to keep the water level below or above one particular value during normal operating conditions and which may have provision for setting by the user

A water level operating control is of the automatic reset type.

2.2.105

water level protective control

control which is intended to prevent a hazardous situation during abnormal operation of the equipment either by

- a) keeping the water level below or above one or more particular values, or by
- b) energizing or de-energizing the associated equipment at one or more particular values of water level

2.2.106

water flow operating control

flow sensing control intended to sense or maintain the water flow between two particular values during normal operating conditions and which may have provision for setting by the user

A water flow operating control is of the automatic reset type.

2.2.107

air flow operating control

flow sensing control intended to sense or maintain the air flow between two particular values during normal operating conditions and which may have provision for setting by the user

An air flow operating control is of the automatic reset type.

2.2.108

water flow cut-out

flow sensing control intended to respond to a lack of water flow during abnormal operating conditions and which has no provision for setting by the user

A water flow cut-out is of the automatic or manual reset type.

2.2.109

air flow cut-out

flow sensing control intended to respond to a lack of air flow during abnormal operating conditions and which has no provision for setting by the user

An air flow cut-out is of the automatic or manual reset type.

2.3 Definitions relating to the function of controls

Additional definition:

2.3.101

response delay

delay provided to increase the response value of a water level operating control for the purpose of preventing unnecessary cycling of the equipment due to fluctuating liquid level

This is usually expressed in units of time.

3 General requirements

This clause of Part 1 is applicable.

4 General notes on tests

This clause of Part 1 is applicable except as follows:

4.1 Conditions of test

4.1.7

Addition:

The rates of change shall have tolerances agreed between the manufacturer and test house.

Additional subclause:

4.1.101 The values in Annex AA apply for the testing of independently mounted water level sensing controls used in boiler applications in Clause 17 unless a higher number is declared. The values in Annex CC apply for the testing of independently mounted air and water flow sensing controls in Clause 17 unless otherwise declared. Values for integrated and incorporated controls are specified in the appropriate equipment standard.

4.3 Instructions for test

4.3.5.1 Modification:

The second sentence is not applicable to combinations of boiler water level sensing controls using a common sensing mechanism.

5 Rating

This clause of Part 1 is applicable.

6 Classification

This clause of Part 1 is applicable except as follows:

6.3 According to their purpose

6.3.9

Additional subclauses:

6.3.9.101 – boiler water level cut-out;

6.3.9.102 – boiler water level limiter;

6.3.9.103 – boiler water feed control;

6.3.9.104 – water level operating control;

6.3.9.105 – water level protective control;

6.3.9.106 – air flow operating control;

6.3.9.107 – water flow operating control;

6.3.9.108 – air flow cut-out;

6.3.9.109 – water flow cut-out.

6.4 According to features of automatic action

6.4.1

Additional subclause:

6.4.1.101 Boiler water feed controls within the scope of this standard are classified as having Type 1 action.

For the purpose of this standard, a Type 2 boiler water feed control is considered to be a boiler water level limiter.

6.4.2

Additional subclause:

6.4.2.101 Boiler water level cut-outs and boiler water level limiters within the scope of this standard are classified as having Type 2 action.

6.4.3

Additional subclauses:

6.4.3.101 – manual reset boiler water level sensing controls within the scope of this standard shall have a trip-free mechanism classified as Type 2.D, 2.H or 2.J action;

6.4.3.102 – an action incorporating response delay (Type 1.AJ or 2.AJ).

6.5 According to the degree of protection and control pollution degree

6.5.2 Addition:

Controls declared in Item 107 of Table 7.2 to be wholly or partially submerged in water during usage shall have enclosures classified as IPX8 which provide protection against continuous immersion in water as specified in IEC 60529.

7 Information

This clause of Part 1 is applicable except as follows:

Table 7.2

Modification:

Information		Clause or subclause	Method
<i>Modifications:</i>			
23	Temperature limits of mounting surfaces (T_s)	6.12.2, 14.1, 17.3	D
27	Number of automatic cycles (A) for each automatic action ¹⁰¹⁾	6.11, 17.8, 17.9	X
34	Not applicable		
44	Not applicable		
<i>Additional items:</i>			
101	Maximum fluid temperature (T_L) in °C	14.5.1	D
102	Response time, if applicable, for boiler water level sensing controls	15	C
103	Maximum working pressure, if applicable	2.3.29, 18.102	C/D ⁽¹⁰⁴⁾
104	Method of determining response time for boiler water level sensing controls	15.6.101	X
105	Test method for 18.101.2 for boiler water level sensing controls	18.101.2	X
106	Any special environmental conditions in which the control is intended to be used (other than declared in Table 7.2 Item 15) ¹⁰²⁾	12.1.101	D
107	Cord-connected float control which may be wholly or partially submerged in water or any other special environmental conditions declared in Item 106	6.5.2, 11.7.1.1, 11.7.1.2.1, 11.7.1.2.2, 12.1.1.101	D

108	Response delay	2.3.101, 6.4.3.102, 11.4.101, H.11.12.8, Annex BB	D
109	Unique or common type reference of special mounting means, if any ¹⁰³⁾	11.6.3.1	C
110	Leveling indication for mounting, if any	11.11.101	C
<i>Additional notes:</i>			
¹⁰¹⁾ The minimum number of automatic cycles is 6 000 for water level sensing controls of the float type.			
¹⁰²⁾ This information may be taken from the appropriate IEC equipment standard or may be as declared by the manufacturer.			
¹⁰³⁾ The unique or common type reference(s) shall be marked on both the mounting means and the control.			
¹⁰⁴⁾ Method C is required for air flow, water flow and boiler water level sensing controls.			

Modify the table in Note 4:

Change "Air flow" to "Air flow or water flow".

Add, to Note 4, the following text:

For water level controls, limits of activating quantity are specified either in the applicable household appliance standard, by the appliance manufacturer or as declared by the water level control manufacturer (see 17.7 and 17.8).

8 Protection against electric shock

This clause of Part 1 is applicable.

9 Provision for protective earthing

This clause of Part 1 is applicable.

10 Terminals and terminations

This clause of Part 1 is applicable except as follows:

10.1 Terminals and terminations for external copper conductors

10.1.4 Addition:

In Canada and the USA, controls for operation above 50 V shall be provided with suitable wiring terminals or leads for the connection of fixed wiring conductors having an ampere rating of no less than:

- 1,25 times the ampere rating of a fixed electric space-heating equipment load;
- 1,25 times the full-load motor current rating of a single motor;
- 1,25 times the combination load of a full-load motor current and 1,25 times a fixed electric space-heating equipment load;
- 1,25 times the full load current of the largest motor plus the full load amperes of the other loads;
- 1,0 times all other loads.

Compliance is checked by inspection.

11 Constructional requirements

This clause of Part 1 is applicable except as follows:

11.4 Actions

11.4.11 Modification:

Delete the last sentence of the first paragraph.

11.4.12 Modification:

Delete the last sentence of the first paragraph.

Additional subclause:

11.4.101 Type 1.AJ or 2.AJ action

A Type 1.AJ or 2.AJ action shall be designed such that a response delay, as declared, is provided.

For Type 2.AJ action, response delay is checked by the test of Subclause 15.5.

11.7 Attachment of cords

11.7.1 Flexing

11.7.1.1 Addition:

For controls declared in Item 107 of Table 7.2, the appropriate test of 11.7.1.2.1 shall be conducted.

11.7.1.2.1 Modification:

This clause of Part 1 is applicable except for controls declared in Item 107 of Table 7.2. Controls so declared are subjected to the following test only, and not that of Part 1.

Three samples of controls declared in Item 107 of Table 7.2 shall be subjected to a flexing test while mounted in the flexing apparatus shown in Figure 9. The cord shall be subjected to a minimum backward and forward movement through an angle of 90°. The cord shall be conducting the maximum rated current at maximum rated voltage. The number of flexings (that is one movement through 90°) shall be 30 000 at a rate of 60 flexings per minute.

For this test, the cord is not loaded with additional weight.

Additional subclause:

11.7.1.2.1.101 *Immediately following the flexing test, the control shall be subjected to the following immersion test:*

The controls, including their cords, shall be immersed and maintained in water or other special environmental condition as declared in Items 106 and 107 of Table 7.2, at T_L for seven days such that the water, or other environmental condition, is at least 1 m above the highest point of the float control.

11.7.1.2.2 Addition:

For controls tested in accordance with Subclause 11.7.1.2.1.101, the following evaluation criteria are used: After the test, the control shall comply with the requirements of Clause 8, Subclause 12.3 and Clause 13 for basic insulation, and there shall be no evidence of ingress of the test medium, compliance for which is checked by inspection.

11.11 Requirements during mounting, maintenance and servicing