



IEC 60947-1

Edition 5.1 2011-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE



Low-voltage switchgear and controlgear –
Part 1: General rules

Appareillage à basse tension –
Partie 1: Règles générales

<https://standards.iteh.ai> IEC 60947-1:2007



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 60947-1

Edition 5.1 2011-03

INTERNATIONAL STANDARD

NORME INTERNATIONALE




Low-voltage switchgear and controlgear –
Part 1: General rules

Appareillage à basse tension –
Partie 1: Règles générales

<https://standards.iteh.ai> (https://standards.iteh.ai)

IEC 60947-1:2007



INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.20

ISBN 978-2-88912-340-7

CONTENTS

FOREWORD	7
1 General	9
1.1 Scope and object.....	9
1.2 Normative references	10
2 Definitions	14
2.1 General terms	18
2.2 Switching devices.....	21
2.3 Parts of switching devices	24
2.4 Operation of switching devices	29
2.5 Characteristic quantities	33
2.6 Tests	42
2.7 Ports	42
3 Classification.....	43
4 Characteristics	44
4.1 General	45
4.2 Type of equipment.....	45
4.3 Rated and limiting values for the main circuit.....	45
4.4 Utilization category.....	51
4.5 Control circuits	51
4.6 Auxiliary circuits	52
4.7 Relays and releases	53
4.8 Co-ordination with short-circuit protective devices (SCPD)	53
4.9 Switching overvoltages	53
5 Product information	53
5.1 Nature of information.....	53
5.2 Marking.....	54
5.3 Instructions for installation, operation and maintenance	55
6 Normal service, mounting and transport conditions	56
6.1 Normal service conditions	56
6.2 Conditions during transport and storage	58
6.3 Mounting	58
7 Constructional and performance requirements	58
7.1 Constructioynal requirements	58
7.2 Performance requirements	66
7.3 Electromagnetic compatibility (EMC)	74
8 Tests	75
8.1 Kinds of test	75
8.2 Compliance with constructional requirements	77
8.3 Performance	83
8.4 Tests for EMC	104

Annex A (informative) Examples of utilization categories for low-voltage switchgear and controlgear.....	145
Annex B (informative) Suitability of the equipment when conditions for operation in service differ from the normal conditions	148
Annex C (normative) Degrees of protection of enclosed equipment.....	149
Annex D (informative) Examples of terminals clamping units and relationship between clamping unit and connecting device	156
Annex E (informative) Description of a method for adjusting the load circuit.....	171
Annex F (informative) Determination of short-circuit power-factor or time-constant	173
Annex G (informative) Measurement of creepage distances and clearances	175
Annex H (informative) Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of equipment	181
Annex J (informative) Items subject to agreement between manufacturer and user	183
Annex K Vacant	184
Annex L (normative) Terminal marking and distinctive number.....	185
Annex M (normative) Flammability test	196
Annex N (normative) Requirements and tests for equipment with protective separation	203
Annex O (informative) Environmental aspects	208
Annex P (informative) Terminal lugs for low voltage switchgear and controlgear connected to copper conductors	217
Annex Q (normative) Special tests – Damp heat, salt mist, vibration and shock	218
Annex R (informative) Application of the metal foil for dielectric testing on accessible parts during operation or adjustment.....	224
Annex S (normative) Digital inputs and outputs	230
Annex T (normative) Extended functions within electronic overload relays	244
Annex U (informative) Examples of control circuit configurations	249
https://standards.iteh.ae/cnlog/standards/icc/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007	
Bibliography.....	252
Table 1 – Standard cross-sections of round copper conductors and approximate relationship between mm ² and AWG/kcmil sizes (see 7.1.8.2)	107
Table 2 – Temperature-rise limits of terminals (see 7.2.2.1 and 8.3.3.3.4)	108
Table 3 – Temperature-rise limits of accessible parts (see 7.2.2.2 and 8.3.3.3.4)	108
Table 4 – Tightening torques for the verification of the mechanical strength of screw-type terminals (see 8.3.2.1, 8.2.6 and 8.2.6.2)	109
Table 5 – Test values for flexion and pull-out tests for round copper conductors (see 8.2.4.4.1)	110
Table 6 – Test values for pull-out test for flat copper conductors (see 8.2.4.4.2)	111
Table 7 – Maximum conductor cross-sections and corresponding gauges (see 8.2.4.5.1)	111
Table 7a – Relationship between conductor cross-section and diameter	112
Table 8 – Tolerances on test quantities (see 8.3.4.3, item a))	113
Table 9 – Test copper conductors for test currents up to 400 A inclusive (see 8.3.3.3.4)....	113
Table 10 – Test copper conductors for test currents above 400 A and up to 800 A inclusive (see 8.3.3.3.4).....	114
Table 11 – Test copper bars for test currents above 400 A and up to 3 150 A inclusive (see 8.3.3.3.4)	114

Table 12 – Impulse withstand test voltages	115
Table 12A – Dielectric test voltage corresponding to the rated insulation voltage.....	115
Table 13 – Minimum clearances in air	116
Table 14 – Test voltages across the open contacts of equipment suitable for isolation.....	116
Table 15 – Minimum creepage distances	117
Table 16 – Values of power-factors and time-constants corresponding to test currents, and ratio n between peak and r.m.s. values of current (see 8.3.4.3, item a))	119
Table 17 – Actuator test force (see 8.2.5.2.1)	119
Table 18 – Vacant.....	119
Table 19 – Vacant.....	119
Table 20 – Test values for conduit pull-out test (see 8.2.7.1)	119
Table 21 – Test values for conduit bending test (see 8.2.7.2)	120
Table 22 – Test values for conduit torque test (see 8.2.7.1 and 8.2.7.3)	120
Table 23 – Tests for EMC – Immunity (see 8.4.1.2).....	121
Table 24 – Acceptance criteria when EM disturbances are present	123
Table H.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage, in case of overvoltage protection by surge-arresters according to IEC 60099-1	182
Table M.1 – HWI and AI characteristics for materials necessary to retain current carrying parts in position	202
Table M.2 – HWI and AI characteristics for materials other than those covered by Table M.1	202
Table P.1 – Examples of terminal lugs for low voltage switchgear and controlgear connected to copper conductors	217
Table Q.1 – Test sequences.....	220
Table S.1 – Rated values and operating ranges of incoming power supply.....	231
Table S.2 – Standard operating ranges for digital inputs (current sinking)	234
Table S.3 – Rated values and operating ranges for current sourcing digital a.c. outputs	235
Table S.4 – Rated values and operating ranges (d.c.) for current-sourcing digital d.c. outputs	237
Table S.5 – Overload and short-circuit tests for digital outputs.....	240
Table T.1 – Operating time of ground/earth fault electronic overload relays	245
Figure 1 – Test equipment for flexion test (see 8.2.4.3 and Table 5)	124
Figure 2 – Gauges of form A and form B (see 8.2.4.5.2 and Table 7)	124
Figure 3 – Diagram of the test circuit for the verification of making and breaking capacities of a single-pole equipment on single-phase a.c. or on d.c. (see 8.3.3.5.2).....	125
Figure 4 – Diagram of the test circuit for the verification of making and breaking capacities of a two-pole equipment on single-phase a.c. or on d.c. (see 8.3.3.5.2).....	126
Figure 5 – Diagram of the test circuit for the verification of making and breaking capacities of a three-pole equipment (see 8.3.3.5.2)	127
Figure 6 – Diagram of the test circuit for the verification of making and breaking capacities of a four-pole equipment (see 8.3.3.5.2).....	128
Figure 7 – Schematic illustration of the recovery voltage across contacts of the first phase to clear under ideal conditions (see 8.3.3.5.2, item e)).....	129
Figure 8a – Diagram of a load circuit adjustment method: load star-point earthed	130
Figure 8b – Diagram of a load circuit adjustment method: supply star-point earthed	131

Figure 9 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a single-pole equipment on single-phase a.c. or on d.c. (see 8.3.4.1.2)	132
Figure 10 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a two-pole equipment on single-phase a.c. or on d.c. (see 8.3.4.1.2)	133
Figure 11 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a three-pole equipment (see 8.3.4.1.2)	134
Figure 12 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a four-pole equipment (see 8.3.4.1.2)	135
Figure 13 – Example of short-circuit making and breaking test record in the case of a single-pole equipment on single-phase a.c. (see 8.3.4.1.8)	136
Figure 14 – Verification of short-circuit making and breaking capacities on d.c. (see 8.3.4.1.8)	137
Figure 15 – Determination of the prospective breaking current when the first calibration of the test circuit has been made at a current lower than the rated breaking capacity (see 8.3.4.1.8, item b))	138
Figure 16 – Actuator test force (see 8.2.5.2.1 and Table 17)	139
Figure 17 – Examples of ports	140
Figure 18 – Test set-up for the verification of immunity to electrostatic discharges	140
Figure 19 – Test set-up for the verification of immunity to radiated radio-frequency electromagnetic fields	141
Figure 20 – Test set-up for the verification of immunity to electrical fast transients/bursts	142
Figure 21 – Test set-up for the verification of immunity to conducted disturbances induced by r.f. fields on power lines	143
Figure 22 – Example of test set-up for the verification of immunity to conducted disturbances induced by r.f. fields on signal lines when CDN's are not suitable	143
Figure 23 – Test set-up for the verification of immunity to power frequency magnetic fields.....	144
Figure C.1 – IP Codes	153
Figure D.1 – Screw terminals	156
Figure D.2 – Pillar terminals	157
Figure D.3 – Stud terminals	158
Figure D.4 – Saddle terminals	159
Figure D.5 – Lug terminals	160
Figure D.6 – Mantle terminals	161
Figure D.7 – Screwless-type terminals	162
Figure D.1 – Screw clamping units	164
Figure D.2 – Pillar clampings units	165
Figure D.3 – Stud clamping units	166
Figure D.4 – Saddle terminals	167
Figure D.5 – Lug clamping units	168
Figure D.6 – Mantle clamping units	169
Figure D.7 – Screwless-type clamping units	170
Figure D.8 – Clamping unit in a connecting device	163
Figure E.1 – Determination of the actual value of the factor γ	172

Figure G.1 – Measurement of ribs	176
Figure G.2 – Creepage distance across the fixed and moving insulation of contact carriers	176
Figure M.1 – Test fixture for hot wire ignition test	199
Figure M.2 – Circuit for arc ignition test	200
Figure N.1 – Example of application with component connected between separated circuits	207
Figure O.1 – Conceptual relationship between provisions in product standards and the environmental impacts associated with the product during its life cycle	213
Figure P.1 – Dimensions	217
Figure R.1 – Operating mechanism outside the enclosure	226
Figure R.2 – Operating space for push-button actuation	227
Figure R.3 – Examples of finger protected location for hazardous-live-parts in push-button vicinity (approximately 25 mm)	228
Figure R.4 – Operating space for actuation by rotary means	229
Figure S.1 – I/O parameters	232
Figure S.2 – U-I operation regions of current-sinking inputs	233
Figure S.3 – Temporary overload waveform for digital a.c. outputs	235
Figure S.4 – Temporary overload waveform for digital d.c. outputs	238
Figure T.1 – Test circuit for the verification of the operating characteristic of a ground/earth fault current sensing electronic relay	248
Figure U.1 – Diagrammatic representation of an ECD	249
Figure U.2 – Single supply and control input	250
Figure U.3 – Separate supply and control inputs	250
Figure U.4 – Equipment with an internal control supply and control input only	251
Figure U.5 – Equipment with several external control supplies	251
Figure U.6 – Equipment with bus interface	251

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –**Part 1: General rules****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
<https://www.iec.ch/60947-1-2007>
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of IEC 60947-1 consists of the fifth edition (2007) [documents 17B/1550/FDIS and 17B/1563/RVD] and its amendment 1 (2010) [documents 17B/1710/FDIS and 17B/1721/RVD]. It bears the edition number 5.1.

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience. A vertical line in the margin shows where the base publication has been modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through.

International Standard IEC 60947-1 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all the parts in the IEC 60947 series, under the general title *Low-voltage switchgear and controlgear* can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

(<https://standards.iteh.ai>)
Document Preview
[IEC 60947-1:2007](https://standards.iteh.ai/doclog/standards/icc/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007)
<https://standards.iteh.ai/doclog/standards/icc/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007>

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 1: General rules

1 General

The purpose of this standard is to harmonize as far as practicable all rules and requirements of a general nature applicable to low-voltage switchgear and controlgear in order to obtain uniformity of requirements and tests throughout the corresponding range of equipment and to avoid the need for testing to different standards.

All those parts of the various equipment standards which can be considered as general have therefore been gathered in this standard together with specific subjects of wide interest and application, e.g. temperature-rise, dielectric properties, etc.

For each type of low-voltage switchgear and controlgear, only two main documents are necessary to determine all requirements and tests:

- 1) this basic standard, referred to as "Part 1" in the specific standards covering the various types of low-voltage switchgear and controlgear;
- 2) the relevant equipment standard hereinafter referred to as the "relevant product standard" or "product standard".

For a general rule to apply to a specific product standard, it shall be explicitly referred to by the latter, by quoting the relevant clause or subclause number of this standard followed by "IEC 60947-1" e.g. "7.2.3 of IEC 60947-1".

A specific product standard may not require, and hence may omit, a general rule (as being not applicable), or it may add to it (if deemed inadequate in the particular case), but it may not deviate from it, unless there is a substantial technical justification.

<https://standards.iec.ch/standard/60947-1-2007>

NOTE The product standards due to be part of the series of IEC standards covering low-voltage switchgear and controlgear are:

- | | |
|--------------|---|
| IEC 60947-2: | Part 2: Circuit-breakers |
| IEC 60947-3: | Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units |
| IEC 60947-4: | Part 4: Contactors and motor-starters |
| IEC 60947-5: | Part 5: Control-circuit devices and switching elements |
| IEC 60947-6: | Part 6: Multiple function equipment |
| IEC 60947-7: | Part 7: Ancillary equipment |
| IEC 60947-8: | Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines. |

1.1 Scope and object

This standard applies, when required by the relevant product standard, to switchgear and controlgear hereinafter referred to as "equipment" and intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.

It does not apply to low-voltage switchgear and controlgear assemblies which are dealt with in IEC 60439.

NOTE In certain clauses or subclauses of this standard, the equipment covered by this standard is also referred to as "device", to be consistent with the text of such clauses or subclauses.

The object of this standard is to state those general rules and requirements which are common to low-voltage equipment as defined in 1.1, including for example:

- definitions;
- characteristics;
- information supplied with the equipment;
- normal service, mounting and transport conditions;
- constructional and performance requirements;
- verification of characteristics and performance.

Digital inputs and/or digital outputs contained in switchgear and controlgear, and intended to be compatible with programmable controllers (PLCs) are covered by Annex S.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(151):2001, *International Electrotechnical Vocabulary (IEV) – Chapter 151: Electrical and magnetic devices*

IEC 60050(441):1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*
Amendment 1 (2000)

IEC 60050(604):1987, *International Electrotechnical Vocabulary (IEV) – Chapter 604: Generation, transmission and distribution of electricity – Operation*
Amendment 1 (1998)

IEC 60050(826):2004, *International Electrotechnical Vocabulary (IEV) – Chapter 826: Electrical installations*

IEC 60060, *High-voltage test techniques*

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*
Amendment 1 (1992)

IEC 60068-2-1:1990, *Environmental testing – Part 2-1: Tests – Tests A: Cold*
Amendment 1 (1993)
Amendment 2 (1994)

IEC 60068-2-2:1974, *Environmental testing – Part 2-2: Tests – Tests B: Dry heat*
Amendment 1 (1993)
Amendment 2 (1994)

IEC 60068-2-6:1995, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27:1987, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-52:1996, *Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution)*

IEC 60068-2-78:2001, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60071-1:1993, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60073:2002, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for indicators and actuators*

IEC 60085:2004, *Electrical insulation – Thermal classification*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60216, *Guide for the determination of thermal endurance properties of electrical insulating materials*

IEC 60228:2004, *Conductors of insulated cables*

IEC 60269-1:1998, *Low-voltage fuses – Part 1: General requirements*
Amendment 1 (2005)

IEC 60269-2:1986, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application)*
Amendment 1 (1995)
Amendment 2 (2001)

IEC 60344:1980, *Guide to the calculation of resistance of plain and coated copper conductors of low-frequency cables and wires*
Amendment 1 (1985)

<https://www.iec.ch/standards/iec60947-1:2007>

IEC 60364-4-44:2001, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*
Amendment 1 (2003)

IEC 60417-DB:2002¹, *Graphical symbols for use on equipment*

IEC 60439-1:1999, *Low-voltage switchgear and controlgear assemblies – Part 1: Type-tested and partially type-tested assemblies*
Amendment 1 (2004)

IEC 60445:1999, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals and of terminations of certain designated conductors, including general rules of an alphanumeric system*

IEC 60447:2004, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*
Amendment 1 (1999)

¹ “DB” refers to the IEC on-line database.

IEC 60617-DB:20011, *Graphical symbols for diagrams*

IEC 60664-1:1992, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests* – Basic safety publication
Amendment 1 (2000)
Amendment 2 (2002)

IEC 60664-3:2003, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60664-5:2007, *Insulation coordination for equipment within low-voltage systems – Part 5: Comprehensive method for determining clearances and creepage distances equal to or less than 2 mm*

IEC 60695-2-2:1991, *Fire hazard testing – Part 2: Test methods – Section 2: Needle-flame test*
Amendment 1 (1994)

IEC 60695-2-10:2000, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-2-12, *Fire hazard testing – Part 2-12: Glowing/hot-wire based test methods – Glow-wire flammability test method for materials*

IEC 60695-11-10:1999, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*
Amendment 1 (2003)

IEC 60947-5-1:2003, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

<https://standards.iec.ch/IEC/60947-1-2007>

IEC 60947-8:2003, *Low-voltage switchgear and controlgear – Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines*
Amendment 1 (2006)

IEC 60981:2004, *Extra heavy-duty electrical rigid steel conduits*

IEC 60999-1:1999, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 60999-2:2003, *Connecting devices – Electrical copper conductors – Safety requirements for screw-type and screwless-type clamping units – Part 2: Particular requirements for clamping units for conductors above 35 mm² up to 300 mm² (included)*

IEC 61000-3-2:2005, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3:1994, *Electromagnetic compatibility (EMC) – Part 3: Limits – Section 3: Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current ≤ 16 A*
Amendment 1 (2001)
Amendment 2 (2005)