



IEC 60947-1

Edition 5.0 2007-06

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

Low-voltage switchgear and controlgear –  
Part 1: General rules

Appareillage à basse tension –  
Partie 1: Règles générales

<https://standards.iteh.ai/codolog/standards/iec/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 60947-1

Edition 5.0 2007-06

# INTERNATIONAL STANDARD

## NORME INTERNATIONALE

Low-voltage switchgear and controlgear –  
Part 1: General rules

Appareillage à basse tension –  
Partie 1: Règles générales

IEC 60947-1:2007

<https://standards.iteh.ai/codalog/standards/iec/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007>

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

XH

ICS 29.130.20

ISBN 2-8318-9181-7

## CONTENTS

FOREWORD .....	7
1 General .....	9
1.1 Scope and object .....	9
1.2 Normative references .....	10
2 Definitions .....	13
2.1 General terms.....	18
2.2 Switching devices .....	21
2.3 Parts of switching devices.....	24
2.4 Operation of switching devices.....	27
2.5 Characteristic quantities .....	32
2.6 Tests .....	41
2.7 Ports .....	41
3 Classification .....	42
4 Characteristics.....	43
4.1 General .....	44
4.2 Type of equipment .....	44
4.3 Rated and limiting values for the main circuit .....	44
4.4 Utilization category .....	50
4.5 Control circuits .....	50
4.6 Auxiliary circuits .....	51
4.7 Relays and releases .....	51
4.8 Co-ordination with short-circuit protective devices (SCPD) .....	51
4.9 Switching overvoltages .....	52
5 Product information.....	52
5.1 Nature of information .....	52
5.2 Marking.....	53
5.3 Instructions for installation, operation and maintenance.....	54
6 Normal service, mounting and transport conditions.....	54
6.1 Normal service conditions .....	54
6.2 Conditions during transport and storage .....	56
6.3 Mounting .....	56
7 Constructional and performance requirements .....	56
7.1 Constructioynal requirements.....	56
7.2 Performance requirements.....	64
7.3 Electromagnetic compatibility (EMC) .....	72
8 Tests .....	73
8.1 Kinds of test .....	73
8.2 Compliance with constructional requirements .....	75
8.3 Performance.....	81
8.4 Tests for EMC .....	101

Annex A (informative) Examples of utilization categories for low-voltage switchgear and controlgear.....	141
Annex B (informative) Suitability of the equipment when conditions for operation in service differ from the normal conditions .....	144
Annex C (normative) Degrees of protection of enclosed equipment.....	146
Annex D (informative) Examples of terminals .....	153
Annex E (informative) Description of a method for adjusting the load circuit.....	160
Annex F (informative) Determination of short-circuit power-factor or time-constant .....	162
Annex G (informative) Measurement of creepage distances and clearances .....	164
Annex H (informative) Correlation between the nominal voltage of the supply system and the rated impulse withstand voltage of equipment .....	170
Annex J (informative) Items subject to agreement between manufacturer and user .....	172
Annex K Vacant .....	173
Annex L (normative) Terminal marking and distinctive number.....	174
Annex M (normative) Flammability test .....	185
Annex N (normative) Requirements and tests for equipment with protective separation .....	188
Annex O (informative) Environmental aspects.....	193
Annex P (informative) Terminal lugs for low voltage switchgear and controlgear connected to copper conductors.....	201
Annex Q (normative) Special tests – Damp heat, salt mist, vibration and shock .....	202
Annex R (informative) Application of the metal foil for dielectric testing on accessible parts during operation or adjustment .....	207
Annex S (normative) Digital inputs and outputs.....	213
 Bibliography.....	227
 <a href="https://standards.iteh.ae/codes/standards/iec/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007">https://standards.iteh.ae/codes/standards/iec/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007</a>	
Table 1 – Standard cross-sections of round copper conductors and approximate relationship between mm <sup>2</sup> and AWG/kcmil sizes (see 7.1.8.2).....	105
Table 2 – Temperature-rise limits of terminals (see 7.2.2.1 and 8.3.3.3.4).....	105
Table 3 – Temperature-rise limits of accessible parts (see 7.2.2.2 and 8.3.3.3.4).....	106
Table 4 – Tightening torques for the verification of the mechanical strength of screw-type terminals (see 8.3.2.1, 8.2.6 and 8.2.6.2) .....	107
Table 5 – Test values for flexion and pull-out tests for round copper conductors (see 8.2.4.4.1) .....	108
Table 6 – Test values for pull-out test for flat copper conductors (see 8.2.4.4.2) .....	108
Table 7 – Maximum conductor cross-sections and corresponding gauges (see 8.2.4.5.1) .....	109
Table 7a – Relationship between conductor cross-section and diameter .....	110
Table 8 – Tolerances on test quantities (see 8.3.4.3, item a)) .....	111
Table 9 – Test copper conductors for test currents up to 400 A inclusive (see 8.3.3.3.4) .....	111
Table 10 – Test copper conductors for test currents above 400 A and up to 800 A inclusive (see 8.3.3.3.4) .....	112

Table 11 – Test copper bars for test currents above 400 A and up to 3 150 A inclusive (see 8.3.3.3.4) .....	112
Table 12 – Impulse withstand test voltages.....	113
Table 12A – Dielectric test voltage corresponding to the rated insulation voltage.....	113
Table 13 – Minimum clearances in air.....	114
Table 14 – Test voltages across the open contacts of equipment suitable for isolation .....	114
Table 15 – Minimum creepage distances .....	115
Table 16 – Values of power-factors and time-constants corresponding to test currents, and ratio $n$ between peak and r.m.s. values of current (see 8.3.4.3, item a)) .....	116
Table 17 – Actuator test force (see 8.2.5.2.1) .....	116
Table 18 – Vacant.....	116
Table 19 – Vacant.....	116
Table 20 – Test values for conduit pull-out test (see 8.2.7.1) .....	116
Table 21 – Test values for conduit bending test (see 8.2.7.2).....	117
Table 22 – Test values for conduit torque test (see 8.2.7.1 and 8.2.7.3).....	117
Table 23 – Tests for EMC – Immunity (see 8.4.1.2) .....	118
Table 24 – Acceptance criteria when EM disturbances are present .....	119
Table H.1 – Correspondence between the nominal voltage of the supply system and the equipment rated impulse withstand voltage, in case of overvoltage protection by surge- arresters according to IEC 60099-1 .....	171
Table M.1 – HWI and AI characteristics for materials necessary to retain current carrying parts in position .....	187
Table M.2 – HWI and AI characteristics for materials other than those covered by Table M.1 .....	187
Table P.1 – Examples of terminal lugs for low voltage switchgear and controlgear connected to copper conductors .....	201
Table Q.1 – Test sequences.....	204
Table S.1 – Rated values and operating ranges of incoming power supply .....	214
Table S.2 – Standard operating ranges for digital inputs (current sinking) .....	217
Table S.3 – Rated values and operating ranges for current sourcing digital a.c. outputs .....	218
Table S.4 – Rated values and operating ranges (d.c.) for current-sourcing digital d.c. outputs.....	220
Table S.5 – Overload and short-circuit tests for digital outputs .....	223
Figure 1 – Test equipment for flexion test (see 8.2.4.3 and Table 5) .....	120
Figure 2 – Gauges of form A and form B (see 8.2.4.5.2 and Table 7) .....	120
Figure 3 – Diagram of the test circuit for the verification of making and breaking capacities of a single-pole equipment on single-phase a.c. or on d.c. (see 8.3.3.5.2) .....	121
Figure 4 – Diagram of the test circuit for the verification of making and breaking capacities of a two-pole equipment on single-phase a.c. or on d.c. (see 8.3.3.5.2) .....	122
Figure 5 – Diagram of the test circuit for the verification of making and breaking capacities of a three-pole equipment (see 8.3.3.5.2).....	123

Figure 6 – Diagram of the test circuit for the verification of making and breaking capacities of a four-pole equipment (see 8.3.3.5.2).....	124
Figure 7 – Schematic illustration of the recovery voltage across contacts of the first phase to clear under ideal conditions (see 8.3.3.5.2, item e)).....	125
Figure 8a – Diagram of a load circuit adjustment method: load star-point earthed .....	126
Figure 8b – Diagram of a load circuit adjustment method: supply star-point earthed .....	127
Figure 9 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a single-pole equipment on single-phase a.c. or on d.c. (see 8.3.4.1.2) .....	128
Figure 10 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a two-pole equipment on single-phase a.c. or on d.c. (see 8.3.4.1.2) .....	129
Figure 11 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a three-pole equipment (see 8.3.4.1.2).....	130
Figure 12 – Diagram of the test circuit for the verification of short-circuit making and breaking capacities of a four-pole equipment (see 8.3.4.1.2).....	131
Figure 13 – Example of short-circuit making and breaking test record in the case of a single-pole equipment on single-phase a.c. (see 8.3.4.1.8) .....	132
Figure 14 – Verification of short-circuit making and breaking capacities on d.c. (see 8.3.4.1.8) .....	133
Figure 15 – Determination of the prospective breaking current when the first calibration of the test circuit has been made at a current lower than the rated breaking capacity (see 8.3.4.1.8, item b)) .....	134
Figure 16 – Actuator test force (see 8.2.5.2.1 and Table 17) .....	135
Figure 17 – Examples of ports .....	136
Figure 18 – Test set-up for the verification of immunity to electrostatic discharges .....	136
Figure 19 – Test set-up for the verification of immunity to radiated radio-frequency electromagnetic fields .....	137
Figure 20 – Test set-up for the verification of immunity to electrical fast transients/bursts .....	138
Figure 21 – Test set-up for the verification of immunity to conducted disturbances induced by r.f. fields on power lines.....	139
Figure 22 – Example of test set-up for the verification of immunity to conducted disturbances induced by r.f. fields on signal lines when CDN's are not suitable.....	139
Figure 23 – Test set-up for the verification of immunity to power frequency magnetic fields.....	140
Figure C.1 – IP Codes .....	150
Figure D.1 – Screw terminals .....	153
Figure D.2 – Pillar terminals .....	154
Figure D.3 – Stud terminals .....	155
Figure D.4 – Saddle terminals .....	156
Figure D.5 – Lug terminals .....	157
Figure D.6 – Mantle terminals.....	158
Figure D.7 – Screwless-type terminals.....	159
Figure E.1 – Determination of the actual value of the factor $\gamma$ .....	161

Figure G.1 – Measurement of ribs .....	165
Figure G.2 – Creepage distance across the fixed and moving insulation of contact carriers .....	165
Figure M.1 – Test fixture for hot wire ignition test.....	185
Figure M.2 – Circuit for arc ignition test .....	186
Figure N.1 – Example of application with component connected between separated circuits .....	192
Figure O.1 – Conceptual relationship between provisions in product standards and the environmental impacts associated with the product during its life cycle .....	197
Figure P.1 – Dimensions .....	201
Figure R.1 – Operating mechanism outside the enclosure.....	209
Figure R.2 – Operating space for push-button actuation.....	210
Figure R.3 – Examples of finger protected location for hazardous-live-parts in push-button vicinity (approximately 25 mm).....	211
Figure R.4 – Operating space for actuation by rotary means .....	212
Figure S.1 – I/O parameters .....	215
Figure S.2 – U-I operation regions of current-sinking inputs .....	216
Figure S.3 – Temporary overload waveform for digital a.c. outputs.....	218
Figure S.4 – Temporary overload waveform for digital d.c. outputs.....	221

<https://standards.iteh.ai/codex/iec/60947-1:2007>

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

**LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –****Part 1: General rules****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60947-1 has been prepared by subcommittee 17B: Low-voltage switchgear and controlgear, of IEC technical committee 17: Switchgear and controlgear.

This fifth edition of IEC 60947-1 cancels and replaces the fourth edition published in 2004. This edition incorporates Amendment 1 which was not published separately due to the number of changes and pages.

The main changes with respect to the previous edition are as follows:

- modification and restructure of 7.1;
- introduction of new figures concerning EMC tests;
- introduction of new Annexes Q, R and S.

The text of this standard is based on the fourth edition and the following documents:

FDIS	Report on voting
17B/1550/FDIS	17B/1563/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A vertical line in the margin shows where the base publication has been modified by the Amendment 1.

A list of all the parts in the IEC 60947 series, under the general title *Low-voltage switchgear and controlgear* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

<https://standards.iteh.ai/doclog/standards/iec/41269901-c319-40c4-acc9-41b7310afd5b/iec-60947-1-2007>

## LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

### Part 1: General rules

#### 1 General

The purpose of this standard is to harmonize as far as practicable all rules and requirements of a general nature applicable to low-voltage switchgear and controlgear in order to obtain uniformity of requirements and tests throughout the corresponding range of equipment and to avoid the need for testing to different standards.

All those parts of the various equipment standards which can be considered as general have therefore been gathered in this standard together with specific subjects of wide interest and application, e.g. temperature-rise, dielectric properties, etc.

For each type of low-voltage switchgear and controlgear, only two main documents are necessary to determine all requirements and tests:

- 1) this basic standard, referred to as "Part 1" in the specific standards covering the various types of low-voltage switchgear and controlgear;
- 2) the relevant equipment standard hereinafter referred to as the "relevant product standard" or "product standard".

For a general rule to apply to a specific product standard, it shall be explicitly referred to by the latter, by quoting the relevant clause or subclause number of this standard followed by "IEC 60947-1" e.g. "7.2.3 of IEC 60947-1".

A specific product standard may not require, and hence may omit, a general rule (as being not applicable), or it may add to it (if deemed inadequate in the particular case), but it may not deviate from it, unless there is a substantial technical justification.

NOTE The product standards due to be part of the series of IEC standards covering low-voltage switchgear and controlgear are:

- 60947-2: Part 2: Circuit breakers
- 60947-3: Part 3: Switches, disconnectors, switch-disconnectors and fuse combination units
- 60947-4: Part 4: Contactors and motor-starters
- 60947-5: Part 5: Control-circuit devices and switching elements
- 60947-6: Part 6: Multiple function equipment
- 60947-7: Part 7: Ancillary equipment

#### 1.1 Scope and object

This standard applies, when required by the relevant product standard, to switchgear and controlgear hereinafter referred to as "equipment" and intended to be connected to circuits, the rated voltage of which does not exceed 1 000 V a.c. or 1 500 V d.c.

It does not apply to low-voltage switchgear and controlgear assemblies which are dealt with in IEC 60439.

NOTE In certain clauses or subclauses of this standard, the equipment covered by this standard is also referred to as "device", to be consistent with the text of such clauses or subclauses.

The object of this standard is to state those general rules and requirements which are common to low-voltage equipment as defined in 1.1, including for example:

- definitions;
- characteristics;
- information supplied with the equipment;
- normal service, mounting and transport conditions;
- constructional and performance requirements;
- verification of characteristics and performance.

Digital inputs and/or digital outputs contained in switchgear and controlgear, and intended to be compatible with programmable controllers (PLCs) are covered by Annex S.

## 1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050(151):2001, *International Electrotechnical Vocabulary (IEV) – Chapter 151: Electrical and magnetic devices*

IEC 60050(441):1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*  
Amendment 1 (2000)

IEC 60050(604):1987, *International Electrotechnical Vocabulary (IEV) – Chapter 604: Generation, transmission and distribution of electricity – Operation*  
Amendment 1 (1998)

<https://standards.iec.ch/standards/iec-60947-1:2007>

IEC 60050(826):2004, *International Electrotechnical Vocabulary (IEV) – Chapter 826: Electrical installations*

IEC 60060, *High-voltage test techniques*

IEC 60068-1:1988, *Environmental testing – Part 1: General and guidance*  
Amendment 1 (1992)

IEC 60068-2-1:1990, *Environmental testing – Part 2-1: Tests – Tests A: Cold*  
Amendment 1 (1993)  
Amendment 2 (1994)

IEC 60068-2-2:1974, *Environmental testing – Part 2-2: Tests – Tests B: Dry heat*  
Amendment 1 (1993)  
Amendment 2 (1994)

IEC 60068-2-6:1995, *Environmental testing – Part 2-6: Tests – Test Fc: Vibration (sinusoidal)*

IEC 60068-2-27:1987, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*

IEC 60068-2-30:2005, *Environmental testing – Part 2-30: Tests – Test Db: Damp heat, cyclic (12 h + 12 h cycle)*

IEC 60068-2-52:1996, *Environmental testing – Part 2-52: Tests – Test Kb: Salt mist, cyclic (sodium chloride solution)*

IEC 60068-2-78:2001, *Environmental testing – Part 2-78: Tests – Test Cab: Damp heat, steady state*

IEC 60071-1:1993, *Insulation co-ordination – Part 1: Definitions, principles and rules*

IEC 60073:2002, *Basic and safety principles for man-machine interface, marking and identification – Coding principles for indicators and actuators*

IEC 60085:2004, *Electrical insulation – Thermal classification*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60216, *Guide for the determination of thermal endurance properties of electrical insulating materials*

IEC 60228:2004, *Conductors of insulated cables*

IEC 60269-1:1998, *Low-voltage fuses – Part 1: General requirements*  
Amendment 1 (2005)

IEC 60269-2:1986, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application)*  
Amendment 1 (1995)  
Amendment 2 (2001)

IEC 60344:1980, *Guide to the calculation of resistance of plain and coated copper conductors of low-frequency cables and wires*  
Amendment 1 (1985)

IEC 60364-4-44:2001, *Electrical installations of buildings – Part 4-44: Protection for safety – Protection against voltage disturbances and electromagnetic disturbances*  
Amendment 1 (2003)

IEC 60417-DB:2002<sup>1</sup>, *Graphical symbols for use on equipment*

IEC 60439-1:1999, *Low-voltage switchgear and controlgear assemblies – Part 1: Type-tested and partially type-tested assemblies*  
Amendment 1 (2004)

IEC 60445:1999, *Basic and safety principles for man-machine interface, marking and identification – Identification of equipment terminals and of terminations of certain designated conductors, including general rules of an alphanumeric system*

IEC 60447:2004, *Basic and safety principles for man-machine interface, marking and identification – Actuating principles*

<sup>1</sup> “DB” refers to the IEC on-line database.

IEC 60529:1989, *Degrees of protection provided by enclosures (IP code)*  
Amendment 1 (1999)

IEC 60617-DB:2001<sup>1</sup>, *Graphical symbols for diagrams*

IEC 60664-1:1992, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests – Basic safety publication*  
Amendment 1 (2000)  
Amendment 2 (2002)

IEC 60695-2-2:1991, *Fire hazard testing – Part 2: Test methods – Section 2: Needle-flame test*  
Amendment 1 (1994)

IEC 60695-2-10:2000, *Fire hazard testing – Part 2-10: Glowing/hot-wire based test methods – Glow-wire apparatus and common test procedure*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-11-10:1999, *Fire hazard testing – Part 11-10: Test flames – 50 W horizontal and vertical flame test methods*  
Amendment 1 (2003)

IEC 60947-5-1:2003, *Low-voltage switchgear and controlgear – Part 5-1: Control circuit devices and switching elements – Electromechanical control circuit devices*

IEC 60947-8:2003, *Low-voltage switchgear and controlgear – Part 8: Control units for built-in thermal protection (PTC) for rotating electrical machines*  
Amendment 1 (2006)

IEC 60981:2004, *Extra heavy-duty electrical rigid steel conduits*

IEC 61000-3-2:2005, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current ≤ 16 A per phase)*

IEC 61000-3-3:1994, *Electromagnetic compatibility (EMC) – Part 3: Limits – Section 3: Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current ≤ 16 A*  
Amendment 1 (2001)  
Amendment 2 (2005)

IEC 61000-4-2:1995, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 2: Electrostatic discharge immunity test – Basic EMC publication*  
Amendment 1 (1998)  
Amendment 2 (2000)

IEC 61000-4-3:2006, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

IEC 61000-4-4:2004, *Electromagnetic compatibility (EMC) – Part 4-4: Testing and measurement techniques – Electrical test transient/burst immunity test*

IEC 61000-4-5:2005, *Electromagnetic compatibility (EMC) – Part 4-5: Testing and measurement techniques – Surge immunity test*