



Designation: C 1433 – 01

Standard Specification for Precast Reinforced Concrete Box Sections for Culverts, Storm Drains, and Sewers¹

This standard is issued under the fixed designation C 1433; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reappraisal. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reappraisal.

1. Scope

1.1 This specification covers single-cell precast reinforced concrete box sections intended to be used for the construction of culverts and for the conveyance of storm water industrial wastes and sewage.

1.2 This specification is the companion to SI Specification C 1433M; therefore, no SI equivalents are shown in this specification.

NOTE 1—This specification is primarily a manufacturing and purchasing specification. However, standard designs are included and the criteria used to develop these designs are given in Appendix X1. The successful performance of this product depends upon the proper selection of the box section, bedding, backfill, and care that the installation conforms to the construction specifications. The purchaser of the precast reinforced concrete box sections specified herein is cautioned that proper correlation of the loading conditions and the field requirements with the box section specified, and provision for inspection at the construction site, are required.

2. Referenced Documents

2.1 ASTM Standards:

- A 82 Specification for Steel Wire, Plain, for Concrete Reinforcement²
- A 185 Specification for Steel Welded Wire Fabric, Plain, for Concrete Reinforcement²
- A 496 Specification for Steel Wire, Deformed, for Concrete Reinforcement²
- A 497 Specification for Steel Welded Wire Fabric, Deformed, for Concrete Reinforcement²

¹ This specification is under the jurisdiction of Committee C13 on Concrete Pipe and is the direct responsibility of Subcommittee C13.07 on Acceptance Specifications and Precast Concrete Box Sections.

Current edition approved July 10, 2001. Published August 2001. Originally published as C 1433-99. Last previous edition C 1433-00a.

² *Annual Book of ASTM Standards*, Vol 01.04.

- A 615/A 615M Specification for Deformed and Plain Billet-Steel Bars for Concrete Reinforcement²
- C 31/C 31M Practice for Making and Curing Concrete Test Specimens in the Field³
- C 33 Specification for Concrete Aggregates³
- C 39 Test Method for Compressive Strength of Cylindrical Concrete Specimens³
- C 150 Specification for Portland Cement⁴
- C 309 Specification for Liquid Membrane-Forming Compounds for Curing Concrete³
- C 497 Test Methods for Concrete Pipe, Manhole Sections, or Tile [Metric]⁵
- C 595 Specification for Blended Hydraulic Cements⁴
- C 618 Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use as a Mineral Admixture in Concrete³
- C 822 Terminology Relating to Concrete Pipe and Related Products⁵
- 2.2 *AASHTO Standard*.⁶
Specifications for Highway Bridges, 1997 Edition

3. Terminology

3.1 *Definitions*—For definitions of terms relating to concrete pipe, see Terminology C 822.

4. Types

4.1 Precast reinforced concrete box sections manufactured in accordance with this specification shall be one of two types identified in Tables 1 and 2, and shall be designated by type, span, rise, and design earth cover.

³ *Annual Book of ASTM Standards*, Vol 04.02.

⁴ *Annual Book of ASTM Standards*, Vol 04.01.

⁵ *Annual Book of ASTM Standards*, Vol 04.05.

⁶ Available from American Association of State Highway and Transportation Officials (AASHTO).

TABLE 1 Design Requirements for Precast Concrete Box Sections Under Earth Dead and HS20 Live Load Conditions

NOTE 1—Design earth covers and reinforcement areas are based on the weight of a column of earth over the width of the box section as defined in Appendix X1.

NOTE 2—Concrete design strength 5000 psi.

NOTE 3—The design earth cover indicated is the height of fill above the top of the box section. Design requirements are based on the material and soil properties, loading data, and typical section as included in Appendix X1. For alternative or special designs, see 7.2.

NOTE 4—Design steel area in square inches per linear foot of box section at those locations which are indicated on the typical section included in Appendix X1.

NOTE 5—The top section designation, for example, 3 ft by 2 ft by 4 in. indicates (interior horizontal span in feet) by (interior vertical rise in feet) by (wall and slab thickness in inches).

NOTE 6—In accordance with the acceptance criteria in 7.2, the manufacturer may interpolate the steel area requirements for fill heights between noted increments or may submit independent designs.

3 ft by 2 ft by 4 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.17	0.39	0.22	0.10	0.19	0.17	0.17	0.14	18
2<3	0.15	0.27	0.27	0.10					18
3-5	0.10	0.12	0.12	0.10					18
10	0.10	0.10	0.10	0.10					18
15	0.10	0.13	0.14	0.10					18
20	0.11	0.17	0.18	0.10					18
25	0.14	0.22	0.22	0.10					18
30	0.17	0.26	0.26	0.10					18

^A Top slab 7 in., bottom slab 6 in.

3 ft by 3 ft by 4 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.17	0.41	0.23	0.10	0.20	0.17	0.17	0.14	18
2<3	0.11	0.31	0.31	0.10					18
3-5	0.10	0.14	0.14	0.10					18
10	0.10	0.11	0.11	0.10					18
15	0.10	0.15	0.15	0.10					18
20	0.10	0.19	0.20	0.10					18
25	0.10	0.23	0.24	0.10					18
30	0.12	0.28	0.29	0.10					18

^A Top slab 7 in., bottom slab 6 in.

4 ft by 2 ft by 5 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.42	0.22	0.12	0.21	0.18	0.18	0.14	18
2<3	0.24	0.29	0.25	0.12					18
3-5	0.12	0.14	0.14	0.12					18
10	0.12	0.12	0.12	0.12					18
15	0.15	0.16	0.16	0.12					18
20	0.19	0.21	0.21	0.12					18
25	0.24	0.26	0.26	0.12					18
30	0.28	0.31	0.31	0.12					18

^A Top slab 8 in., bottom slab 6 in.

4 ft by 3 ft by 5 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.46	0.25	0.12	0.23	0.18	0.18	0.14	18
2<3	0.20	0.35	0.31	0.12					18
3-5	0.12	0.17	0.17	0.12					18
10	0.12	0.14	0.14	0.12					18

15	0.12	0.19	0.19	0.12					18
20	0.14	0.24	0.25	0.12					18
25	0.18	0.30	0.30	0.12					18
30	0.21	0.36	0.36	0.12					18

^A Top slab 8 in., bottom slab 6 in.

4 ft by 4 ft by 5 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.48	0.27	0.12	0.24	0.18	0.18	0.14	18
2<3	0.16	0.38	0.34	0.12					18
3-5	0.12	0.18	0.18	0.12					18
10	0.12	0.15	0.15	0.12					18
15	0.12	0.20	0.21	0.12					18
20	0.12	0.26	0.26	0.12					18
25	0.15	0.31	0.32	0.12					18
30	0.17	0.38	0.38	0.12					18

^A Top slab 8 in., bottom slab 6 in.

5 ft by 3 ft by 6 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.19	0.47	0.24	0.14	0.22	0.19	0.19	0.17	18
2<3	0.26	0.36	0.28	0.14					18
3-5	0.14	0.19	0.19	0.14					18
10	0.14	0.16	0.16	0.14					18
15	0.17	0.22	0.22	0.14					18
20	0.21	0.28	0.29	0.14					18
25	0.26	0.35	0.35	0.14					18
30	0.32	0.42	0.42	0.14					18

^A Top slab 8 in., bottom slab 7 in.

5 ft by 4 ft by 6 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.19	0.50	0.27	0.14	0.24	0.19	0.19	0.17	18
2<3	0.22	0.41	0.33	0.14					18
3-5	0.14	0.21	0.21	0.14					18
10	0.14	0.17	0.18	0.14					18
15	0.14	0.24	0.25	0.14					18
20	0.18	0.31	0.32	0.14					18
25	0.22	0.38	0.39	0.14					18
30	0.26	0.46	0.46	0.14					18

^A Top slab 8 in., bottom slab 7 in.

5 ft by 5 ft by 6 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.19	0.52	0.29	0.14	0.24	0.19	0.19	0.17	18
2<3	0.19	0.43	0.35	0.14					18
3-5	0.14	0.22	0.22	0.14					18
10	0.14	0.18	0.19	0.14					18
15	0.14	0.25	0.26	0.14					18
20	0.15	0.32	0.33	0.14					18
25	0.19	0.40	0.41	0.14					18
30	0.23	0.47	0.48	0.14					18

^A Top slab 8 in., bottom slab 7 in.

6 ft by 3 ft by 7 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.25	0.48	0.23	0.17	0.21	0.19	0.19	0.17	18
2<3	0.30	0.38	0.26	0.17					18
3-5	0.17	0.20	0.17	0.17					18
10	0.17	0.18	0.18	0.17					18
15	0.23	0.25	0.25	0.17					18

20	0.29	0.32	0.32	0.17	18
25	0.36	0.39	0.40	0.17	18
30	0.43	0.47	0.47	0.17	18

^A Top slab 8 in.

6 ft by 4 ft by 7 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2 ^A	0.20	0.52	0.26	0.17	0.22	0.19	0.19	0.17	
2<3	0.26	0.42	0.31	0.17					18
3-5	0.17	0.23	0.21	0.17					18
10	0.17	0.20	0.21	0.17					18
15	0.19	0.28	0.28	0.17					18
20	0.25	0.36	0.36	0.17					18
25	0.30	0.44	0.45	0.17					18
30	0.36	0.52	0.53	0.17					18

^A Top slab 8 in.

6 ft by 5 ft by 7 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2 ^A	0.19	0.55	0.29	0.17	0.24	0.19	0.19	0.17	
2<3	0.23	0.45	0.34	0.17					18
3-5	0.17	0.24	0.22	0.17					18
10	0.17	0.21	0.23	0.17					18
15	0.17	0.29	0.31	0.17					18
20	0.21	0.38	0.39	0.17					18
25	0.26	0.46	0.48	0.17					18
30	0.31	0.56	0.58	0.17					18

^A Top slab 8 in.

6 ft by 6 ft by 7 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2 ^A	0.19	0.57	0.31	0.17	0.25	0.19	0.19	0.17	
2<3	0.21	0.48	0.36	0.17					18
3-5	0.17	0.25	0.23	0.17					18
10	0.17	0.22	0.24	0.17					18
15	0.17	0.31	0.32	0.17					18
20	0.19	0.39	0.41	0.17					18
25	0.23	0.48	0.49	0.17					18
30	0.28	0.58	0.61	0.17					18

^A Top slab 8 in.

7 ft by 4 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.28	0.53	0.24	0.19	0.21	0.19	0.19	0.19	
2<3	0.30	0.43	0.29	0.19					18
3-5	0.19	0.24	0.19	0.19					18
10	0.19	0.22	0.23	0.19					18
15	0.25	0.31	0.32	0.19					18
20	0.32	0.40	0.40	0.19					18
25	0.39	0.49	0.49	0.19					18
30	0.47	0.58	0.59	0.19					18

7 ft by 5 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.25	0.56	0.28	0.19	0.22	0.19	0.19	0.19	
2<3	0.27	0.47	0.33	0.19					18
3-5	0.19	0.26	0.22	0.19					18
10	0.19	0.24	0.25	0.19					18
15	0.22	0.33	0.34	0.19					18
20	0.28	0.43	0.44	0.19					18
25	0.34	0.52	0.54	0.19					18
30	0.41	0.64	0.66	0.19					18

7 ft by 6 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.22	0.58	0.30	0.19	0.23	0.19	0.19	0.19	
2<3	0.24	0.49	0.35	0.19					18
3-5	0.19	0.27	0.23	0.19					18
10	0.19	0.26	0.27	0.19					18
15	0.20	0.35	0.37	0.19					18
20	0.25	0.45	0.46	0.19					18
25	0.30	0.55	0.57	0.19					18
30	0.36	0.68	0.73	0.19					18

7 ft by 7 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.23	0.60	0.31	0.19	0.24	0.19	0.19	0.19	
2<3	0.22	0.51	0.37	0.19					18
3-5	0.19	0.28	0.24	0.19					18
10	0.19	0.27	0.29	0.19					18
15	0.19	0.36	0.38	0.19					18
20	0.23	0.46	0.48	0.19					18
25	0.28	0.56	0.58	0.19					18
30	0.33	0.70	0.77	0.19					18

8 ft by 4 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.34	0.58	0.27	0.19	0.19	0.19	0.19	0.19	
2<3	0.37	0.50	0.33	0.19					37
3-5	0.23	0.29	0.25	0.19					18
10	0.26	0.28	0.29	0.19					18
15	0.36	0.39	0.40	0.19					18
20	0.46	0.50	0.51	0.19					18
25	0.57	0.63	0.64	0.19					36

8 ft by 5 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.30	0.62	0.30	0.19	0.23	0.19	0.19	0.19	
2<3	0.35	0.54	0.37	0.19					18
3-5	0.20	0.31	0.26	0.19					18
10	0.23	0.30	0.32	0.19					18
15	0.32	0.42	0.43	0.19					18
20	0.41	0.54	0.56	0.19					18
25	0.50	0.71	0.73	0.19					31

8 ft by 6 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.28	0.64	0.33	0.19	0.24	0.19	0.19	0.19	
2<3	0.32	0.57	0.40	0.19					18
3-5	0.19	0.33	0.27	0.19					18
10	0.21	0.32	0.34	0.19					18
15	0.29	0.45	0.46	0.19					18
20	0.37	0.57	0.59	0.19					18
25	0.45	0.77	0.79	0.19					31

8 ft by 7 ft by 8 in.									
Circumferential Reinforcement Areas, in. ² /ft									
Design Earth Cover, ft	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	"M," in.
0<2	0.27	0.66	0.35	0.19	0.24	0.19	0.19	0.19	
2<3	0.29	0.60	0.42	0.19					18
3-5	0.19	0.33	0.29	0.19					18
10	0.20	0.34	0.36	0.19					18
15	0.27	0.46	0.49	0.19					18
20	0.34	0.60	0.62	0.19					18
25	0.42	0.80	0.84	0.19					31

8 ft by 8 ft by 8 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.30	0.68	0.36	0.19	0.25	0.19	0.19	0.19	
2<3	0.27	0.61	0.43	0.19					18
3-5	0.19	0.34	0.31	0.19					18
10	0.19	0.35	0.38	0.19					18
15	0.25	0.48	0.51	0.19					18
20	0.32	0.61	0.65	0.19					18
25	0.39	0.83	0.87	0.19					31

9 ft by 5 ft by 9 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.32	0.59	0.29	0.22	0.22	0.22	0.22	0.22	
2<3	0.37	0.54	0.35	0.22					18
3-5	0.22	0.32	0.26	0.22					18
10	0.28	0.33	0.34	0.22					18
15	0.38	0.45	0.46	0.22					18
20	0.49	0.58	0.59	0.22					18
25	0.60	0.75	0.77	0.22					33

9 ft by 6 ft by 9 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.29	0.62	0.31	0.22	0.22	0.22	0.22	0.22	
2<3	0.34	0.57	0.38	0.22					18
3-5	0.22	0.34	0.28	0.22					18
10	0.26	0.35	0.37	0.22					18
15	0.35	0.48	0.50	0.22					18
20	0.44	0.62	0.64	0.22					18
25	0.54	0.82	0.84	0.22					33

9 ft by 7 ft by 9 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.27	0.64	0.33	0.22	0.22	0.22	0.22	0.22	
2<3	0.31	0.60	0.41	0.22					18
3-5	0.22	0.35	0.30	0.22					18
10	0.24	0.37	0.39	0.22					18
15	0.32	0.50	0.53	0.22					18
20	0.41	0.65	0.67	0.22					18
25	0.50	0.87	0.92	0.22					33

9 ft by 8 ft by 9 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.28	0.65	0.35	0.22	0.23	0.22	0.22	0.22	
2<3	0.29	0.62	0.42	0.22					18
3-5	0.22	0.33	0.35	0.22					18
10	0.22	0.38	0.41	0.22					18
15	0.30	0.52	0.55	0.22					18
20	0.38	0.66	0.71	0.22					18
25	0.46	0.90	0.98	0.22					33

9 ft by 9 ft by 9 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.31	0.66	0.35	0.22	0.23	0.22	0.22	0.22	
2<3	0.27	0.63	0.43	0.22					18
3-5	0.22	0.35	0.35	0.22					18
10	0.22	0.39	0.43	0.22					18
15	0.28	0.53	0.57	0.22					18
20	0.36	0.68	0.74	0.22					18
25	0.44	0.93	1.03	0.22					33

10 ft by 5 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.33	0.57	0.27	0.24	0.24	0.24	0.24	0.24	
2<3	0.39	0.55	0.34	0.24					18
3-5	0.25	0.33	0.27	0.24					18
10	0.32	0.35	0.36	0.24					18
15	0.44	0.48	0.49	0.24					18
20	0.57	0.61	0.63	0.24					18
25	0.70	0.78	0.80	0.24					40

10 ft by 6 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.30	0.60	0.30	0.24	0.24	0.24	0.24	0.24	
2<3	0.37	0.58	0.37	0.24					18
3-5	0.24	0.35	0.29	0.24					18
10	0.30	0.37	0.39	0.24					18
15	0.40	0.51	0.53	0.24					18
20	0.52	0.66	0.68	0.24					18
25	0.64	0.86	0.91	0.24					35

10 ft by 7 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.28	0.62	0.32	0.24	0.24	0.24	0.24	0.24	
2<3	0.34	0.60	0.40	0.24					18
3-5	0.24	0.36	0.31	0.24					18
10	0.28	0.39	0.42	0.24					18
15	0.37	0.54	0.56	0.24					18
20	0.48	0.69	0.72	0.24					18
25	0.58	0.92	1.01	0.24					35

10 ft by 8 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.26	0.63	0.34	0.24	0.24	0.24	0.24	0.24	
2<3	0.31	0.62	0.42	0.24					18
3-5	0.24	0.37	0.34	0.24					18
10	0.26	0.41	0.44	0.24					18
15	0.35	0.56	0.59	0.24					18
20	0.44	0.72	0.75	0.24					18
25	0.54	0.97	1.09	0.24					35

10 ft by 9 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.29	0.65	0.35	0.24	0.24	0.24	0.24	0.24	
2<3	0.29	0.64	0.43	0.24					18
3-5	0.24	0.37	0.36	0.24					18
10	0.25	0.43	0.46	0.24					18
15	0.33	0.58	0.61	0.24					18
20	0.42	0.74	0.80	0.24					18
25	0.51	1.01	1.16	0.24					35

10 ft by 10 ft by 10 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.32	0.65	0.37	0.24	0.24	0.24	0.24	0.24	
2<3	0.27	0.65	0.44	0.24					18
3-5	0.24	0.37	0.38	0.24					18
10	0.24	0.44	0.48	0.24					18
15	0.32	0.59	0.64	0.24					18
20	0.40	0.76	0.83	0.24					18
25	0.49	1.03	1.21	0.24					35

11 ft by 4 ft by 11 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.38	0.52	0.26	0.26	0.26	0.26	0.26	0.26	
2<3	0.45	0.51	0.28	0.26					18
3-5	0.30	0.30	0.26	0.26					18
10	0.40	0.33	0.34	0.26					18
15	0.56	0.46	0.47	0.26					18
20	0.72	0.59	0.60	0.26					42
25	0.89	0.72	0.73	0.26					44

11 ft by 6 ft by 11 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.32	0.58	0.29	0.26	0.26	0.26	0.26	0.26	
2<3	0.38	0.58	0.36	0.26					18
3-5	0.26	0.35	0.30	0.26					18
10	0.34	0.39	0.41	0.26					18
15	0.47	0.54	0.56	0.26					18
20	0.60	0.69	0.71	0.26					18
25	0.73	0.90	0.97	0.26					36

11 ft by 8 ft by 11 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.27	0.62	0.33	0.26	0.26	0.26	0.26	0.26	
2<3	0.33	0.63	0.41	0.26					18
3-5	0.26	0.38	0.35	0.26					18
10	0.30	0.44	0.47	0.26					18
15	0.41	0.60	0.63	0.26					18
20	0.51	0.77	0.80	0.26					18
25	0.63	1.07	1.20	0.26					36

11 ft by 10 ft by 11 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.30	0.64	0.36	0.26	0.26	0.26	0.26	0.26	
2<3	0.29	0.65	0.43	0.26					18
3-5	0.26	0.38	0.39	0.26					18
10	0.28	0.47	0.51	0.26					18
15	0.37	0.64	0.68	0.26					18
20	0.46	0.82	0.89	0.26					18
25	0.56	1.16	1.35	0.26					36

11 ft by 11 ft by 11 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.34	0.64	0.39	0.26	0.26	0.26	0.26	0.26	
2<3	0.27	0.66	0.45	0.26					18
3-5	0.26	0.39	0.42	0.26					18
10	0.27	0.49	0.54	0.26					18
15	0.35	0.65	0.71	0.26					18
20	0.44	0.84	0.93	0.26					18
25	0.54	1.18	1.40	0.26					36

12 ft by 4 ft by 12 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.39	0.50	0.29	0.29	0.29	0.29	0.29	0.29	
2<3	0.48	0.51	0.29	0.29					18
3-5	0.33	0.30	0.29	0.29					18
10	0.46	0.35	0.36	0.29					18
15	0.63	0.48	0.49	0.29					18
20	0.81	0.62	0.63	0.29					18
25	1.00	0.76	0.77	0.29					46

12 ft by 6 ft by 12 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.33	0.57	0.29	0.29	0.29	0.29	0.29	0.29	
2<3	0.40	0.58	0.35	0.29					18
3-5	0.29	0.36	0.31	0.29					18
10	0.39	0.42	0.43	0.29					18
15	0.53	0.57	0.59	0.29					18
20	0.68	0.73	0.75	0.29					18
25	0.83	0.94	1.02	0.29					44

12 ft by 8 ft by 12 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.29	0.61	0.33	0.29	0.29	0.29	0.29	0.29	
2<3	0.35	0.63	0.40	0.29					18
3-5	0.29	0.39	0.36	0.29					18
10	0.35	0.46	0.49	0.29					18
15	0.46	0.63	0.66	0.29					18
20	0.59	0.81	0.84	0.29					18
25	0.72	1.15	1.29	0.29					38

12 ft by 10 ft by 12 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.29	0.63	0.36	0.29	0.29	0.29	0.29	0.29	
2<3	0.31	0.66	0.43	0.29					18
3-5	0.29	0.40	0.41	0.29					18
10	0.32	0.50	0.55	0.29					18
15	0.42	0.68	0.73	0.29					18
20	0.53	0.87	0.94	0.29					18
25	0.64	1.28	1.47	0.29					38

12 ft by 12 ft by 12 in.									
Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2	0.35	0.64	0.41	0.33	0.29	0.29	0.29	0.29	
2<3	0.29	0.67	0.48	0.29					18
3-5	0.29	0.42	0.45	0.29					18
10	0.29	0.53	0.59	0.29					18
15	0.39	0.71	0.78	0.29					18
20	0.48	0.93	1.03	0.29					18
25	0.59	1.34	1.61	0.29					38

TABLE 2 Design Requirements for Precast Concrete Box Sections Under Earth Dead and Interstate Live Load Conditions

NOTE 1—Design earth covers and reinforcement areas are based on the weight of a column of earth over the width of the box section as defined in Appendix X1.

NOTE 2—Concrete design strength 5000 psi.

NOTE 3—The design earth cover indicated is the height of fill above the top of the box section. Design requirements are based on the material and soil properties, loading data, and typical section as included in Appendix X1. For alternative or special designs, see 7.2.

NOTE 4—Design steel area in square inches per linear foot of box section at those locations which are indicated on the typical section included in Appendix X1.

NOTE 5—The top section designation, for example, 3 ft by 2 ft by 4 in. indicates (interior horizontal span in feet) by (interior vertical rise in feet) by (wall and slab thickness in inches).

NOTE 6—In accordance with the acceptance criteria in 7.2, the manufacturer may interpolate the steel area requirements for fill heights between noted increments or may submit independent designs.

3 ft by 2 ft by 4 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.17	0.39	0.22	0.10	0.19	0.17	0.17	0.14	
2<3	0.15	0.27	0.27	0.10					18
3-5	0.10	0.12	0.12	0.10					18
10	0.10	0.10	0.10	0.10					18
15	0.10	0.14	0.14	0.10					18
20	0.12	0.18	0.18	0.10					18
25	0.14	0.22	0.22	0.10					18
30	0.17	0.26	0.26	0.10					18

^A Top slab 7 in., bottom slab 6 in.

3 ft by 3 ft by 4 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.17	0.41	0.23	0.10	0.20	0.17	0.17	0.14	
2<3	0.11	0.31	0.31	0.10					18
3-5	0.10	0.14	0.14	0.10					18
10	0.10	0.11	0.11	0.10					18
15	0.10	0.15	0.16	0.10					18
20	0.10	0.19	0.20	0.10					18
25	0.10	0.24	0.24	0.10					18
30	0.12	0.28	0.29	0.10					18

^A Top slab 7 in., bottom slab 6 in.

4 ft by 2 ft by 5 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.42	0.22	0.12	0.21	0.18	0.18	0.14	
2<3	0.24	0.29	0.25	0.12					18
3-5	0.12	0.14	0.14	0.12					18
10	0.12	0.12	0.12	0.12					18
15	0.15	0.17	0.17	0.12					18
20	0.19	0.21	0.21	0.12					18
25	0.24	0.26	0.26	0.12					18
30	0.29	0.31	0.31	0.12					18

^A Top slab 8 in., bottom slab 6 in.

4 ft by 3 ft by 5 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.46	0.25	0.12	0.23	0.18	0.18	0.14	
2<3	0.20	0.35	0.31	0.12					18
3-5	0.12	0.17	0.17	0.12					18
10	0.12	0.14	0.14	0.12					18

15	0.12	0.19	0.20	0.12					18
20	0.15	0.25	0.25	0.12					18
25	0.18	0.30	0.31	0.12					18
30	0.21	0.36	0.36	0.12					18

^A Top slab 8 in., bottom slab 6 in.

4 ft by 4 ft by 5 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.18	0.48	0.27	0.12	0.24	0.18	0.18	0.14	
2<3	0.16	0.38	0.34	0.12					18
3-5	0.12	0.18	0.18	0.12					18
10	0.12	0.15	0.16	0.12					18
15	0.12	0.20	0.21	0.12					18
20	0.12	0.26	0.27	0.12					18
25	0.15	0.32	0.33	0.12					18
30	0.18	0.38	0.39	0.12					18

^A Top slab 8 in., bottom slab 6 in.

5 ft by 3 ft by 6 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.20	0.47	0.30	0.14	0.22	0.19	0.19	0.17	
2<3	0.26	0.36	0.28	0.14					18
3-5	0.14	0.19	0.19	0.14					18
10	0.14	0.16	0.17	0.14					18
15	0.17	0.22	0.23	0.14					18
20	0.22	0.29	0.29	0.14					18
25	0.27	0.35	0.36	0.14					18
30	0.32	0.42	0.43	0.14					18

^A Top slab 8 in., bottom slab 7 in.

5 ft by 4 ft by 6 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.19	0.50	0.34	0.14	0.24	0.19	0.19	0.17	
2<3	0.22	0.41	0.33	0.14					18
3-5	0.14	0.21	0.21	0.14					18
10	0.14	0.18	0.19	0.14					18
15	0.14	0.24	0.25	0.14					18
20	0.18	0.31	0.32	0.14					18
25	0.22	0.38	0.39	0.14					18
30	0.26	0.46	0.47	0.14					18

^A Top slab 8 in., bottom slab 7 in.

5 ft by 5 ft by 6 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.19	0.52	0.36	0.14	0.24	0.19	0.19	0.17	
2<3	0.19	0.43	0.35	0.14					18
3-5	0.14	0.22	0.22	0.14					18
10	0.14	0.19	0.20	0.14					18
15	0.14	0.26	0.27	0.14					18
20	0.16	0.33	0.34	0.14					18
25	0.19	0.40	0.41	0.14					18
30	0.23	0.48	0.49	0.14					18

^A Top slab 8 in., bottom slab 7 in.

6 ft by 3 ft by 7 in.

Design Earth Cover, ft	Circumferential Reinforcement Areas, in. ² /ft								"M," in.
	A _{s1}	A _{s2}	A _{s3}	A _{s4}	A _{s5}	A _{s6}	A _{s7}	A _{s8}	
0<2 ^A	0.25	0.48	0.32	0.17	0.21	0.19	0.19	0.17	
2<3	0.30	0.38	0.26	0.17					18
3-5	0.17	0.20	0.17	0.17					18
10	0.17	0.18	0.19	0.17					18
15	0.23	0.25	0.26	0.17					18