

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

**Câbles électriques – Calcul du courant admissible –
Partie 1-1: Equations de l'intensité du courant admissible (facteur de charge
100 %) et calcul des pertes – Généralités**



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2014 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

**Câbles électriques – Calcul du courant admissible –
Partie 1-1: Equations de l'intensité du courant admissible (facteur de charge
100 %) et calcul des pertes – Généralités**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.060.20

ISBN 978-2-8322-1926-3

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

Withdrawn

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[iec-60287-1-1-2006](https://standards.iteh.ai/standards/iec/d/0622c5-58f4-4731-861a-e53abdb929ad/iec-60287-1-1-2006)

<https://standards.iteh.ai/standards/iec/d/0622c5-58f4-4731-861a-e53abdb929ad/iec-60287-1-1-2006>

REDLINE VERSION

VERSION REDLINE



**Electric cables – Calculation of the current rating –
Part 1-1: Current rating equations (100 % load factor) and calculation of losses –
General**

**Câbles électriques – Calcul du courant admissible –
Partie 1-1: Equations de l'intensité du courant admissible (facteur de charge
100 %) et calcul des pertes – Généralités**

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
1 General.....	6
1.1 Scope.....	6
1.2 Normative references.....	6
1.3 Symbols.....	7
1.4 Permissible current rating of cables.....	10
2 Calculation of losses.....	13
2.1 AC resistance of conductor.....	13
2.2 Dielectric losses (applicable to a.c. cables only).....	16
2.3 Loss factor for sheath and screen (applicable to power frequency a.c. cables only).....	16
2.4 Loss factor for armour, reinforcement and steel pipes (applicable to power frequency a.c. cables only).....	25
Table 1 – Electrical resistivities and temperature coefficients of metals used.....	30
Table 2 – Skin and proximity effects – Experimental values for the coefficients k_s and k_p	31
Table 3 – Values of relative permittivity and loss factors for the insulation of high-voltage and medium-voltage cables at power frequency.....	33
Table 4 – Absorption coefficient of solar radiation for cable surfaces.....	34

IEC 60287-1-1:2006

<https://standards.iteh.ai/catalog/standards/iec/d/0622c5-58f4-4731-861a-e53abdb929ad/iec-60287-1-1-2006>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ELECTRIC CABLES –
CALCULATION OF THE CURRENT RATING –**

**Part 1-1: Current rating equations (100 % load factor)
and calculation of losses – General**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 60287-1-1 edition 2.1 contains the second edition (2006-12) [documents 20/851/FDIS and 20/867/RVD] and its amendment 1 (2014-11) [documents 20/1499/FDIS and 20/1547/RVD].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions and deletions are displayed in red, with deletions being struck through. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 60287-1-1 has been prepared by IEC technical committee 20: Electric cables.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60287 series, published under the general title: *Electric cables – Calculation of the current rating*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The “colour inside” logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

ITeH Standards
(<https://standards.iteh.ai>)
Document Preview
IEC 60287-1-1:2006
<https://standards.iteh.ai/catalog/standards/iec/d/0622c5-58f4-4731-861a-e53abdb929ad/iec-60287-1-1-2006>

INTRODUCTION

This Part 1-1 contains formulae for the quantities R , W_d , λ_1 and λ_2 .

It contains methods for calculating the permissible current rating of cables from details of the permissible temperature rise, conductor resistance, losses and thermal resistivities.

Formulae for the calculation of losses are also given.

The formulae in this standard contain quantities which vary with cable design and materials used. The values given in the tables are either internationally agreed, for example, electrical resistivities and resistance temperature coefficients, or are those which are generally accepted in practice, for example, thermal resistivities and permittivities of materials. In this latter category, some of the values given are not characteristic of the quality of new cables but are considered to apply to cables after a long period of use. In order that uniform and comparable results may be obtained, the current ratings should be calculated with the values given in this standard. However, where it is known with certainty that other values are more appropriate to the materials and design, then these may be used, and the corresponding current rating declared in addition, provided that the different values are quoted.

Quantities related to the operating conditions of cables are liable to vary considerably from one country to another. For instance, with respect to the ambient temperature and soil thermal resistivity, the values are governed in various countries by different considerations. Superficial comparisons between the values used in the various countries may lead to erroneous conclusions if they are not based on common criteria: for example, there may be different expectations for the life of the cables, and in some countries design is based on maximum values of soil thermal resistivity, whereas in others average values are used. Particularly, in the case of soil thermal resistivity, it is well known that this quantity is very sensitive to soil moisture content and may vary significantly with time, depending on the soil type, the topographical and meteorological conditions, and the cable loading.

The following procedure for choosing the values for the various parameters should, therefore, be adopted.

Numerical values should preferably be based on results of suitable measurements. Often such results are already included in national specifications as recommended values, so that the calculation may be based on these values generally used in the country in question; a survey of such values is given in Part 3-1.

A suggested list of the information required to select the appropriate type of cable is given in Part 3-1.

ELECTRIC CABLES – CALCULATION OF THE CURRENT RATING –

Part 1-1: Current rating equations (100 % load factor) and calculation of losses – General

1 General

1.1 Scope

This part of IEC 60287 is applicable to the conditions of steady-state operation of cables at all alternating voltages, and direct voltages up to 5 kV, buried directly in the ground, in ducts, troughs or in steel pipes, both with and without partial drying-out of the soil, as well as cables in air. The term "steady state" is intended to mean a continuous constant current (100 % load factor) just sufficient to produce asymptotically the maximum conductor temperature, the surrounding ambient conditions being assumed constant.

This part provides formulae for current ratings and losses.

The formulae given are essentially literal and designedly leave open the selection of certain important parameters. These may be divided into three groups:

- parameters related to construction of a cable (for example, thermal resistivity of insulating material) for which representative values have been selected based on published work;
- parameters related to the surrounding conditions, which may vary widely, the selection of which depends on the country in which the cables are used or are to be used;
- parameters which result from an agreement between manufacturer and user and which involve a margin for security of service (for example, maximum conductor temperature).

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60027-3, *Letter symbols to be used in electrical technology – Part 3: Logarithmic and related quantities, and their units*

IEC 60028:1925, *International standard of resistance for copper*

IEC 60141 (all parts), *Tests on oil-filled and gas-pressure cables and their accessories*

IEC 60228, *Conductors of insulated cables*

IEC 60502-1, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)*

IEC 60502-2, *Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 2: Cables for rated voltages from 6 kV ($U_m = 7,2$ kV) up to 30 kV ($U_m = 36$ kV)*

IEC 60889, *Hard-drawn aluminium wire for overhead line conductors*

1.3 Symbols

The symbols used in this standard and the quantities which they represent are given in the following list:

A	cross-sectional area of the armour	mm^2
B_1 B_2	} coefficients (see 2.4.2)	
C	capacitance per core	F/m
D_e^*	external diameter of cable	m
D_i	diameter over insulation	mm
D_s	external diameter of metal sheath	mm
D_{oc}	the diameter of the imaginary coaxial cylinder which just touches the crests of a corrugated sheath	mm
D_{it}	the diameter of the imaginary cylinder which just touches the inside surface of the troughs of a corrugated sheath	mm
F	coefficient defined in 2.3.5	
H	intensity of solar radiation	W/m^2
H	magnetizing force (see 2.4.2)	ampere turns/m
H_s	inductance of sheath	H/m
H_1 H_2 H_3	} components of inductance due to the steel wires (see 2.4.2)	H/m
I	current in one conductor (r.m.s. value)	A
M N	} coefficients defined in 2.3.5	
P Q	} coefficients defined in 2.3.3	Ω/m
R	alternating current resistance of conductor at its maximum operating temperature	Ω/m
R_A	a.c. resistance of armour at its maximum operating temperature	Ω/m
R_{A0}	a.c. resistance of armour at 20 °C	Ω/m
R_e	equivalent a.c. resistance of sheath and armour in parallel	Ω/m
R_s	a.c. resistance of cable sheath or screen at their maximum operating temperature	Ω/m
R_{s0}	a.c. resistance of cable sheath or screen at 20 °C	Ω/m
R'	d.c. resistance of conductor at maximum operating temperature	Ω/m
R_0	d.c. resistance of conductor at 20 °C	Ω/m
T_1	thermal resistance per core between conductor and sheath	K.m/W
T_2	thermal resistance between sheath and armour	K.m/W
T_3	thermal resistance of external serving	K.m/W
T_4	thermal resistance of surrounding medium (ratio of cable surface temperature rise above ambient to the losses per unit length)	K.m/W

T_4^*	external thermal resistance in free air, adjusted for solar radiation	K.m/W
U_0	voltage between conductor and screen or sheath	V
W_A	losses in armour per unit length	W/m
W_C	losses in conductor per unit length	W/m
W_d	dielectric losses per unit length per phase	W/m
W_s	losses dissipated in sheath per unit length	W/m
$W_{(s+A)}$	total losses in sheath and armour per unit length	W/m
X	reactance of sheath (two-core cables and three-core cables in trefoil)	Ω/m
X_1	reactance of sheath (cables in flat formation)	Ω/m
X_m	mutual reactance between the sheath of one cable and the conductors of the other two when cables are in flat information	Ω/m
a	shortest minor length in a cross-bonded electrical section having unequal minor lengths	
c	distance between the axes of conductors and the axis of the cable for three-core cables (= $0,55 r_1 + 0,29 t$ for sector-shaped conductors)	mm
d	mean diameter of sheath or screen	mm
d'	mean diameter of sheath and reinforcement	mm
d_2	mean diameter of reinforcement	mm
d_A	mean diameter of armour	mm
d_c	external diameter of conductor	mm
d'_c	external diameter of equivalent round solid conductor having the same central duct as a hollow conductor	mm
d_d	internal diameter of pipe	mm
d_f	diameter of a steel wire	mm
d_i	internal diameter of hollow conductor	mm
d_M	major diameter of screen or sheath of an oval conductor	mm
d_m	minor diameter of screen or sheath of an oval conductor	mm
d_x	diameter of an equivalent circular conductor having the same cross-sectional area and degree of compactness as the shaped one	mm
f	system frequency	Hz
g_s	coefficient used in 2.3.6.1	
k	factor used in the calculation of hysteresis losses in armour or reinforcement (see 2.4.2.4)	
k_p	factor used in calculating x_p (proximity effect)	
k_s	factor used in calculating x_s (skin effect)	
l	length of a cable section (general symbol, see 2.3 and 2.3.4)	m
\ln	natural logarithm (logarithm to base e, see IEC 60027-3)	
m	$\frac{\omega}{R_s} 10^{-7}$	
n	number of conductors in a cable	
n_1	number of steel wires in a cable (see 2.4.2)	
p	length of lay of a steel wire along a cable (see 2.4.2)	
p q }	coefficients used in 2.3.6.2	
r_1	circumscribing radius of two- or three-sector shaped conductors	mm

s	axial separation of conductors	mm
s_1	axial separation of two adjacent cables in a horizontal group of three, not touching	mm
s_2	axial separation of cables (see 2.4.2)	mm
t	insulation thickness between conductors	mm
t_3	thickness of the serving	mm
t_s	thickness of the sheath	mm
ν	ratio of the thermal resistivities of dry and moist soils ($\nu = \rho_d/\rho_w$)	
x_p	argument of a Bessel function used to calculate proximity effect	
x_s	argument of a Bessel function used to calculate skin effect	
y_p	proximity effect factor	} (see 2.1)
y_s	skin effect factor	
α_{20}	temperature coefficient of electrical resistivity at 20 °C, per kelvin	l/K
β	angle between axis of armour wires and axis of cable (see 2.4.2)	
β_1	coefficient used in 2.3.6.1	
γ	angular time delay (see 2.4.2)	
Δ_1	} coefficients used in 2.3.6.1	
Δ_2		
δ	equivalent thickness of armour or reinforcement	mm
$\tan \delta$	loss factor of insulation	
ε	relative permittivity of insulation	
θ	maximum operating temperature of conductor	°C
θ_a	ambient temperature	°C
θ_{ar}	maximum operating temperature of armour	°C
θ_{sc}	maximum operating temperature of cable screen or sheath	°C
θ_x	critical temperature of soil; this is the temperature of the boundary between dry and moist zones	°C
$\Delta\theta$	permissible temperature rise of conductor above ambient temperature	K
$\Delta\theta_x$	critical temperature rise of soil; this is the temperature rise of the boundary between dry and moist zones above the ambient temperature of the soil	K
λ_0	coefficient used in 2.3.6.1	
λ_1, λ_2	ratio of the total losses in metallic sheaths and armour respectively to the total conductor losses (or losses in one sheath or armour to the losses in one conductor)	
λ'_1	ratio of the losses in one sheath caused by circulating currents in the sheath to the losses in one conductor	
λ''_1	ratio of the losses in one sheath caused by eddy currents to the losses in one conductor	
λ'_{1m}	loss factor for the middle cable	} Three cables in flat formation without transposition, with sheaths bonded at both ends
λ'_{11}	loss factor for the outer cable with the greater losses	
λ'_{12}	loss factor for the outer cable with the least losses	

μ	relative magnetic permeability of armour material	
μ_e	longitudinal relative permeability	
μ_t	transverse relative permeability	
ρ	conductor resistivity at 20 °C	$\Omega \cdot m$
ρ_d	thermal resistivity of dry soil	$K.m/W$
ρ_w	thermal resistivity of moist soil	$K.m/W$
ρ_s	sheath resistivity at 20 °C	$\Omega \cdot m$
σ	absorption coefficient of solar radiation for the cable surface	
ω	angular frequency of system ($2\pi f$)	

1.4 Permissible current rating of cables

When the permissible current rating is being calculated under conditions of partial drying out of the soil, it is also necessary to calculate a rating for conditions where drying out of the soil does not occur. The lower of the two ratings shall be used.

1.4.1 Buried cables where drying out of the soil does not occur or cables in air

1.4.1.1 AC cables

The permissible current rating of an a.c. cable can be derived from the expression for the temperature rise above ambient temperature:

$$\Delta\theta = (I^2R + \frac{1}{2} W_d) T_1 + [I^2R (1 + \lambda_1) + W_d] n T_2 + [I^2R (1 + \lambda_1 + \lambda_2) + W_d] n (T_3 + T_4)$$

where

I is the current flowing in one conductor (A);

$\Delta\theta$ is the conductor temperature rise above the ambient temperature (K);

NOTE The ambient temperature is the temperature of the surrounding medium under normal conditions, at a situation in which cables are installed, or are to be installed, including the effect of any local source of heat, but not the increase of temperature in the immediate neighbourhood of the cables due to heat arising therefrom.

R is the alternating current resistance per unit length of the conductor at maximum operating temperature (Ω/m);

W_d is the dielectric loss per unit length for the insulation surrounding the conductor (W/m);

T_1 is the thermal resistance per unit length between one conductor and the sheath (K.m/W);

T_2 is the thermal resistance per unit length of the bedding between sheath and armour (K.m/W);

T_3 is the thermal resistance per unit length of the external serving of the cable (K.m/W);

T_4 is the thermal resistance per unit length between the cable surface and the surrounding medium, as derived from 2.2 of Part 2 (K.m/W);

n is the number of load-carrying conductors in the cable (conductors of equal size and carrying the same load);

λ_1 is the ratio of losses in the metal sheath to total losses in all conductors in that cable;

λ_2 is the ratio of losses in the armouring to total losses in all conductors in that cable.