

**SLOVENSKI STANDARD**  
**SIST EN 60870-6-503:2004****01-maj-2004****Nadomešča:****SIST EN 60870-6-503:2000**

---

**Oprema in sistemi za daljinsko vodenje - 6-503. del: Protokoli daljinskega vodenja, ki so združljivi s standardi ISO in priporočili ITU-T - Storitve in protokol TASE.2 (IEC 60870-6-503:2002)**

Telecontrol equipment and systems -- Part 6-503: Telecontrol protocols compatible with ISO standards and ITU-T recommendations - TASE.2 Services and protocol

**iTeh STANDARD PREVIEW**

Fernwirkrichtungen und -systeme -- Teil 6-503: Fernwirkprotokolle, die mit ISO-Normen und ITU-T-Empfehlungen kompatibel sind - TASE.2-Dienste und -Protokoll

[SIST EN 60870-6-503:2004](#)

Matériels et systèmes de téléconduite -- Partie 6-503: Protocoles de téléconduite compatibles avec les normes ISO et les recommandations de l'UIT-T - Services et protocole TASE.2

**Ta slovenski standard je istoveten z: EN 60870-6-503:2002**

---

**ICS:**

33.200 Daljinsko krmiljenje, daljinske Telecontrol. Telemetering  
meritve (telemetrija)

**SIST EN 60870-6-503:2004****en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 60870-6-503:2004](#)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>

EUROPEAN STANDARD

**EN 60870-6-503**

NORME EUROPÉENNE

EUROPÄISCHE NORM

May 2002

ICS 33.200

Supersedes EN 60870-6-503:1997

English version

**Telecontrol equipment and systems**  
**Part 6-503: Telecontrol protocols compatible with ISO standards**  
**and ITU-T recommendations -**  
**TASE.2 Services and protocol**  
(IEC 60870-6-503:2002)

Matériels et systèmes de téléconduite  
Partie 6-503: Protocoles de téléconduite  
compatibles avec les normes ISO  
et les recommandations de l'UIT-T -  
Services et protocole TASE.2  
(CEI 60870-6-503:2002)

Fernwirkrichtungen und -systeme  
Teil 6-503: Fernwirkprotokolle,  
die mit ISO-Normen und  
ITU-T-Empfehlungen kompatibel sind -  
TASE.2-Dienste und -Protokoll  
(IEC 60870-6-503:2002)

(standards.iteh.ai)

[SIST EN 60870-6-503:2004](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>

This European Standard was approved by CENELEC on 2002-05-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

# CENELEC

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 57/574/FDIS, future edition 2 of IEC 60870-6-503, prepared by IEC TC 57, Power system control and associated communications, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60870-6-503 on 2002-05-01.

This European Standard supersedes EN 60870-6-503:1997.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2003-02-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2005-05-01

Annexes designated "normative" are part of the body of the standard. In this standard, annexes A, B and ZA are normative. Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of the International Standard IEC 60870-6-503:2002 was approved by CENELEC as a European Standard without any modification.

**(standards.iteh.ai)**

[SIST EN 60870-6-503:2004](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>

## Annex ZA (normative)

### Normative references to international publications with their corresponding European publications

This European Standard incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this European Standard only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies (including amendments).

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60870-6-702	1998	Telecontrol equipment and systems Part 6-702: Telecontrol protocols compatible with ISO standards and ITU- T recommendations - Functional profile for providing the TASE.2 application service in end systems	EN 60870-6-702	1998
IEC 60870-6-802	2002	Part 6-802: Telecontrol protocols compatible with ISO standards and ITU- T recommendations - TASE.2 Object models	EN 60870-6-802	2002
ISO/IEC 8073	<sup>1)</sup>	Information technology - Open systems interconnection - Protocol for providing the connection-mode transport service	-	-
ISO/IEC 8208	2000	Information technology - Data communications - X.25 Packet Layer Protocol for Data Terminal Equipment	-	-
ISO/IEC 8473	Series	Information technology - Protocol for providing the connectionless-mode network service	-	-
ISO/IEC 8802-3	2001	Information technology - Telecommunications and information exchange between systems - Local and metropolitan area networks - Specific requirements Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ISO 9506-1	2000	Industrial automation systems - Manufacturing Message Specification Part 1: Service definition	-	-

<sup>1)</sup> Undated reference.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO 9506-2	2000	Part 2: Protocol specification	-	-
ISO/IEC 9542	- <sup>1)</sup>	Information processing systems - Telecommunications and information exchange between systems - End system to intermediate system routing exchange protocol for use in conjunction with the Protocol for providing the connectionless-mode network service (ISO 8473)	-	-
ISO/IEC 10589	1992	Information technology - Telecommunications and information exchange between systems - Intermediate system to intermediate system intra-domain-routing exchange protocol for use in conjunction with the protocol for providing the connectionless-mode network Service (ISO 8473)	-	-
ISO/IEC ISP 10608-1	1992	Information technology - International Standardized Profile TAnnnn - Connection-mode Transport Service over Connectionless-mode Network Service Part 1: General overview and subnetwork-independent requirements	-	-
ISO/IEC ISP 10608-2	1992	Part 2: TA51 profile including subnetwork-dependent requirements for CSMA/CD Local Area Networks (LANs)	-	-
ISO/IEC ISP 10608-5	1992	Part 5: TA1111/TA1121 profiles including subnetwork-dependent requirements for X.25 packet-switched data networks using virtual calls	-	-
ISO/IEC ISP 10613-1	1994	Information technology - International Standardized Profile RA - Relaying the Connectionless-mode Network Service Part 1: Subnetwork-independent requirements	-	-
ISO/IEC ISP 10613-2	1994	Part 2: LAN Subnetwork-dependent, media-independent requirements	-	-
ISO/IEC ISP 10613-3	1994	Part 3: CSMA/CD LAN subnetwork-dependent, media-dependent requirements	-	-
ISO/IEC ISP 10613-5	1994	Part 5: Definition of profile RA51.51, relaying the Connectionless-mode Network Service between CSMA/CD LAN subnetworks	-	-

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC ISP 10613-7	1994	Part 7: PSDN subnetwork-dependent, media-dependent requirements for virtual calls over a permanent access	-	-
ISO/IEC ISP 10613-8	1994	Part 8: Definition of profile RA51.1111, relaying the Connectionless-mode Network Service between CSMA/CD LAN subnetworks and PSDNs using virtual calls over a PSTN leased line permanent access	-	-
ISO/IEC ISP 10613-9	1994	Part 9: Definition of profile RA51.1121, relaying the Connectionless-mode Network Service between CSMA/CD LAN subnetworks and PSDNs using virtual calls over a digital data circuit/CSDN leased line permanent access	-	-
ISO/IEC 8649	- <sup>1)</sup>	Information technology - Open systems interconnection - Service definition for the Association Control Service Element (ACSE)	-	-

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60870-6-503:2004](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 60870-6-503:2004](#)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>



INTERNATIONAL  
STANDARD

IEC  
60870-6-503

Second edition  
2002-04

---

---

**Telecontrol equipment and systems –**

**Part 6-503:**

**Telecontrol protocols compatible with  
ISO standards and ITU-T recommendations –  
TASE.2 Services and protocol**

(standards.iteh.ai)

*Matériels et systèmes de téléconduite –*

*SIST EN 60870-6-503:2004*

[https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004)

*Partie 6-503:*

*Protocoles de téléconduite compatibles avec les  
normes ISO et les recommandations de l'UIT-T –  
Services et protocole TASE.2*

© IEC 2002 — Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland  
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale  
International Electrotechnical Commission  
Международная Электротехническая Комиссия

PRICE CODE

XF

For price, see current catalogue

## CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
<b>1 Scope.....</b>	<b>8</b>
1.1 Control centre.....	8
1.2 Architecture.....	9
1.3 Network Model.....	10
1.4 Relation between TASE.2 and MMS.....	10
<b>2 Normative references.....</b>	<b>11</b>
<b>3 Definitions.....</b>	<b>13</b>
<b>4 Abbreviations.....</b>	<b>15</b>
<b>5 TASE.2 Model.....</b>	<b>15</b>
5.1 Informal TASE.2 Model Description.....	15
5.1.1 Associations.....	17
5.1.2 Bilateral Agreements, Bilateral Tables and Access Control.....	18
5.1.3 Data Value Objects and Services.....	20
5.1.4 Data Set Objects and Services.....	20
5.1.5 Account Objects and Services.....	20
5.1.6 Information Message Object and Services.....	20
5.1.7 Transfer Set Objects and Services.....	21
5.1.8 Common Data Transfer Mechanisms.....	23
5.1.9 Special Transfer Objects and Services.....	24
5.1.10 Device Objects and Services.....	24
5.1.11 Program Objects and Services.....	25
5.1.12 Event Enrollment Objects and Services.....	26
5.1.13 Event Condition Objects and Services.....	26
5.2 Formal TASE.2 Model Description.....	26
5.2.1 General Access Control Requirements.....	29
5.2.2 Association Management.....	29
5.2.3 Bilateral Tables.....	31
5.2.4 List of Access Control Specification.....	32
5.2.5 Data Values.....	33
5.2.6 Data Sets.....	34
5.2.7 Accounts.....	36
5.2.8 Information Messages.....	36
5.2.9 Transfer Sets.....	37
5.2.10 Special Transfer Objects.....	45
5.2.11 Devices.....	46
5.2.12 Programs.....	48
5.2.13 Event Enrollments.....	49
5.2.14 Event Conditions.....	49
<b>6 Mapping of TASE.2 Object Models onto MMS Object Models.....</b>	<b>50</b>
6.1 Object Modelling Notation (Informative).....	50
6.2 The Virtual Control Centre (VCC).....	51
6.2.1 TASE.2 Domain Mapping.....	51
6.2.2 TASE.2 Control Centre Mapping.....	52
6.2.3 OSI Application Processes, Application Entities and Presentation Addresses.....	52

6.3	Association Object Model Mapping.....	52
6.4	Bilateral Table Object Model Mapping .....	53
6.5	Data Value Object Model Mapping .....	55
6.6	Data Set Object Model Mapping .....	55
6.7	Account Object Model Mapping.....	56
6.8	Information Message Object Model Mapping .....	56
6.9	Transfer Set Object Model Mapping .....	57
6.9.1	Data Set Transfer Set Object Model Mapping .....	57
6.9.2	Time Series Transfer Set Object Model Mapping .....	59
6.9.3	Transfer Account Transfer Set Object Model Mapping .....	60
6.9.4	Information Message Transfer Set Object Model Mapping .....	61
6.10	Next Transfer Set Object Model Mapping .....	61
6.11	Transfer Set Name Object Model Mapping .....	62
6.12	Conditions Object Model Mapping .....	62
6.13	Event Code Object Model Mapping .....	62
6.14	Transfer Set Time Stamp Object Model Mapping.....	62
6.15	Device Object Model Mapping.....	63
6.16	Program Object Model Mapping .....	63
6.17	Event Enrollment Object Model Mapping .....	64
6.18	Event Condition Object Model Mapping .....	64
7	Mapping of TASE.2 Operations and Actions onto MMS Services.....	65
7.1	Use of MMS Services .....	66
7.1.1	Association Management Mapping to MMS .....	67
7.1.2	Data Value Operations Mapping to MMS .....	70
7.1.3	Data Set Operations Mapping to MMS.....	73
7.1.4	Transfer Set Operations and Actions Mapping to MMS .....	80
7.1.5	Account Operations and Actions Mapping .....	92
7.1.6	Device Operations and Actions Mapping to MMS.....	93
7.1.7	Program Operations Mapping to MMS .....	99
7.1.8	Event Enrollment Operations Mapping to MMS .....	104
7.1.9	Event Condition Actions Mapping onto MMS.....	106
7.1.10	Summary of TASE.2 Operations.....	107
8	Standardized Application-specific Objects .....	109
8.1	Named Type Objects .....	109
8.1.1	Visible-String-32 Type.....	109
8.1.2	MMS ObjectName .....	109
8.1.3	Time Stamp Types .....	110
8.1.4	TimeStampExtended Type .....	110
8.1.5	Time Interval Types .....	111
8.1.6	TransferSet Types .....	111
8.1.7	Conditions Types .....	113
8.1.8	SupportedFeatures Type.....	114
8.1.9	TASE.2Version Type.....	114
8.2	Named Variable Objects .....	115
8.2.1	"Supported_Features".....	115
8.2.2	"Bilateral_Table_ID" .....	115
8.2.3	"TASE.2_Version" .....	115
8.2.4	Data Value Objects .....	115
8.2.5	Transfer Set Objects.....	116

8.2.6	"Next_DSTransfer_Set".....	116
8.2.7	"Next_TSTransfer_Set".....	116
8.2.8	"Transfer_Set_Name".....	116
8.2.9	"TA_Transfer_Set".....	116
8.2.10	"IM_Transfer_Set".....	116
8.2.11	"DSConditions_Detected".....	117
8.2.12	"TSConditions_Detected".....	117
8.2.13	"TAConditions_Detected".....	117
8.2.14	"Event_Code_Detected".....	117
8.2.15	"Transfer_Set_Time_Stamp".....	117
8.2.16	"Transfer_Report_ACK".....	117
8.2.17	"Transfer_Report_NACK".....	118
8.3	Named Variable List Objects.....	118
8.4	Information Message Objects.....	118
8.5	Event Condition Objects.....	118
9	Conformance.....	119
9.1	Allowable Subsets.....	119
9.2	PICS.....	120
9.3	MMS Services Required.....	124
Annex A (normative) TASE.2 Operations and Actions Summary.....		125
Annex B (normative) Quality of Service (QOS), Routing and Priority.....		127
Figure 1	– Protocol relationships.....	9
Figure 2	– Router-based WAN.....	10
Figure 3	– Mesh network.....	10
Figure 4	– Informal TASE.2 Model.....	17
Figure 5	– Transfer Reporting Mechanism.....	22
Figure 6	– Relationship between TASE.2 and Real Control Centres.....	27
Figure 7	– TASE.2 server components.....	66
Figure 8	– TASE.2 Server Association Control Components.....	67
Figure 9	– Data Value operations.....	70
Figure 10	– Sequence of Get Data Value.....	71
Figure 11	– Data Set operations.....	74
Figure 12	– Sequence of Create Data Set.....	76
Figure 13	– Sequence of Delete Data Set.....	77
Figure 14	– Transfer Set services.....	81
Figure 15	– Sequence of Transfer Set operations and actions.....	90
Figure 16	– Device operations.....	94
Figure 17	– Sequence of Device Control.....	95
Figure 18	– Server Program Components.....	100
Figure 19	– Sequence of Program Invocation operations.....	104
Table 1 – Scope of the object models in the VCC.....		28
Table 2 – Summary of TASE.2 Operations.....		107

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 6-503: Telecontrol protocols compatible with  
ISO standards and ITU-T recommendations –  
TASE.2 Services and protocol**

## FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides, and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) Attention is drawn to the possibility that some of the elements of this International Standard may be the subject of patent rights. The IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60870-6-503 has been prepared by IEC technical committee 57: Power system control and associated communications.

This second edition cancels and replaces the first edition published in 1997 and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/574/FDIS	57/582/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Annexes A and B form an integral part of this standard.

The committee has decided that the contents of this publication will remain unchanged until 2004. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

## **iTeh STANDARD PREVIEW (standards.iteh.ai)**

[SIST EN 60870-6-503:2004](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004)

<https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11fe2943a36/sist-en-60870-6-503-2004>

## INTRODUCTION

The Telecontrol Application Service Element (TASE.2) protocol (also known as Inter-Control Centre Communications Protocol, ICCP) allows for data exchange over Wide Area Networks (WANs) between a utility control centre and other control centres, other utilities, power pools, regional control centres, and Non-Utility Generators. Data exchange information consists of real-time and historical power system monitoring and control data, including measured values, scheduling data, energy accounting data, and operator messages. This data exchange occurs between one control centre's Supervisory Control And Data Acquisition/Energy Management System/Distribution Management System (SCADA/EMS/DMS) host and another centre's host, often through one or more intervening communications processors.

This part of IEC 60870 defines a mechanism for exchanging time-critical data between control centres. In addition, it provides support for device control, general messaging and control of programs at a remote control centre. It defines a standardized method of using the ISO 9506 Manufacturing Message Specification (MMS) services to implement the exchange of data. The definition of TASE.2 consists of three documents. This part of IEC 60870 defines the TASE.2 application modelling and service definitions. IEC 60870-6-702 defines the application profile for use with TASE.2. IEC 60870-6-802 defines a set of standardized object definitions to be supported.

The TASE.2 describes real control centres with respect to their external visible data and behaviour using an object oriented approach. The objects are abstract in nature and may be used in a wide variety of applications. The use of TASE.2 goes far beyond the application in the control centre to control centre communications. This standard must be understood as a tool box for any application domain with comparable requirements. i.e. the TASE.2 may be applied in areas like substation automation, power plants, factory automation, chemical plants, or others which have comparable requirements. It provides a generic solution for advanced Information and Communication Technology.

[SIST EN 60870-6-503:2004](https://standards.iteh.ai/catalog/standards/sist/6166d18d-8495-45a8-a43d-b11e2945a56/sist-en-60870-6-503-2004)

The TASE.2 version number for this standard is 2001-08. See 8.2.3 for more details.