

**SLOVENSKI
STANDARD**

**SIST EN 60598-
1:2000/A11:2003**

marec 2003

Luminaires - Part 1: General requirements and tests - Amendment A11 (IEC 60598-1:1999, modified)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60598-1:2000/A11:2004

<https://standards.iteh.ai/catalog/standards/sist/e80e3a1a-a02c-4e1c-a391-c3ac4d8e6d76/sist-en-60598-1-2000-a11-2004>

ICS 29.140.40

Referenčna številka
SIST EN 60598-1:2000/A11:2003(en)

iTeh STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60598-1:2000/A11:2004

<https://standards.iteh.ai/catalog/standards/sist/e80e3a1a-a02c-4e1c-a391-c3ac4d8c6d76/sist-en-60598-1-2000-a11-2004>

EUROPEAN STANDARD

EN 60598-1/A11

NORME EUROPÉENNE

EUROPÄISCHE NORM

June 2002

ICS 29.140.40

English version

Luminaires Part 1: General requirements and tests

Luminaires

Partie 1: Prescriptions générales et essais

Leuchten

Teil 1: Allgemeine Anforderungen
und Prüfungen

iTeh STANDARD PREVIEW

This amendment A11 modifies the European Standard EN 60598-1:1993; it was approved by CENELEC on 2002-06-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

[SIST EN 60598-1:2000/A11:2004](https://standards.iteh.ai/SIST/EN-60598-1-2000/A11-2004)

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This amendment to the European Standard EN 60598-1:1993 was prepared by the Technical Committee CENELEC TC 34Z, Luminaires and associated equipment.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A11 to EN 60598-1:1993 on 2002-06-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2002-12-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2002-12-01

Amendment A11 to EN 60598-1:1993

3.3 Additional information

Add new subclause:

3.3.101 Where the terminal block is not supplied with the luminaire, the packaging needs to contain the following wording:

"Terminal block not included. Installation may require advice from a qualified person."

5.2.1 **Replace** the indent relating to "fixed luminaires" by: 1:2004

<https://standards.iteh.ai/catalog/standards/sist/e80e3a1a-a02c-4e1c-a391-c7e1a7703036/en-60598-1-2004>

Fixed luminaires terminals; plugs for engagement with socket-outlets; non-detachable flexible cables or cords; adapters for engagement with supply tracks; appliance inlets; connecting leads (tails): account shall be taken of national installation rules/practice when deciding whether to supply a connection device or not. Where the luminaire is delivered with connecting leads (tails) and without a means of connection to the supply, the manufacturer of the luminaire shall specify which terminal block may be used which shall conform to EN 60998-2-1 or EN 60998-2-2; either the terminal block to be used shall be specified or the following shall be defined:

- the type of terminal (screw/screwless);
- number of terminals;
- rated voltage;
- rated connecting capacity;
- any necessary preparation of the ends of conductors;
- any fixing method.

The requirements of 4.6, 4.7.1, 4.7.2, 4.10.1, 11.2, 12 and 13.2 shall be applied.