



SLOVENSKI STANDARD
SIST HD 603 S1:1998/A3:2007
01-junij-2007

Distribucijski kabli za naznačeno napetost 0,6/1 kV

Distribution cables of rated voltage 0,6/1 kV

Energieverteilungskabel mit Nennspannungen 0,6/1 kV

Câbles de distribution de tension nominale 0,6/1 kV

Ta slovenski standard je istoveten z: HD 603 S1:1994/A3:2007

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

ICS:

29.060.20 Kabli Cables

SIST HD 603 S1:1998/A3:2007 en

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

HARMONIZATION DOCUMENT
DOCUMENT D'HARMONISATION
HARMONISIERUNGSDOKUMENT

HD 603 S1/A3

April 2007

ICS 29.060.20

English version

Distribution cables of rated voltage 0,6/1 kV

Câbles de distribution
de tension nominale 0,6/1 kV

Energieverteilungskabel
mit Nennspannungen 0,6/1 kV

This amendment A3 modifies the Harmonization Document HD 603 S1:1994; it was approved by CENELEC on 2006-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this amendment at national level.

Up-to-date lists and bibliographical references concerning such national implementations may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in one official version (English).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This amendment to the Harmonization Document HD 603 S1:1994 has been prepared by WG9 of Technical Committee CENELEC TC 20, Electric cables.

Part 1 has been revised, especially to include a Guide to use and selection of cables. A list of additions and amendments to the particular sections of Parts 3 to 8 is given in this Part 0.

Users of HD 603 should note that, in the particular sections, cross-references have only been updated where the complete section has been re-issued. This Part 0 of HD 603 contains a list of relevant changes to cross-references which should be consulted in conjunction with the particular section. National standards implementing one or more particular sections of HD 603 may update cross-references in advance of changes to the published version of the HD.

The text of the draft, including a correction circulated as prAA, was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A3 to HD 603 S1:1994 on 2006-11-01.

The following dates were fixed:

- latest date by which the existence of the amendment has to be announced at national level (doa) 2007-05-01
- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2007-11-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2009-11-01

By decision of the Technical Board (D81/139 extended by D104/118 & D114/076) this HD exists only in English.

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

CONTENTS

(HD 603 S1:1994 with A1, A2 and A3)

Part 1	^{1) 5) 11)}	GENERAL REQUIREMENTS
Part 3		PVC INSULATED CABLES - UNARMoured
	3A	^{1) 11)} Cables with (type 3A-1) and without (type 3A-2) concentric conductor
	3B	¹¹⁾ Cables without concentric conductor (type 3B-1)
	3C	Cables (type 3C-1) with concentric conductor, PVC sheath
	3D	Cables (type 3D-1) without concentric conductor, PE sheath
	3E	Cables (type 3E-1) without concentric conductor, PVC sheath
	3F	^{1) 4) 11)} Cables with (type 3F-1) and without (type 3F-2) concentric conductor
	3G	^{1) 5) 11)} Cables with (type 3G-1) and without (type 3G-2) concentric conductor
	3H	Cables with (type 3H-1) and without (type 3H-2) concentric conductor
	3I	^{1) 5) 10)} Cables with (type 3I-1) and without (types 3I-2 and 3I-3) concentric conductor
	3J	^{1) 11)} Cables with concentric conductor (type 3J-1)
	3K	Withdrawn
	3L	^{1) 5) 11)} Cables with concentric conductor (type 3L-1)
	3M	^{2) 11)} Unarmoured cables (type 3M-1)
	3N	^{5) 10)} Unarmoured cables (type 3N)
	3O	¹¹⁾ Cables without (type 3O-1) concentric conductor
Part 4		PVC INSULATED CABLES - ARMoured
	4A	^{1) 11)} Cables with concentric conductor (screen) (type 4A)
	4B	^{1) 5) 10)} Cables with braided (type 4B-1) or helically applied (type 4B-2) armour
	4C	^{2) 11)} Cables without concentric conductor (type 4C)
	4D	^{1) 11)} Armoured cables without (type 4D-1) concentric conductor
	4E	¹¹⁾ Armoured cables with (type 4E-1) or without (type 4E-2) concentric copper conductor or screen
		https://standards.sist.org/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007
Part 5		XLPE INSULATED CABLES - UNARMoured
	5A	¹¹⁾ Cables without concentric conductor (type 5A)
	5B	Cables (type 5B) without concentric conductor, PE sheath
	5C	Cables (type 5C) without concentric conductor, PVC sheath
	5D	^{1) 4) 11)} Cables with and without concentric conductor (types 5D-1 and 5D-2)
	5E	^{1) 11)} Cables (for energy boards) with concentric conductor (type 5E)
	5F	^{1) 11)} Cables with concentric screen and uninsulated neutral (type 5F)
	5G	^{1) 5) 11)} Cables with (type 5G-1) and without (type 5G-2) concentric conductor
	5H	Cables without concentric conductor (type 5H)
	5I	^{1) 5) 10)} Cables without concentric conductor (type 5I)
	5J	^{1) 11)} Cables with concentric conductor (type 5J)
	5K	^{1) 11)} Cables with concentric screen (type 5K)
	5L	^{1) 11)} Cables with concentric screen (type 5L)
	5M	^{1) 11)} Cables without concentric conductor (type 5M)
	5N	^{1) 9)} Cables without concentric conductor (type 5N)
	5O	^{5) 11)} Cables without concentric conductor, PVC sheath (type 5O)
	5P	^{1) 5) 11)} Cables with concentric conductor, PVC or PE sheath (type 5P-1 and 5P-2)
	5Q	Withdrawn
	5R	^{1) 5) 10)} CNE cables with concentric waveform neutral/earth conductor (type 5R)
	5S	^{1) 5) 10)} Service cables with concentric conductor (type 5S)
	5T	^{1) 11)} Cables with (type 5T-1) and without (type 5T-2) concentric conductor
	5U	¹¹⁾ Cables with (type 5TU1) concentric waveform neutral conductor
	5V	^{3) 11)} Unarmoured cables (type 5V)
	5W	^{3) 13)} Cables with concentric conductor (type 5W)
	5X	¹²⁾ Cables without concentric conductor (type 5X)

Part 6 XLPE INSULATED CABLES - ARMoured

6A ^{1) 5) 10)}	Cables with braided (type 6A-1) or helically applied (type 6A-2) armour
6B	Withdrawn
6C ^{1) 11)}	Armoured cables with (type 6C-1) and without (type 6C-2) concentric conductor
6D ^{3) 11)}	Steel tape armoured cables (type 6D)
6E ¹¹⁾	Cables without concentric conductor (screen) (type 6E)

Part 7 EPR INSULATED CABLES - UNARMoured

7A ^{5) 9)}	Cables with and without concentric conductor (type 7A)
7B ^{5) 9)}	Pre-assembled cables without concentric conductor (type 7B)
7C ^{1) 13)}	Cables without concentric conductor (type 7C)
7D	Withdrawn
7E ^{1) 11)}	Cables with (type 7E-1) and without (type 7E-2) concentric conductor

Part 8 EPR INSULATED CABLES - ARMoured

8A	Withdrawn
8B ^{1) 11)}	Armoured cables with (type 8B-1) and without (type 8B-2) concentric conductor

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

- 1) Amendment A1 introduces some changes to the text.
- 2) Amendment A1 completely revises the particular section.
- 3) New section introduced by amendment A1.
- 4) Amendment A2 introduces some changes to the text.
- 5) Amendment A2 completely revises the particular section.
- 6) Amendment A1 withdraws the section.
- 7) Amendment A2 withdraws the section.
- 8) Amendment A3 introduces some changes to the text.
- 9) Amendment A3 introduces new Guide to use (Annex A).
- 10) Amendment A3 introduces some changes to the text and new Guide to use (Annex A).
- 11) Amendment A3 completely revises the particular section and introduces new Guide to use (Annex A).
- 12) New section introduced by amendment A3.
- 13) Amendment A3 withdraws the section.

List of updated cross-references

Original Ref	Original title	New Ref	New title
HD 186	Marking by inscription for the identification of cores of electric cables having more than five cores	EN 50334	Marking by inscription for the identification of cores of electric cables
HD 383	Conductors of insulated cables	EN 60228	Conductors of insulated cables
HD 405 (series)	Test on electric cables under fire condition	EN 50265 (series)	Common test methods for cables under fire conditions – Test for resistance to vertical flame propagation for a single insulated conductor or cable.
HD 405.1	Tests on electric cables under fire conditions – Part 1: Test on a single vertical insulated wire or cable	EN 50265-2-1	Common test methods for cables under fire conditions – Test for resistance to vertical flame propagation for a single insulated conductor or cable – Part 2-1: Procedure – 1 kW pre-mixed flame
HD 405.3	Tests on electric cables under fire conditions – Part 3: Tests on bunched wires or cables	EN 50266 (series)	Common test methods for cables under fire conditions – Test for vertical flame spread of vertically-mounted bunched wires or cables
HD 505 (series)	Common test methods for insulating and sheathing materials of electric cables	EN 60811 (series)	Insulating and sheathing materials of electric cables – Common test methods
HD 606 (series)	Measurement of smoke density of electric cables burning under defined conditions	EN 50268 (series)	Common test methods for cables under fire conditions – Measurement of smoke density of cables burning under defined conditions
EN 50265-2-1	Common test methods for cables under fire conditions – Test for resistance to vertical flame propagation for a single insulated conductor or cable Part 2-1: Procedures – 1 kW pre-mixed flame	EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions Part 1-2: Test for vertical flame propagation for a single insulated wire or cable - Procedure for 1 kW pre-mixed flame
EN 50268 (series)	Common test methods for cables under fire conditions – Test for vertical flame spread of vertically-mounted bunched wires or cables	EN 61034 (series)	Measurement of smoke density of cables burning under defined conditions
IEC 183	Guide to the selection of high-voltage cables	IEC 60183	Guide of the selection of high-voltage cables
IEC 60502	Extruded solid dielectric insulated power cables for rated voltages from 1 kV to 30 kV	IEC 60502-1	Power cables with extruded insulation and their accessories for rated voltages from 1 kV ($U_m = 1,2$ kV) up to 30 kV ($U_m = 36$ kV) – Part 1: Cables for rated voltages of 1 kV ($U_m = 1,2$ kV) and 3 kV ($U_m = 3,6$ kV)
IEC 754-1	Tests on gases evolved during combustion of materials from cables – Part 1: Determination of the amount of halogen acid gas	EN 50267-2-1	Common test methods for cables under fire conditions – Tests on gases evolved during combustion of materials from cables – Part 2-1: Procedures – Determination of the amount of halogen acid gas

BLANK PAGE

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

PART 1: GENERAL REQUIREMENTS

Replace the complete part by the following:

**iTeh STANDARD PREVIEW
(standards.iteh.ai)**

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)
<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

HD 603 S1:1994/A3:2007

DISTRIBUTION CABLES OF RATED VOLTAGE 0,6/1 KV

PART 1: GENERAL REQUIREMENTS

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

CONTENTS

1	General.....	4
	1.1 Scope	4
	1.2 Object	4
2	Definitions.....	4
	2.1 Definitions concerning the insulating and sheathing compounds	4
	2.2 Definitions relating to the tests	5
	2.3 Rated voltage.....	6
3	Marking.....	6
	3.1 Indication of origin	6
	3.2 Additional marking	7
	3.3 Durability.....	7
	3.4 Legibility.....	7
	3.5 Common marking.....	7
	3.6 Use of the name CENELEC.....	7
4	Core identification	7
5	General requirements for the construction of cables	8
	5.1 Conductors	8
	5.2 Insulation	8
	5.3 Assembly of cores	9
	5.4 Fillers and tapes.....	9
	5.5 Inner covering (bedding).....	9
	5.6 Inner sheath.....	10
	5.7 Metallic coverings	10
	5.8 Oversheath	10
6	Tests on completed cables	11
7	Sealing and packing	11
8	Current ratings.....	11
9	Guide to use and selection of cables	11
Annex A (informative)	Guide to use and selection of cables	37
	A.1 Object	37
	A.2 Recommendations for selection of cables	37
	A.3 Recommendation for storage and transport	38
	A.4 Recommendation for cable installation	40
	A.5 Environment.....	44

REFERENCES

References are made in this Part 1 to other parts of HD 603 and to other Harmonization Documents as follows:

EN 50334	Marking by inscription for the identification of cores of electric cables
EN 60228	Conductors of insulated cables (IEC 60228)
EN 60332-1-2	Tests on electric and optical fibre cables under fire conditions - Part 1-2: Test for vertical flame propagation for a single insulated wire or cable – Procedure for 1 kW pre-mixed flame (IEC 60332-1-2)
EN 60811 (series)	Insulating and sheathing materials of electric and optical cables – Common test methods (IEC 60811 series)
HD 308	Identification of cores in cables and flexible cores
HD 605	Electric cables – Additional test methods
IEC 60287 (series)	Electric cables – Calculation of the current rating

In all cases reference to another HD or International Standard implies the latest edition of that document.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST HD 603 S1:1998/A3:2007](https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007)

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

1 General

1.1 Scope

HD 603 applies to cables of rated voltage $U_0/U = 0,6/1$ kV used in underground power distribution systems mainly for public distribution, of nominal voltage not exceeding 0,6/1 kV a.c.

This part (Part 1) specifies the general requirements applicable to these cables, unless otherwise specified in the particular sections of this HD.

Test methods are specified in HD 605 and in EN 60228, EN 60332-1-2 and EN 60811.

The particular types of cables are specified in Parts 3 to 8.

1.2 Object

The objects of this Harmonization Document are:

- to standardise cables that are safe and reliable when properly used, in relation to the technical requirements of the system of which they form a part;
- to state the characteristics and manufacturing requirements which have a direct or indirect bearing on safety,
- and to specify methods for checking conformity with those requirements.

2 Definitions

2.1 Definitions concerning the insulating and sheathing compounds

2.1.1 Insulating and sheathing compounds

The types of insulating and sheathing compounds covered by this HD are listed below, together with their abbreviated designations:

iTeh STANDARD PREVIEW
(standards.iteh.ai)
SIST HD 603 S1:1998/A3:2007
<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

Table 2.1.1 – Insulating and sheathing compounds

	Insulating and sheathing compounds	See:
Insulation	a) <i>Thermoplastic:</i> Insulating compounds based on: - polyvinyl chloride or copolymers (PVC) - polyolefin (PO)	Table 1 Table 4C
	b) <i>Cross-linked:</i> Insulating compounds based on: - cross-linked polyethylene (XLPE) - ethylene propylene rubber (EPR) - hard ethylene propylene rubber (HEPR)	Table 2A Table 2B Table 2C
Sheathing	a) <i>Elastomeric</i> sheathing compound based on: - Polychloroprene (PCP) - Chlorosulfonated polyethylene (CSP) or similar polymer	Table 3
	b) <i>Thermoplastic:</i> sheathing compounds based on: - polyvinyl chloride (PVC) - polyethylene (PE) - polyolefin (PO)	Table 4A Table 4B Table 4C

SIST HD 603 S1:1998/A3:2007

<https://standards.iteh.ai/catalog/standards/sist/583d09be-dd1e-4fa1-9f8e-11710f8498a7/sist-hd-603-s1-1998-a3-2007>

2.1.2 Type of compound

The category in which a compound is placed according to its properties is determined by specific tests. The type designation is not directly related to the composition of the compound.

2.2 Definitions relating to the tests

NOTE Tests classified as sample (S) or routine (R) may be required as part of any type approval schemes.

2.2.1 Type tests (Symbol T)

Tests required to be made before supplying a type of cable covered by this HD on a general commercial basis in order to demonstrate satisfactory performance characteristics to meet the intended application. These tests are of such a nature that, after they have been made, they need not be repeated unless changes are made in the cable material, design or type of manufacturing process which might change the performance characteristics.

2.2.2 Sample tests (Symbol S)

Tests made on samples of completed cable, or components taken from a completed cable adequate to verify that the finished product meets the design specifications.

2.2.3 Routine tests (Symbol R)

Tests made on all production cable lengths to demonstrate compliance with requirements.

2.2.4 Tests after installation

Test intended to demonstrate the integrity of the cable and its accessories as installed.