

TECHNICAL SPECIFICATION

IEC TS 62351-6

First edition
2007-06

**Power systems management and
associated information exchange –
Data and communications security –**

**Part 6:
Security for IEC 61850**

(<https://standards.iteh.ai>)
Document Preview

IEC TS 62351-6:2007

<https://standards.iteh.ai/catalog/standards/iec/2/487b2ee-c5af-4636-be9d-1b48c725f0c9/iec-ts-62351-6-2007>



Reference number
IEC/TS 62351-6:2007(E)



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

IEC TS C 351-6:2007

<https://standards.iec.ch/standards/iec/2487b2ee-c5af-4636-be9d-1b48c725f0c9/iec-ts-62351-6-2007>

TECHNICAL SPECIFICATION

IEC TS 62351-6

First edition
2007-06

Power systems management and associated information exchange – Data and communications security –

Part 6: Security for IEC 61850

(<https://standards.iteh.ai>)
Document Preview

IEC TS 62351-6:2007

<https://standards.iteh.ai/catalog/standards/iec/2/487b2ee-c5af-4636-be9d-1b48c725f0c9/iec-ts-62351-6-2007>



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CONTENTS

FOREWORD.....	3
1 Scope and object.....	5
1.1 Scope.....	5
1.2 Object	5
2 Normative references	5
3 Definitions	6
4 Security issues addressed by this specification	6
4.1 Operational issues affecting choice of security options	6
4.2 Security threats countered.....	7
4.3 Attack methods countered	7
5 Correlation of IEC 61850 parts and IEC 62351 parts	7
5.1 IEC 61850 security for profiles using ISO 9506 (MMS)	7
5.1.1 General	7
5.1.2 Control centre to substation.....	7
5.1.3 Substation communications	7
5.2 IEC 61850 security for profiles using VLAN IDs	8
6 IEC 61850 security for SNTP.....	8
7 IEC 61850 security for profiles using VLAN technologies	8
7.1 Overview of VLAN usage and IEC 61850 (informative)	8
7.2 Extended PDU.....	8
7.2.1 General format of extended PDU.....	8
7.2.2 Format of extension octets	9
7.2.3 Substation configuration language.....	12
8 Conformance.....	13
8.1 General conformance	13
8.2 Conformance for implementations claiming ISO 9506 profile security	14
8.3 Conformance for implementations claiming VLAN profile security.....	14
8.4 Conformance for implementations claiming SNTP profile security.....	15
Bibliography.....	16
Figure 1 – General format of extended PDU.....	8
Figure 2 – SCL extensions for certificates.....	12
Figure 3 – Extension to AccessPoint SCL definition	13
Table 1 – Scope of application to standards.....	5
Table 2 – Extract from IEC 61850-9-2 (informative)	11
Table 3 – Conformance table	14
Table 4 – PICS for ISO 9506 profile	14
Table 5 – PICS for VLAN profiles	14
Table 6 – PICS for SNTP profiles.....	15

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**POWER SYSTEMS MANAGEMENT AND ASSOCIATED
INFORMATION EXCHANGE –
DATA AND COMMUNICATIONS SECURITY –****Part 6: Security for IEC 61850**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

The main task of IEC technical committees is to prepare International Standards. In exceptional circumstances, a technical committee may propose the publication of a technical specification when

- the required support cannot be obtained for the publication of an International Standard, despite repeated efforts, or
- the subject is still under technical development or where, for any other reason, there is the future but no immediate possibility of an agreement on an International Standard.

Technical specifications are subject to review within three years of publication to decide whether they can be transformed into International Standards.

IEC 62351-6, which is a technical specification, has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this technical specification is based on the following documents:

Enquiry draft	Report on voting
57/805/DTS	57/859/RVC

Full information on the voting for the approval of this technical specification can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62351 series, published under the general title *Power systems management and associated information exchange – Data and communications security*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- transformed into an International standard,
- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

Withdrawing

POWER SYSTEMS MANAGEMENT AND ASSOCIATED INFORMATION EXCHANGE – DATA AND COMMUNICATIONS SECURITY –

Part 6: Security for IEC 61850

1 Scope and object

1.1 Scope

This part of IEC 62351 specifies messages, procedures, and algorithms for securing the operation of all protocols based on or derived from the standard IEC 61850. This specification applies to at least those protocols listed in Table 1.

Table 1 – Scope of application to standards

Number	Name
IEC 61850-8-1	Communication networks and systems in substations – Part 8-1: Specific Communication Service Mapping (SCSM) – Mappings to MMS (ISO/IEC 9506-1 and ISO/IEC 9506-2) and to ISO/IEC 8802-3
IEC 61850-9-2	Communication networks and systems in substations – Part 9-2: Specific Communication Service Mapping (SCSM) – Sampled values over ISO/IEC 8802-3
IEC 61850-6	Communication networks and systems in substations – Part 6: Configuration description language for communication in electrical substations related to IEDs

1.2 Object

The initial audience for this specification is intended to be the members of the working groups developing or making use of the protocols listed in Table 1. For the measures described in this specification to take effect, they must be accepted and referenced by the specifications for the protocols themselves. This document is written to enable that process.

The subsequent audience for this specification is intended to be the developers of products that implement these protocols.

Portions of this specification may also be of use to managers and executives in order to understand the purpose and requirements of the work.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850 (all parts), *Communication networks and systems in substations*

IEC 61850-6, *Communication networks and systems in substations – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-8-1, *Communication networks and systems in substations – Part 8-1: Specific Communication Service Mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-9-1, *Communication networks and systems in substations – Part 9-1: Specific Communication Service Mapping (SCSM) – Sampled values over serial unidirectional multidrop point to point link*

IEC 61850-9-2, *Communication networks and systems in substations – Part 9-2: Specific Communication Service Mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

IEC 62351-1, *Power systems management and associated information exchange – Data and communications security – Part 1: Communication network and system security – Introduction to security issues*

IEC 62351-2, *Power systems management and associated information exchange – Data and communications security – Part 2: Glossary of terms*

IEC 62351-4, *Power systems management and associated information exchange – Data and communications security – Part 4: Profiles including MMS*

ISO 9506 (all parts), *Industrial automation systems – Manufacturing Message Specification*

ISO/IEC 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO/IEC 13239, *Information technology – Telecommunications and information exchange between systems – High-level data link control (HDLC) procedures*

IEEE Std. 802.1Q-2003, *Virtual Bridged Local Area Networks*

RFC 2030, *Simple Network Time Protocol (SNTP) Version 4 for IPv4, IPv6 and OSI*

RFC 2313, *PKCS #1: RSA Encryption Version 1.5*

RFC 3447, *Public-Key Cryptography Standards (PKCS) #1: RSA Cryptography Specifications Version 2.1*

RFC 4634, *US Secure Hash Algorithms (SHA and HMAC-SHA)*

3 Definitions

For the purposes of this document, the terms and definitions contained in IEC 62351-2 apply.

4 Security issues addressed by this specification

4.1 Operational issues affecting choice of security options

For applications using GOOSE and IEC 61850-9-2 and requiring 4 ms response times, multicast configurations and low CPU overhead, encryption is not recommended. Instead, the communication path selection process (e.g. the fact that GOOSE and SMV are supposed to be restricted to a logical substation LAN) shall be used to provide confidentiality for information exchanges. However, this specification does define a mechanism for allowing confidentiality for applications where the 4 ms delivery criterion is not a concern.

NOTE The actual performance characteristics of an implementation claiming conformance to this technical specification is outside the scope of this specification.

With the exception of confidentiality, this specification sets forth a mechanism that allows co-existence of secure and non-secure PDUs.

4.2 Security threats countered

See IEC 62351-1 for a discussion of security threats and attack methods.

If encryption is not employed, then the specific threats countered in this part include:

- unauthorized modification of information through message level authentication of the messages.

If encryption is employed, then the specific threats countered in this part include:

- unauthorized access to information through message level authentication and encryption of the messages;
- unauthorized modification (tampering) or theft of information through message level authentication and encryption of the messages.

4.3 Attack methods countered

The following security attack methods are intended to be countered through the appropriate implementation of the specification/recommendations found within this document:

- man-in-the-middle: this threat will be countered through the use of a Message Authentication Code mechanism specified within this document;
- tamper detection/message integrity: These threats will be countered through the algorithm used to create the authentication mechanism as specified within this document;
- replay: this threat will be countered through the use of specialized processing state machines specified within IEC 62351-4 and this document.

5 Correlation of IEC 61850 parts and IEC 62351 parts

5.1 IEC 61850 security for profiles using ISO 9506 (MMS)

5.1.1 General

IEC 61850 implementations claiming conformance to this specification and declaring support for the IEC 61850-8-1 profile utilizing TCP/IP and ISO 9506 (MMS) shall implement Clauses 5 and 6 of IEC 62351-4. In addition to the IEC 62351-4 specification, extensions to IEC 61850-6 (the Substation Configuration Language) shall be supported as prescribed in 7.2.3.

IEC 61850-8-1 specifies the use of MMS within a substation. However, the scope of this specification provides security specifications for use within the substation and external to the substation (e.g. Control Centre to Substation).

5.1.2 Control centre to substation

The IEC 62351-4 standard shall be used without any other additions.

5.1.3 Substation communications

The following cipher suite shall be supported in addition to those specified in IEC 62351-4.

TLS_DH_RSA_WITH_AES_128_SHA

NOTE This additional cipher suite is suggested in order to allow less CPU utilization when the communication environment is within a substation.

5.2 IEC 61850 security for profiles using VLAN IDs

For the IEC 61850 profiles specified that make use of VLAN IDs (e.g. IEC 61850-8-1 GOOSE, IEC 61850-9-1, and IEC 61850-9-2) profile security shall be provided as specified in Clause 7.

6 IEC 61850 security for SNTP

RFC 2030, including mandatory use of the authentication algorithms, shall be used.


7 IEC 61850 security for profiles using VLAN technologies

7.1 Overview of VLAN usage and IEC 61850 (informative)

This specification extends the normal IEC 61850 GOOSE and SMV PDUs. The outline of a PDU for GSE Management and GOOSE is given in Annex C of IEC 61850-8-1.

7.2 Extended PDU

7.2.1 General format of extended PDU



IEC 1053/07

Figure 1 – General format of extended PDU

Figure 1 depicts the fact that the Reserved1 and Reserved2 fields are to be used for implementations claiming conformance to this specification in regards to GOOSE and SMV. This specification specifies that the:

- **Reserved1 field** shall be used to specify the number of octets conveyed by the extension octets. This value shall be contained in the first octet of the Reserved1 field. The valid range of values is zero(0) through 255. A value of zero(0) shall indicate that no extension octets are present.

The second octet of the Reserved1 field shall be reserved for future use;