

INTERNATIONAL
STANDARD

IEC
CEI

NORME
INTERNATIONALE

60364-7-709

Second edition
Deuxième édition
2007-05

Low-voltage electrical installations –

Part 7-709:

**Requirements for special
installations or locations –**

Marinas and similar locations

(standards.iteh.ai)

Installations électriques à basse tension –

[IEC 60364-7-709:2007](#)

<https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

Partie 7-709:

Exigences pour les installations

ou emplacements spéciaux –

Marinas et emplacements analogues



Reference number
Numéro de référence
IEC/CEI 60364-7-709:2007



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications! Just Published details twice a month all new publications released. Available on-line and also by email.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL
STANDARD

IEC
CEI

NORME
INTERNATIONALE

60364-7-709

Second edition
Deuxième édition
2007-05

Low-voltage electrical installations –

Part 7-709:

**Requirements for special
installations or locations –**

Marinas and similar locations

(standards.iteh.ai)

Installations électriques à basse tension –

[IEC 60364-7-709:2007](#)

<https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

Partie 7-709:

**Exigences pour les installations
ou emplacements spéciaux –**

Marinas et emplacements analogues



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE
CODE PRIX

Q

For price, see current catalogue
Pour prix, voir catalogue en vigueur

CONTENTS

FOREWORD.....	3
INTRODUCTION.....	5
709 Marinas and similar locations.....	6
709.1 Scope	6
709.2 Normative references	6
709.3 Terms and definitions.....	6
709.31 Purposes, supplies and structure	7
709.312 Conductor arrangement and system earthing	7
709.313 Supplies.....	7
709.4 Protection for safety.....	7
709.41 Protection against electric shock.....	7
709.413 Protective measure: electrical separation.....	8
709.5 Selection and erection of electrical equipment	8
709.512 Operational conditions and external influences	8
709.521 Types of wiring systems.....	9
709.533 Devices for protection against overcurrent	10
709.536 Isolation and switching.....	10
709.55 Other equipment.....	10
Annex A (informative) Examples of methods of obtaining supply in marinas.....	12
Annex B (informative) Example of an instruction notice to be placed in marinas.....	15
Annex C (informative) List of notes concerning certain countries.....	16
Bibliography.....	17
Figure 709A.1 – Direct connection to a single phase mains supply	12
Figure 709A.2 – Direct connection to a single phase mains supply with an isolating transformer on the vessel	12
Figure 709A.3 – Direct connection to a three phase mains supply.....	13
Figure 709A.4 – Direct connection to a three phase mains supply with an isolating transformer on the vessel	13
Figure 709A.5 – Connection to a single phase supply through a shore-mounted isolating transformer	14

STANDARD PREVIEW
(standards.iteh.ai)

IEC 60364-7-709:2007

https://standards.iteh.ai/catalog/standards/sist/a-47d5-b55f-

51f8664240d/iec-60364-7-709-2007

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

**Part 7-709: Requirements for special installations or locations –
Marinas and similar locations**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60364-7-709 has been prepared by IEC technical committee 64: Electrical installations and protection against electric shock.

This second edition of IEC 60364-7-709 cancels and replaces the first edition, published in 1994. It constitutes a technical revision.

The major changes with regard to the previous edition concern:

- the removal of the requirements for the electrical installation in pleasure craft as these are now covered by IEC 60092-507;
- the requirements of this part have been aligned with those in other parts of IEC 60364.

The text of this standard is based on the following documents:

FDIS	Report on voting
64/1573/FDIS	64/1588/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The reader's attention is drawn to the fact that Annex C lists all of the "in-some-country" clauses on differing practices of a less permanent nature relating to the subject of this standard.

A list of all the parts in the IEC 60364 series, under the general title *Low-voltage electrical installations*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or [IEC 60364-7-709:2007](#)
- amended. <https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

(standards.iteh.ai)

INTRODUCTION

The requirements of this part of IEC 60364 supplement, modify or replace certain of the general requirements contained in Parts 1 to 6 of IEC 60364.

The clause numbering appearing after 709 refers to the corresponding parts or clauses of IEC 60364, Parts 1 to 6. Numbering of clauses does not, therefore, necessarily follow sequentially. Numbering of figures and tables takes the number of this part followed by a sequential number.

The absence of reference to a part or a clause means that the general requirements contained in Parts 1 to 6 of IEC 60364 are applicable.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 60364-7-709:2007](https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007)

<https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

LOW-VOLTAGE ELECTRICAL INSTALLATIONS –

Part 7-709: Requirements for special installations or locations – Marinas and similar locations

709 Marinas and similar locations

709.1 Scope

The particular requirements specified in this part of IEC 60364 apply only to circuits intended to supply pleasure craft or houseboats in marinas and similar locations.

NOTE 1 In this part “marina” means “marina and similar locations”.

The particular requirements do not apply to the supply of house boats if they are directly supplied from the public network.

The particular requirements do not apply to the internal electrical installations of pleasure craft or house boats.

NOTE 2 For electrical installations of pleasure craft, see IEC 60092-507.

NOTE 3 The electrical installations of house boats should comply with the general requirements of IEC 60364, together with the relevant particular requirements of IEC 60364-7.

For the remainder of the electrical installation of marinas and similar locations the general requirements of IEC 60364 together with the relevant particular requirements of IEC 60364-7 apply.

<https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

709.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038, *IEC standard voltages*

IEC 60309-1, *Plugs, socket-outlets and couplers for industrial purposes – Part 1: General requirements*

IEC 60309-2, *Plugs, socket-outlets and couplers for industrial Purposes – Part 2: Dimensional interchangeability requirements for pin and contact-tubes accessories*

IEC 60364-4-43, *Electrical installations of buildings – Part 4-43: Protection for safety – Protection against overcurrent*

IEC 61558-2-4, *Safety of power transformers, power supply units and similar – Part 2: Particular requirements for isolating transformers for general use*

IEC 62262, *Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)*

709.3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

709.3.1**pleasure craft**

any boat, vessel, yacht, motor launch, houseboat or other floating craft used exclusively for sport or leisure

709.3.2**marina**

facility for the mooring of pleasure craft with fixed wharves, jetties, piers or a pontoon arrangement capable of berthing one or more pleasure craft

709.3.3**houseboat**

floating decked structure which is designed or adapted for use as a place of permanent residence often kept in one place on inland water

709.31 Purposes, supplies and structure**709.312 Conductor arrangement and system earthing****709.312.2 Types of system earthing****709.312.2.1 TN-systems**

Add the following:

For a TN-system, the final circuits for the supply of pleasure craft or houseboats shall not include a PEN conductor.

ITeh STANDARD PREVIEW
(standards.iteh.ai)

709.313 Supplies

[IEC 60364-7-709:2007](#)

709.313.1.2 <https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007>

Add the following:

The nominal supply system voltage shall be selected from IEC 60038.

The nominal supply voltage shall not exceed 230 V single-phase, or 400 V three-phase.

709.4 Protection for safety**709.41 Protection against electric shock****709.411.2 Requirements for basic protection****709.41.B.2 Obstacles**

Protection by obstacles shall not be used.

709.41.B.3 Placing out of reach

Protection by placing out of reach shall not be used.

709.41.C.1 Non-conducting location

Protection by non-conducting location shall not be used.

NOTE This precludes the use of class 0 equipment.

709.41.C.2 Protection by earth-free local equipotential bonding

Protection by earth free local equipotential bonding shall not be used.

709.413 Protective measure: electrical separation

Where the protective measure of electrical separation is used for supplying pleasure craft compliance with all the requirements of Clause 413 and with 709.413.3.2 and 709.413.3.6 shall be ensured.

709.413.3.2 The circuit shall be supplied through a fixed isolating transformer complying with IEC 61558-2-4.

The protective conductor of the supply to the isolating transformer shall not be connected to the earth terminal in the socket-outlet supplying the pleasure craft.

NOTE See Annex A.

709.413.3.6

Add the following:

The equipotential bonding of the pleasure craft shall not be connected to the protective conductor of the shore supply.

709.5 Selection and erection of electrical equipment**709.512 Operational conditions and external influences****709.512.2 External influences** [IEC 60364-7-709:2007](https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007)

[https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-](https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007)

Add the following:

[51f8664240df/iec-60364-7-709-2007](https://standards.iteh.ai/catalog/standards/sist/d5414807-891a-47d5-b55f-51f8664240df/iec-60364-7-709-2007)

NOTE For marinas particular attention is given in this part to the likelihood of corrosive elements, movement of structures, mechanical damage, presence of flammable fuel and the increased risk of electric shock due to

- presence of water;
- reduction in body resistance;
- contact of the body with earth potential.

709.512.2.1.1 Presence of water (AD)

In marinas, equipment installed on or above a jetty, wharf, pier or pontoon shall be selected as follows, according to the external influences which may be present:

- water splashes (AD4): IPX4;
- water jets (AD5): IPX5;
- water waves (AD6): IPX6.

709.512.2.1.2 Presence of solid foreign bodies (AE)

Equipment installed on or above a jetty, wharf, pier or pontoon shall be selected with a degree of protection of at least IP4X in order to protect against the ingress of very small objects (AE3).

709.512.2.1.3 Presence of corrosive or polluting substances (AF)

Equipment installed on or above a jetty, wharf, pier or pontoon shall be suitable for use in the presence of atmospheric corrosive or polluting substances (AF2). If hydrocarbons are present AF3 is applicable.

709.512.2.1.4 Impact (AG)

Equipment installed on or above a jetty, wharf, pier or pontoon shall be protected against mechanical damage (impact of medium severity AG2). Protection shall be afforded by one or more of the following:

- the position or location of the equipment shall be selected to avoid being damaged by any reasonably foreseeable impact;
- local or general mechanical protection shall be provided;
- equipment shall be installed which complies with a minimum degree of protection for external mechanical impact of IK07 (See IEC 62262).

709.521 Types of wiring systems

709.521.7 Wiring systems of marinas

709.521.7.1 The following wiring systems are suitable for distribution circuits in marinas:

- a) underground cables;
- b) overhead cables or overhead insulated conductors;
- c) cables with copper conductors and thermoplastic or elastomeric insulation and installed within an appropriate cable management system taking into account external influences such as movement, impact, corrosion and ambient temperature;
- d) mineral-insulated cables with PVC protective covering;
- e) armoured cables with a thermoplastic or elastomeric covering;
- f) other cables and materials that are no less suitable than those listed under a), b), c), d) or e) above.

709.521.7.2 The following wiring systems shall not be used on or above a jetty, wharf, pier or pontoon:

- a) overhead cables and overhead conductors in free air suspended from or incorporating a support wire, e.g. as installation method N^{os}. 35 and 36 in Table 52-3 of IEC 60364-5-52;
- b) insulated conductors in conduits, trunking etc., e.g. as installation methods N^{os}. 4 and 6 in Table 52-3 of IEC 60364-5-52;
- c) cables with aluminium conductors;
- d) mineral-insulated cables.

709.521.7.3 Cables and cable management systems shall be selected and installed so that mechanical damage due to tidal and other movement of floating structures is prevented.

Cable management systems shall be installed to allow the drainage of water/condensate e.g. by sloping way and/or drainage holes.

709.521.7.4 Underground cables

Underground distribution circuits shall, unless provided with additional mechanical protection be buried at a sufficient depth to avoid being damaged, e.g. by movement of vehicles.

NOTE 1 A depth of 0,5 m is generally considered as a minimum depth to fulfil this requirement.

NOTE 2 For conduit systems buried underground, see IEC 61386-24.

709.521.7.5 Overhead cables or overhead insulated conductors

All overhead conductors shall be insulated.

Poles and other supports for overhead wiring shall be located or protected so that they are unlikely to be damaged by any foreseeable movement of vehicles.

Overhead conductors shall be at a height above ground of not less than 6 m in all areas subjected to movement of vehicles movement and 3,5 m in all other areas.

709.53.1 Devices for protection against indirect contact by automatic disconnection of supply

709.531.2 Residual current protective devices (RCD's)

Add the following:

Every socket-outlet shall be individually protected by an RCD having a rated residual operating current not exceeding 30 mA. The RCD selected shall disconnect all poles, including the neutral.

Every final circuit intended for the fixed connection of a supply to a house boat shall be protected individually by an RCD having a rated residual operating current not exceeding 30 mA. The RCD selected shall disconnect all poles, including the neutral.

709.533 Devices for protection against overcurrent

In addition the following applies:

Each socket-outlet shall be individually protected by an overcurrent protective device, in accordance with the requirements of IEC 60364-4-43.

Every final circuit intended for the fixed connection of a supply to a house boat shall be individually protected by an overcurrent protective device, in accordance with the requirements of IEC 60364-4-43.

709.536 Isolation and switching

709.536.2 Isolation

709.536.2.1 General

709.536.2.1.1 At least one means of isolation shall be installed in each distribution board. This device shall disconnect all live conductors including the neutral conductor.

709.55 Other equipment

709.55.1 Socket-outlets general

709.55.1.1 Every socket-outlet with a current rating up to 63 A shall comply with IEC 60309-2. Every socket-outlet with a current rating over 63 A shall comply with IEC 60309-1.

Every socket-outlet shall meet the degree of protection of at least IP44 or such protection shall be provided by an enclosure.