

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Explosive atmospheres –
Part 0: Equipment – General requirements

Atmosphères explosives –
Partie 0: Matériel – Exigences générales

<https://standards.iteh.ai/ccc/86110a90-da04-4298-868c-adbaa86e8662/iec-60079-0-2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us.

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



IEC 60079-0

Edition 5.0 2007-10

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Explosive atmospheres –
Part 0: Equipment – General requirements**

**Atmosphères explosives –
Partie 0: Matériel – Exigences générales**

<https://standards.iteh.ai> <https://standards.iteh.ai/standard/iec-60079-0-2007>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX **XD**

ICS 29.260.20

ISBN 2-8318-9326-7

Withdrawn

iTeh Standards
(<https://standards.iteh.ai>)

Document Preview

[IEC 60079-0:2007](https://standards.iteh.ai/cz11/standards/iec/60079-0-2007)
<https://standards.iteh.ai/cz11/standards/iec/60079-0-2007>

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET

This interpretation sheet has been prepared by committee 31: Equipment for explosive atmospheres, of IEC.

The text of this interpretation sheet is based on the following documents:

ISH	Report on voting
31/768/ISH	31/779/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

Subclauses 26.8 and 26.9 of IEC 60079-0 (2007)

Following the discussions by the TC 31/WG 22 Task Group addressing the repeatability of the thermal endurance to heat and thermal endurance to cold tests it was proposed that a tolerance be clarified for the test periods in Edition 6. 31/744/DC was issued and comments received and resolved as 31/752A/INF.

These interpretations are made available for edition 5 of this standard due to the current use of that standard by manufacturers, conformity assessment schemes and national bodies by means of this "Interpretation Sheet" as follows:

Details of interpretation:

Interpretation of subclause 26.8 Thermal endurance to heat and 26.9 Thermal endurance to cold of IEC 60079-0 (2007):

Question: As it is unreasonable to consider them to be the exact test time, are the time frames for the 24 h, 336 h (2 weeks) or 672 h (4 weeks) tests considered to be the minimum times? If so, what is the maximum time?

Interpretation: The 24 h, 336 h and 672 h values are considered the minimum number of hours for each of the tests. It is practical that the time periods should not extend beyond 24⁺²₀ h, 336⁺³⁰₀ h, 672⁺³⁰₀ h.

It is intended that this interpretation will be introduced in IEC 60079-0 Edition 6 and therefore an Interpretation Sheet will not be required for this or future editions.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

IEC 60079-0
Edition 5.0 2007-10

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

INTERPRETATION SHEET 2

This interpretation sheet has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

The text of this interpretation sheet is based on the following documents:

DISH	Report on voting
31/1453/DISH	31/1466/RVDISH

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

<https://standards.iteh.ae/cdlog/standards/iec/c6110a90-da04-4298-868c-adbaa86e8662/iec-60079-0-2007>

Interpretation sheet of Subclause 16.5 of IEC 60079-0:2007

The TC 31/CAG requested (Resolution 2 of 2018-04-19) that WG 22 prepare an interpretation sheet based on IECEx Decision Sheet DS2018/002 addressing the assignment of entry point and branching point temperatures of electrical rotating machines.

This interpretation is made available for Edition 5 of this standard due to the current use of that standard by manufacturers, conformity assessment schemes and national bodies by means of this "Interpretation Sheet" as follows:

Details of interpretation:

IEC 60079-0:2007 (Ed. 5), Explosive atmospheres – Part 0: Equipment – General requirements

Interpretation of Subclause 16.5 Temperature at branching point and entry point:

Question: Subclause 16.5 of IEC 60079-0:2007 (Ed. 5) states “When the temperature under rated conditions is higher than 70 °C at the entry point or 80 °C at the branching point of the conductors, information shall be marked on the equipment exterior to provide guidance to the user on the proper selection of cable and cable gland or conductors in conduit.”

It is not normal practice for electrical rotating machines to be tested with the cable entry devices and cables that might be used in an actual installation, but with the cables available at the manufacturer's test area. In many cases, there will be no formal entry device as the cables will enter via the space reserved for fixing of a gland plate.

How shall the relevant entry point and branching point temperatures be determined?

Interpretation: *The use of the maximum internal air space temperature to represent the maximum service temperature of terminal box gaskets and seals, the cable branching point temperature, and the entry point temperature reflects the normal practice of testing electrical rotating machines without prior knowledge of the actual glands and cables to be used for installation. The production of heat from the electrical rotating machine connections is generally insignificant with respect to the production of heat from the machine windings and core.*

Further amplification:

- 1) The entry point of the cable where the temperature is measured should be sealed so far as possible to ensure that there is minimum air-circulation which can reduce the measured temperature.
- 2) This is not intended to apply to any gasket between the terminal box and the frame of the electrical rotating machine, where higher temperatures may be recorded, but only to the gasket between the terminal box and its lid.

Although written in the context of electrical rotating machines, there may be other types of equipment where an equivalent approach is applicable.

CONTENTS

FOREWORD	8
1 Scope	10
2 Normative references	11
3 Terms and definitions	14
4 Equipment grouping	24
4.1 Group I	24
4.2 Group II	24
4.3 Group III	25
4.4 Equipment for a particular explosive atmosphere	25
5 Temperatures	25
5.1 Environmental influences	25
5.1.1 Ambient temperature	25
5.1.2 External source of heating or cooling	25
5.2 Service temperature	26
5.3 Maximum surface temperature	26
5.3.1 Determination of maximum surface temperature	26
5.3.2 Limitation of maximum surface temperature	26
5.3.3 Small component temperature for Group I or Group II electrical equipment	27
6 Requirements for all electrical equipment	28
6.1 General	28
6.2 Mechanical strength of equipment	29
6.3 Opening times	29
6.4 Circulating currents	29
6.5 Gasket retention	30
6.6 Electromagnetic and ultrasonic energy radiating equipment	30
6.6.1 Radio frequency sources	30
6.6.2 Lasers or other continuous wave sources	31
6.6.3 Ultrasonic sources	31
7 Non-metallic enclosures and non-metallic parts of enclosures	31
7.1 General	31
7.1.1 Applicability	31
7.1.2 Specification of materials	31
7.1.3 Plastic materials	32
7.1.4 Elastomeric materials	32
7.2 Thermal endurance	32
7.2.1 Tests for thermal endurance	32
7.2.2 Material selection	32
7.3 Resistance to light	33
7.4 Electrostatic charges on external non-metallic materials	33
7.4.1 Applicability	33
7.4.2 Avoidance of a build-up of electrostatic charge on Group I or Group II electrical equipment	33
7.4.3 Avoidance of a build-up of electrostatic charge on equipment for Group III	35
7.5 Threaded holes	35

8	Metallic enclosures and metallic parts of enclosures	35
8.1	Material composition	35
8.1.1	Group I	35
8.1.2	Group II	35
8.1.3	Group III	36
8.2	Threaded holes	36
9	Fasteners	36
9.1	General	36
9.2	Special fasteners	36
9.3	Holes for special fasteners	37
9.3.1	Thread engagement	37
9.3.2	Tolerance and clearance	37
9.3.3	Hexagon socket set screws	38
10	Interlocking devices	38
11	Bushings	38
12	Materials used for cementing	38
13	Ex components	39
13.1	General	39
13.2	Mounting	39
13.3	Internal mounting	39
13.4	External mounting	39
14	Connection facilities and termination compartments	39
14.1	General	39
14.2	Termination compartment	39
14.3	Type of protection	40
14.4	Creepage and clearance	40
15	Connection facilities for earthing or bonding conductors	40
15.1	Equipment requiring earthing	40
15.1.1	Internal	40
15.1.2	External	40
15.2	Equipment not requiring earthing	40
15.3	Size of conductor connection	40
15.4	Protection against corrosion	41
15.5	Secureness of electrical connections	41
16	Entries into enclosures	41
16.1	General	41
16.2	Identification of entries	41
16.3	Cable glands	41
16.4	Blanking elements	42
16.5	Temperature at branching point and entry point	42
16.6	Electrostatic charges of cable sheaths	42
17	Supplementary requirements for rotating electrical machines	43
17.1	Fans and fan hoods	43
17.2	Ventilation openings for external fans	43
17.3	Construction and mounting of the ventilating systems	44
17.4	Clearances for the ventilating system	44
17.5	Materials for external fans and fan hoods	44
17.6	Equipotential bonding conductors	44

18	Supplementary requirements for switchgear	44
18.1	Flammable dielectric	44
18.2	Disconnectors	44
18.3	Group I – Provisions for locking.....	45
18.4	Doors and covers	45
19	Supplementary requirements for fuses	45
20	Supplementary requirements for plugs, socket outlets and connectors	45
20.1	Interlocking	45
20.1.1	Explosive gas atmospheres	46
20.1.2	Explosive dust atmospheres	46
20.2	Energized plugs	46
21	Supplementary requirements for luminaires	46
21.1	General	46
21.2	Covers for luminaires of EPL Gb or EPL Db	47
21.3	Covers for luminaires of EPL Gc or EPL Dc.....	47
21.4	Special lamps	47
22	Supplementary requirements for caplights and handlights	47
22.1	Group I caplights	47
22.2	Group II and Group III caplights and handlights	48
23	Equipment incorporating cells and batteries	48
23.1	General	48
23.2	Batteries	48
23.3	Cell types	48
23.4	Cells in a battery	49
23.5	Ratings of batteries	49
23.6	Interchangeability	49
23.7	Charging of primary batteries	49
23.8	Leakage	49
23.9	Connections	49
23.10	Orientation	50
23.11	Replacement of cells or batteries	50
23.12	Replaceable battery pack	50
24	Documentation	50
25	Compliance of prototype or sample with documents	50
26	Type tests	50
26.1	General	50
26.2	Test configuration.....	51
26.3	Tests in explosive test mixtures	51
26.4	Tests of enclosures	51
26.4.1	Order of tests	51
26.4.2	Resistance to impact	53
26.4.3	Drop test	54
26.4.4	Acceptance criteria	54
26.4.5	Degree of protection (IP) by enclosures	54
26.5	Thermal tests	55
26.5.1	Temperature measurement.....	55
26.5.2	Thermal shock test	56
26.5.3	Small component ignition test (Group I and Group II).....	56

26.6	Torque test for bushings.....	57
26.6.1	Test procedure	57
26.6.2	Acceptance criteria.....	58
26.7	Non-metallic enclosures or non-metallic parts of enclosures.....	58
26.7.1	General	58
26.7.2	Test temperatures	58
26.8	Thermal endurance to heat.....	58
26.9	Thermal endurance to cold.....	59
26.10	Resistance to light	59
26.10.1	Test procedure	59
26.10.2	Acceptance criteria.....	59
26.11	Resistance to chemical agents for Group I electrical equipment.....	59
26.12	Earth continuity	60
26.13	Surface resistance test of parts of enclosures of non-metallic materials.....	61
26.14	Charging tests	62
26.14.1	Introduction	62
26.14.2	Principle of the test	62
26.14.3	Samples and test apparatus	63
26.14.4	Ambient conditions	63
26.14.5	Conditioning	63
26.14.6	Determination of the most efficient charging method	63
26.14.7	Assessment of discharge	65
26.15	Measurement of capacitance	66
26.15.1	Test procedure	66
26.15.2	Acceptance criteria.....	66
27	Routine tests	66
28	Manufacturer's responsibility	66
28.1	Conformity with the documentation.....	66
28.2	Certificate	66
28.3	Responsibility for marking	66
29	Marking	67
29.1	Location	67
29.2	General	67
29.3	Ex marking for explosive gas atmospheres	67
29.4	Ex marking for explosive dust atmospheres	69
29.5	Combined types of protection	70
29.6	Multiple types of protection	70
29.7	Ga using two independent Gb types of protection	71
29.8	Ex components	71
29.9	Small equipment and small Ex components	71
29.10	Extremely small equipment and extremely small Ex components	72
29.11	Warning markings.....	72
29.12	Alternate marking of Equipment Protection Levels (EPLs).....	72
29.12.1	Alternate marking of type of protection for explosive gas atmospheres	72
29.12.2	Alternate marking of type of protection for explosive dust atmospheres	73
29.13	Cells and batteries.....	73
29.14	Examples of marking	74

30 Instructions.....	76
30.1 General	76
30.2 Cells and batteries	77

Annex A (normative) Supplementary requirements for cable glands	78
Annex B (normative) Requirements for Ex components.....	85
Annex C (informative) Example of rig for resistance to impact test.....	87
Annex D (informative) Introduction of an alternative risk assessment method encompassing “equipment protection levels” for Ex equipment	88
Annex E (informative) Motors supplied by converters.....	93

Bibliography.....	94
-------------------	----

Figure 1 – Tolerances and clearance for threaded fasteners	37
Figure 2 – Contact surface under head of fastener with a reduced shank.....	38
Figure 3 – Illustration of entry points and branching points	43
Figure 4 – Assembly of test sample for earth-continuity test.....	61
Figure 5 – Test piece with painted electrodes	62
Figure 6 – Rubbing with a pure polyamide or cotton cloth	64
Figure 7 – Discharging of a container with a probe connected to earth via a 0,1 µF capacitor.....	64
Figure 8 – Charging by influence with a d.c. voltage power supply	65
Figure A.1 – Illustration of the terms used for cable glands	78
Figure A.2 – Rounded edge of the point of entry of the flexible cable	79
Figure C.1 – Example of rig for resistance to impact test	87

<https://standards.iteh.ae/c6110a90-da04-4298-868c-adbaa86e8662/iec-60079-0-2007>

Table 1 – Ambient temperatures in service and additional marking	25
Table 2 – Classification of maximum surface temperatures for Group II electrical equipment.....	27
Table 3a – Assessment of temperature classification according to component size at 40°C ambient temperature	28
Table 3b – Assessment of temperature classification according to component size – Variation in maximum power dissipation with ambient temperature	28
Table 4 – Radio frequency power thresholds.....	30
Table 5 – Radio-frequency energy thresholds	30
Table 6 – Limitation of surface areas	34
Table 7 – Diameter or width of long parts.....	34
Table 8 – Limitation of thickness of non-metallic layer	34
Table 9 – Minimum cross-sectional area of protective conductors	41
Table 10 – Primary cells	48
Table 11 – Secondary cells	49
Table 12 – Tests for resistance to impact.....	53
Table 13 – Torque to be applied to the stem of bushing used for connection facilities	58
Table 14 – Text of warning markings	72
Table B.1 – Clauses with which Ex components shall comply	85

Table D.1 – Traditional relationship of EPLs to zones (no additional risk assessment)	90
Table D.2 – Description of risk of ignition protection provided	91



INTERNATIONAL ELECTROTECHNICAL COMMISSION

EXPLOSIVE ATMOSPHERES –

Part 0: Equipment – General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60079-0 has been prepared by IEC technical committee 31: Equipment for explosive atmospheres.

This fifth edition cancels and replaces the fourth edition, published in 2004, and constitutes a full technical revision.

The significant changes with respect to the previous edition are listed below:

- Requirements for explosive dust atmospheres transferred from IEC 61241-0.
- The marking Group "II" alone has been replaced by "IIA", "IIB", or "IIC" as many of the enclosure requirements are now aligned with a specific sub-group.
- Dust groups defined as Group IIIA, IIIB and IIIC.
- Limits for ultrasonic and electromagnetic radiation introduced.