

---

**Power transformer and reactor fittings - Part 5: Liquid level, pressure devices and flow indicators - Amendment A1**

Power transformer and reactor fittings -- Part 5: Liquid level, pressure and flow indicators, pressure relief devices and dehydrating breathers

Zubehr fr Transformatoren und Drosselspulen -- Teil 5: Flüssigkeitsstandanzeiger, Druckanzeigeeinrichtungen und Durchflussmesser, Druckentlastungsventile und Luftentfeuchter

**iTeh STANDARD PREVIEW**

**(standards.iteh.ai)**

Accessoires pour transformateurs de puissance et bobines d'inductance -- Partie 5: Indicateurs de niveau de liquide isolant, manomètres et indicateurs de circulation de liquide isolant, soupapes de sret et asscheurs d'air

<https://standards.iteh.ai/en/standards/SIST-EN-50216-5-2002-A1-2004>

**Ta slovenski standard je istoveten z: EN 50216-5:2002/A1:2002**

---

**ICS:**

29.180      Transformatorji. Dušilke      Transformers. Reactors

**SIST EN 50216-5:2002/A1:2004**      **en**

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[SIST EN 50216-5:2002/A1:2004](https://standards.iteh.ai/catalog/standards/sist/d202a7ac-0030-4ad8-a361-bc41576c6b5e/sist-en-50216-5-2002-a1-2004)

<https://standards.iteh.ai/catalog/standards/sist/d202a7ac-0030-4ad8-a361-bc41576c6b5e/sist-en-50216-5-2002-a1-2004>

EUROPEAN STANDARD

**EN 50216-5/A1**

NORME EUROPÉENNE

EUROPÄISCHE NORM

December 2002

ICS 29.180

English version

**Power transformer and reactor fittings  
Part 5: Liquid level, pressure devices and flow indicators**

Accessoires pour transformateurs  
de puissance et bobines d'inductance  
Partie 5: Indicateurs de niveau de liquide  
isolant, manomètres et indicateurs  
de circulation de liquide isolant

Zubehör für Transformatoren  
und Drosselspulen  
Teil 5: Flüssigkeitsstandanzeiger,  
Druckanzeigeeinrichtungen  
und Durchflussmesser

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

This amendment A1 modifies the European Standard EN 50216-5:2002; it was approved by CENELEC on 2002-11-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this amendment the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

This amendment was prepared by the Technical Committee CENELEC TC 14, Power transformers.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A1 to EN 50216-5:2002 on 2002-11-01.

The following dates were fixed:

- latest date by which the amendment has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2003-11-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2005-11-01

---

### 3 Direct reading dial type liquid level indicators

3.2.3 **Replace** in Table 1 "24 V d.c. to 127 V d.c." with "24 V d.c. to 220 V d.c.".

### 4 Liquid pressure gauges – Differential pressure gauges

4.2.3 **Replace** in Table 2 "48 V d.c. to 127 V d.c." with "24 V d.c. to 220 V d.c.".

<https://standards.iteh.ai/catalog/standards/sist/d202a7ac-0030-4ad8-a361-bc41576c6b5e/sist-en-50216-5-2002-a1-2004>

### 5 Liquid flow indicators

5.2.3 **Replace** in Table 3 "48 V d.c. to 127 V d.c." with "24 V d.c. to 220 V d.c.".

---