An American National Standard

AMERICAN SOCIETY FOR TESTING AND MATERIALS 100 Barr Harbor Dr., West Conshohocken, PA 19428 Reprinted from the Annual Book of ASTM Standards. Copyright ASTM

Standard Specification for Seamless Carbon Steel Boiler Tubes for High-Pressure Service¹

This standard is issued under the fixed designation A 192/A 192M; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval. A superscript epsilon (ϵ) indicates an editorial change since the last revision or reapproval.

This standard has been approved for use by agencies of the Department of Defense.

€ Note—Keywords were added editorially in September 1996.

1. Scope

- 1.1 This specification² covers minimum-wall-thickness, seamless carbon steel boiler and superheater tubes for high-pressure service.
- 1.2 The tubing sizes and thicknesses usually furnished to this specification are ½ in. to 7 in. [12.7 to 177.8 mm] outside diameter and 0.085 to 1.000 in. [2.2 to 25.4 mm], inclusive, in minimum wall thickness. Tubing having other dimensions may be furnished, provided such tubes comply with all other requirements of this specification.
- 1.3 Mechanical property requirements do not apply to tubing smaller than ½ in. [3.2 mm] inside diameter or 0.015 in. [0.4 mm] thickness.
- 1.4 When these products are to be used in applications conforming to ISO Recommendations for Boiler Construction, the requirements of Specification A 520 shall supplement and supersede the requirements of this specification.
- 1.5 The values stated in either inch-pound units or SI units are to be regarded separately as standard. Within the text, the SI units are shown in brackets. The values stated in each system are not exact equivalents; therefore, each system must be used independently of the other. Combining values from the two systems may result in nonconformance with the specification. The inch-pound units shall apply unless the "M" designation of this specification is specified in the order.

2. Referenced Documents

2.1 ASTM Standards:

A 450/A 450M Specification for General Requirements for Carbon, Ferritic Alloy, and Austenitic Alloy Steel Tubes³ A 520 Specification for Supplementary Requirements for Seamless and Electric-Resistance-Welded Carbon Steel

Tubular Products for High-Temperature Service Conforming to ISO Recommendations for Boiler Construction³

3. Ordering Information

- 3.1 Orders for material under this specification should include the following, as required, to describe the desired material adequately:
 - 3.1.1 Quantity (feet, metres, or number of lengths),
 - 3.1.2 Name of material (seamless tubes),
 - 3.1.3 Manufacture (hot-finished or cold-finished),
 - 3.1.4 Size (outside diameter and minimum wall thickness),
 - 3.1.5 Length (specific or random),
 - 3.1.6 Optional requirements (Section 8),
- 3.1.7 Test report required (see section on Certification of Specification A 450/A 450M),
 - 3.1.8 Specification designation, and
 - 3.1.9 Special requirements.

4. General Requirements

4.1 Material furnished under this specification shall conform to the applicable requirements of the current edition of Specification A 450/A 450M, unless otherwise provided herein.

5. Manufacture

5.1 Tubes shall be made by the seamless process and shall be either hot-finished or cold-finished, as specified.

6. Heat Treatment

6.1 Hot-finished tubes need not be heat treated. Cold-finished tubes shall be heat treated after the final cold-finishing at a temperature of 1200°F [650°C] or higher.

7. Chemical Composition

7.1 The steel shall conform to the following requirements as to chemical composition:

Carbon, %	0.06-0.18
Manganese, %	0.27-0.63
Phosphorus, max, %	0.035
Sulfur, max, %	0.035
Silicon, max, %	0.25

¹ This specification is under the jurisdiction of ASTM Committee A-1 on Steel, Stainless Steel, and Related Alloys, and is the direct responsibility of Subcommittee A01.09 on Carbon Steel Tubular Products.

Current edition approved Dec. 15, 1991. Published March 1992. Originally published as A 192-36 T. Last previous edition A 192/A 192M-90a.

² For ASME Boiler and Pressure Vessel Code applications see related Specification SA-192 in Section II of that Code.

³ Annual Book of ASTM Standards, Vol 01.01.

7.2 Supplying an alloy grade of steel that specifically requires the addition of any element other than those listed in 7.1 is not permitted.

8. Product Analysis

- 8.1 When requested on the purchase order, a product analysis shall be made by the supplier from one tube per 100 pieces for sizes over 3 in. [76.2 mm] and one tube per 250 pieces for sizes 3 in. [76.2 mm] and under; or when tubes are identified by heat, one tube per heat shall be analyzed. The chemical composition thus determined shall conform to the requirements specified.
- 8.2 If the original test for product analysis fails, retests of two additional billets or tubes shall be made. Both retests, for the elements in question, shall meet the requirements of the specification; otherwise all remaining material in the heat or lot (see Note) shall be rejected or, at the option of the producer, each billet or tube may be individually tested for acceptance. Billets or tubes which do not meet the requirements of the specification shall be rejected.

Note 1—A lot consists of 250 tubes for sizes 3 in. [76.2 mm] and under and of 100 tubes for sizes over 3 in. [76.2 mm], prior to cutting to length.

9. Hardness Requirements

9.1 The tubes shall have a hardness number not exceeding the following:

Brinell Hardness Number (Tubes 0.200 in. [5.1 mm] and over in wall thickness)

Rockwell Hardness Number (Tubes less than 0.200 in. [5.1 mm] in wall thickness)

137 HB

77 HRB

12. Product Marking

11. Forming Operations

without developing defects.

12.1 In addition to the marking prescribed in Specification A 450/A 450M, the marking shall indicate whether the tube is hot finished or cold finished.

13. Keywords

13.1 boiler tubes; seamless steel tube; steel tube-carbon

10. Mechanical Tests Required

- 10.1 Flattening Test—One flattening test shall be made on specimens from each end of two tubes selected from each lot (see Note) or fraction thereof.
- 10.2 Flaring Test—One flaring test shall be made on specimens from each end of two tubes selected from each lot (see

EXPLANATORY NOTES

Note 1-For purposes of design, the following tensile properties may be assumed:

Tensile strength, min, ksi [MPa] 47 [325] Yield strength, min, ksi [MPa] 26 [180] Elongation in 2 in. or 50 mm, min, % 35

The American Society for Testing and Materials takes no position respecting the validity of any patent rights asserted in connection with any item mentioned in this standard. Users of this standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, are entirely their own responsibility.

This standard is subject to revision at any time by the responsible technical committee and must be reviewed every five years and if not revised, either reapproved or withdrawn. Your comments are invited either for revision of this standard or for additional standards and should be addressed to ASTM Headquarters. Your comments will receive careful consideration at a meeting of the responsible technical committee, which you may attend. If you feel that your comments have not received a fair hearing you should make your views known to the ASTM Committee on Standards, 100 Barr Harbor Drive, West Conshohocken, PA 19428.

Note) or fraction thereof. These tubes shall be selected apart from those used for the flattening test.

10.3 Hardness Test—Brinell or Rockwell hardness tests shall be made on specimens from two tubes from each lot. The term lot applies to all tubes prior to cutting, of the same nominal diameter and wall thickness which are produced from the same heat of steel. When final heat treatment is in a batch-type furnace, a lot shall include only those tubes of the same size and the same heat which are heat treated in the same furnace charge. When the final heat treatment is in a continuous furnace, a lot shall include all tubes of the same size and heat, heat treated in the same furnace at the same temperature, time at heat, and furnace speed.

10.4 Hydrostatic Test—Each tube shall be subjected to the hydrostatic pressure test, or instead of this test, a nondestructive test may be used when specified by the purchaser.

11.1 Tubes when inserted in the boiler shall stand expanding

and beading without showing cracks or flaws. Superheater

tubes when properly manipulated shall stand all forging,

welding, and bending operations necessary for application