

INTERNATIONAL STANDARD

**Field device tool (FDT) interface specification –
Part 1: Overview and guidance**

<https://standards.iteh.ai/catalog/standards/sist/47256e-7be8-4acb-842f-d9223df4abe6/iec-62453-1-2009>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

**Field device tool (FDT) interface specification –
Part 1: Overview and guidance**

<https://standards.iteh.ai/catalog/standards/sist/47256e-7be8-4acb-842f-d9223df4abe6/iec-62453-1-2009>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

PRICE CODE

W

ICS 25.040.40; 35.100.05; 35.110

ISBN 978-2-88910-715-5

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Terms, definitions, symbols, abbreviations and conventions	7
3.1 Terms and definitions	7
3.2 Abbreviations	12
3.3 Conventions	12
4 FDT overview	12
4.1 State of the art	12
4.2 Objectives of FDT	13
4.2.1 General features.....	13
4.2.2 Device and module manufacturer benefits.....	14
4.2.3 System manufacturer and integrator benefits.....	14
4.2.4 Other applications	14
4.3 FDT model	15
4.3.1 General	15
4.3.2 Frame Applications.....	16
4.3.3 Device Type Manager.....	17
4.3.4 Communication Channel concept.....	18
4.3.5 Presentation object.....	20
5 Structure of the IEC 62453 series.....	20
5.1 Structure overview	20
5.2 Part 2 – Concepts and detailed description.....	21
5.3 Parts 3xy – Communication profile integration.....	22
5.3.1 General.....	22
5.3.2 Communication profile integration – IEC 61784 CPF 1.....	22
5.3.3 Communication profile integration – IEC 61784 CPF 2.....	22
5.3.4 Communication profile integration – IEC 61784 CP 3/1 and 3/2	22
5.3.5 Communication profile integration – IEC 61784 CP 3/4, CP 3/5 and 3/6.....	22
5.3.6 Communication profile integration – IEC 61784 CPF 6.....	22
5.3.7 Communication profile integration – IEC 61784 CPF 9.....	23
5.3.8 Communication profile integration – IEC 61784 CPF 15.....	23
5.4 Parts 4x – Object model integration profiles	23
5.4.1 General	23
5.4.2 Object model integration profile – Common object model.....	23
5.5 Parts 5xy – Communication profile implementation.....	23
5.5.1 General	23
5.5.2 Communication profile integration – IEC 61784 CPF 1.....	23
5.5.3 Communication profile integration – IEC 61784 CPF 2.....	24
5.5.4 Communication profile integration – IEC 61784 CP 3/1 and 3/2	24
5.5.5 Communication profile integration – IEC 61784 CP 3/4, CP 3/5 and 3/6.....	24
5.5.6 Communication profile integration – IEC 61784 CPF 6.....	24
5.5.7 Communication profile integration – IEC 61784 CPF 9.....	24
5.5.8 Communication profile integration – IEC 61784 CPF 15.....	24

5.6	Parts 6x – DTM styleguides.....	25
5.6.1	General	25
5.6.2	Device Type Manager (DTM) styleguide for common object model	25
6	Relation of the IEC 62453 series to other standardization activities	25
7	Migration to DTM.....	29
8	How to read IEC 62453	30
8.1	Architecture.....	30
8.2	Dynamic behavior.....	30
8.3	Structured data types	31
8.4	Fieldbus communication	31
	Annex A (informative) UML notation.....	32
	Annex B (informative) Implementation policy.....	37
	Bibliography.....	38
	Figure 1 – Different tools and fieldbusses result in limited integration.....	13
	Figure 2 – Full integration of all devices and modules into a homogeneous system.....	14
	Figure 3 – General architecture and components.....	15
	Figure 4 – FDT software architecture.....	17
	Figure 5 – General FDT client/server relationship.....	18
	Figure 6 – Typical FDT channel architecture.....	19
	Figure 7 – Channel/parameter relationship.....	20
	Figure 8 – Structure of the IEC 62453 series.....	20
	Figure 9 – Standards related to IEC 62453 – in an automation hierarchy.....	26
	Figure 10 – Standards related to IEC 62453 – grouped by purpose.....	28
	Figure 11 – DTM – implementations.....	30
	Figure A.1 – Note.....	32
	Figure A.2 – Class.....	32
	Figure A.3 – Association.....	32
	Figure A.4 – Composition.....	33
	Figure A.5 – Aggregation.....	33
	Figure A.6 – Dependency.....	33
	Figure A.7 – Abstract class, generalization and interface.....	33
	Figure A.8 – Multiplicity.....	34
	Figure A.9 – Elements of UML statechart diagrams.....	34
	Figure A.10 – Example of UML state chart diagram.....	35
	Figure A.11 – UML use case syntax.....	35
	Figure A.12 – UML sequence diagram.....	36
	Table 1 – Overview of related standards.....	27

INTERNATIONAL ELECTROTECHNICAL COMMISSION

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 1: Overview and guidance

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62453-1 has been prepared by subcommittee 65E: Devices and integration in enterprise systems, of IEC technical committee 65: Industrial-process measurement, control and automation.

This part, in conjunction with the other parts of the first edition of the IEC 62453 series cancels and replaces IEC/PAS 62453-1, IEC/PAS 62453-2, IEC/PAS 62453-3, IEC/PAS 62453-4 and IEC/PAS 62453-5 published in 2006, and constitutes a technical revision.

The text of this standard is based on the following documents:

FDIS	Report on voting
65E/123/FDIS	65E/136/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 62453 series, under the general title *Field Device Tool (FDT) interface specification*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

A bilingual version of this publication may be issued at a later date.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 62453-1:2009](https://standards.iteh.ai/catalog/standards/sist/47256e-7be8-4acb-842f-d9223df4abe6/iec-62453-1-2009)

<https://standards.iteh.ai/catalog/standards/sist/47256e-7be8-4acb-842f-d9223df4abe6/iec-62453-1-2009>

INTRODUCTION

Enterprise automation requires two main data flows: a “vertical” data flow from enterprise level down to the field devices including signals and configuration data, and a “horizontal” communication between field devices operating on the same or different communication technologies.

With the integration of fieldbuses into control systems, there are a few other tasks which need to be performed. In addition to fieldbus- and device-specific tools, there is a need to integrate these tools into higher-level system-wide planning- or engineering tools. In particular, for use in extensive and heterogeneous control systems, typically in the area of the process industry, the unambiguous definition of engineering interfaces that are easy to use for all those involved is of great importance.

Several different manufacturer specific tools have to be used. The data in these tools are often invisible data islands from the viewpoint of system life-cycle management and plant-wide automation.

To ensure the consistent management of a plant-wide control and automation technology, it is necessary to fully integrate fieldbuses, devices and sub-systems as a seamless part of a wide range of automation tasks covering the whole automation life-cycle.

IEC 62453 provides an interface specification for developers of FDT (Field Device Tool) components to support function control and data access within a client/server architecture. The availability of this standard interface facilitates development of servers and clients by multiple manufacturers and supports open interoperation.

A device or module-specific software component, called a DTM (Device Type Manager) is supplied by a manufacturer with the related device type or software entity type. Each DTM can be integrated into engineering tools via defined FDT interfaces. This approach to integration is in general open for all fieldbuses and thus supports integration of different devices and software modules into heterogeneous control systems.

The IEC 62453 common application interface supports the interests of application developers, system integrators, and manufacturers of field devices and network components. It also simplifies procurement, reduces system costs and helps manage the lifecycle. Significant savings are available in operating, engineering and maintaining the control systems.

The objectives of IEC 62453 series are to support:

- universal plant-wide tools for life-cycle management of heterogeneous fieldbus environments, multi-manufacturer devices, function blocks and modular sub-systems for all automation domains (e.g. process automation, factory automation and similar monitoring and control applications);
- integrated and consistent life-cycle data exchange within a control system including its fieldbuses, devices, function blocks and modular sub-systems;
- simple and powerful manufacturer-independent integration of different automation devices, function blocks and modular sub-systems into the life-cycle management tools of a control system.

The FDT concept supports planning and integration of monitoring and control applications, it does not provide a solution for other engineering tasks such as “electrical wiring planning”, “mechanical planning”. Plant management subjects such as “maintenance planning”, “control optimization”, “data archiving”, are not part of this FDT standard. Some of these aspects may be included in future editions of FDT publications.

FIELD DEVICE TOOL (FDT) INTERFACE SPECIFICATION –

Part 1: Overview and guidance

1 Scope

This part of IEC 62453 presents an overview and guidance for the IEC 62453 series. It

- explains the structure and content of the IEC 62453 series (see Clause 5);
- provides explanations of some aspects of the IEC 62453 series that are common to many of the parts of the series;
- describes the relationship to some other standards.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61784 (all parts), *Industrial communication networks – Profiles*

ISO/IEC 19501:2005, *Information technology – Open Distributed Processing – Unified Modeling Language (UML) Version 1.4.2*

<https://standards.iec.ch/catalog/standards/sist/4/72/56e-7be8-4acb-842f-d9223df4abe6/iec-62453-1-2009>

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document the following terms, definitions and abbreviations apply.

3.1 Terms and definitions

3.1.1 actor

coherent set of roles that users of use cases play when interacting with these use cases

[ISO/IEC 19501]

NOTE An actor has one role for each use case with which it communicates.

3.1.2 address

communication protocol specific access identifier

3.1.3 application

software functional unit that is specific to the solution of a problem in industrial-process measurement and control

NOTE An application may be distributed among resources, and may communicate with other applications.

3.1.4

business object

object representing specific behavior (e.g. DTM, BTM and channel)

NOTE The term business object has been defined originally as part of the design pattern 3-tier architecture, where the business object is part of the business layer.

3.1.5

Block Type Manager (BTM)

specialized DTM to manage and handle a block

3.1.6

communication

fieldbus protocol specific data transfer

3.1.7

Communication Channel

access point for communication to field device

3.1.8

configuration

system created by configuring the plant components and the topology

3.1.9

configure

(see also parameterize)

setting parameters at the instance data as well as the logical association of plant components to build up the plant topology (off-line)

3.1.10

connection

established data path for communication with an selected device

3.1.11

data

set of parameter values

3.1.12

data type

set of values together with a set of permitted operations

[ISO 2382 series]

3.1.13

DCS manufacturer / system manufacturer

manufacturer of the engineering system

3.1.14

device

(see also field device)

- a) networked independent physical entity of an industrial automation system capable of performing specified functions in a particular context and delimited by its interfaces [IEC 61499-1]
- b) entity that performs control, actuating and/or sensing functions and interfaces to other such entities within an automation system

3.1.15**device manufacturer**

manufacturer of fieldbus devices

3.1.16**device type**

device characterization based on abstract properties such as manufacturer, fieldbus protocol, device type identifier, device classification, version information or other information

NOTE The scope of such characterizations can vary depending on the properties that are used in the definition of such a set and is manufacturer specific for each DTM.

3.1.17**distributed system**

FDT objects that jointly are executed on different PCs in a network

NOTE The implementation of such a distributed system is vendor specific (for example: DTM and Presentation are executed on different PCs or DTMs are executed in multi-user system on different PCs)

3.1.18**documentation**

human readable information about a device instance

NOTE This may be electronic information in a database.

3.1.19**Device Type Manager (DTM)**

a) software component containing device specific application software

b) generic class and means "Type Manager"

NOTE The D is kept because the Acronym is well-known in the market.

3.1.20**DTM device type**

software module for a particular device type within the DTM

NOTE A DTM may contain one or more DTM device types

3.1.21**entity**

particular thing, such as a person, place, process, object, concept, association, or event

[IEC 61499-1]

3.1.22**field device**

(see also device)

3.1.23**Frame Application**

FDT runtime environment

3.1.24**FDT model**

interface specification for objects and object behavior in a monitoring and control system

3.1.25**function**

specific purpose of an entity or its characteristic action

[IEC 61499-1]

3.1.26

hardware

physical equipment, as opposed to programs, procedures, rules and associated documentation

[ISO/AFNOR Dictionary of computer science]

3.1.27

implementation

development phase in which the hardware and software of a system become operational

[IEC 61499-1]

3.1.28

instantiation

creation of an instance of a specified type

[IEC 61499-1]

3.1.29

interface

shared boundary between two *functional units*, defined by functional characteristics, signal characteristics, or other characteristics as appropriate

[IEC 60050-351]

3.1.30

mapping

set of values having defined correspondence with the quantities or values of another set

[ISO/AFNOR Dictionary of computer science]

3.1.31

multi-user environment

environment which allows operation by more than one user

3.1.32

network

all of the media, connectors, repeaters, routers, gateways and associated node communication elements by which a given set of communicating devices are interconnected

[IEC 61158-5-X]

NOTE In this document network is used to express that one or more interconnected fieldbus systems with different protocols can be applied.

3.1.33

nested communication

communication using a hierarchy of communication systems

3.1.34

operation

well-defined action that, when applied to any permissible combination of known entities, produces a new entity

[ISO/AFNOR Dictionary of computer science]

3.1.35

parameter

variable that is given a constant value for a specified application and that may denote the application

[ISO/AFNOR Dictionary of computer science]

3.1.36**parameterize**

(see also configure)

setting parameters in a device or a block or an object

3.1.37**persistent data**

stored data that is preserved through shut down/restart and maintenance activities

3.1.38**Process Channel**

representation of process value and its properties

3.1.39**service**

functional capability of a resource, which can be modeled by a sequence of service primitives

[IEC 61499-1]

3.1.40**session**

instance of user interactions within the FDT model

3.1.41**synchronization**

synchronization of data depending on the context where used

NOTE For example, synchronization can occur between the DTM and device or between several DTM instances having a reference to the same instance data.

3.1.42**system**

set of interrelated elements considered in a defined context as a whole and separated from its environment

[IEC 60050-351]

NOTE 1 Such elements may be both material objects and concepts as well as the results thereof (e.g. forms of organization, mathematical methods, and programming languages).

NOTE 2 The system is considered to be separated from the environment and other external systems by an imaginary surface, which can cut the links between them and the considered system.

3.1.43**transient data**

temporary data which have not been stored (while configuring or parameterizing)

3.1.44**type**

software element, which specifies the common attributes shared by all instances of the type

[IEC 61499-1]

3.1.45**variable**

software entity that may take different values, one at a time

[IEC 61499-1]

NOTE 1 The values of a variable are usually restricted to a certain data type.