

INTERNATIONAL STANDARD

ISO
8322-8

First edition
1992-07-01

Building construction — Measuring instruments — Procedures for determining accuracy in use —

Part 8: **STANDARD PREVIEW**

**Electronic distance-measuring instruments up to
150 m**

ISO 8322-8:1992

[https://standards.iteh.ai/catalog/standards/sist/51784c77-0410-4402-acdb-](https://standards.iteh.ai/catalog/standards/sist/51784c77-0410-4402-acdb-4694a03b627e/iso-8322-8-1992)

*Construction immobilière — Instruments de mesure — Procédures de
détermination de l'exactitude d'utilisation —*

*Partie 8: Appareils de mesure de distances à train d'ondes jusqu'à
150 m*

INTERNATIONAL

ISO



Reference number
ISO 8322-8:1992(E)

Contents

	Page
1 Scope	1
2 Normative reference	1
3 General	1
4 Accuracy specification of EDM instruments	2
5 Sources of error	2
6 State of adjustment	4
7 Test procedure for the accuracy in use of EDM instruments ..	4
8 Long-term stability	7

Annexes

A Systematic errors inherent in the instrument	8
A.1 Procedure for the investigation of systematic errors inherent in the instrument	8
A.2 Accuracy in use of the measured distances in clause 7, having applied the zero correction and cyclic correction	9
B Various EDM instruments and their unit lengths	18

<https://standards.iteh.ai/catalog/standards/sist/51784c77-0410-4402-acdb-4694a03b627e/iso-8322-8-1992>

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

International Standard ISO 8322-8 was prepared by Technical Committee ISO/TC 59, *Building construction*, Sub-Committee SC 4, *Limits and fits in building construction*.

ISO 8322 consists of the following parts, under the general title *Building construction — Measuring instruments — Procedures for determining accuracy in use*:

- Part 1: *Theory*
- Part 2: *Measuring tapes*
- Part 3: *Optical levelling instruments*
- Part 4: *Theodolites*
- Part 5: *Optical plumbing instruments*
- Part 6: *Laser instruments*
- Part 7: *Instruments when used for setting out*
- Part 8: *Electronic distance-measuring instruments up to 150 m*
- Part 9: *Electronic distance-measuring instruments up to 500 m*
- Part 10: *Testing short-range reflectors*

Other International Standards for testing measuring instruments for land surveying purposes, and for measuring procedures in ordnance survey, are in preparation.

Annexes A and B of this part of ISO 8322 are for information only.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

This page intentionally left blank

[ISO 8322-8:1992](#)

<https://standards.iteh.ai/catalog/standards/sist/51784c77-0410-4402-acdb-4694a03b627e/iso-8322-8-1992>

Building construction — Measuring instruments — Procedures for determining accuracy in use —

Part 8:

Electronic distance-measuring instruments up to 150 m

1 Scope

This part of ISO 8322 specifies test procedures to be adopted when determining and assessing the accuracy in use of electronic distance-measuring (EDM) equipment on building construction, for distances up to 150 m.

The procedure applies to those types of EDM instruments used for surveying, control and compliance measurements and also when collecting accuracy data.

Annex A gives examples of the determination of systematic errors. Annex B gives the unit lengths of various EDM instruments.

2 Normative reference

The following standard contains provisions which, through reference in this text, constitute provisions of this part of ISO 8322. At the time of publication, the edition indicated was valid. All standards are subject to revision, and parties to agreements based on this part of ISO 8322 are encouraged to investigate the possibility of applying the most recent edition of the standard indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 4463-1:1989, *Measurement methods for building — Setting-out and measurement — Part 1: Planning and organization, measuring procedures, acceptance criteria.*

3 General

3.1 Before commencing surveying, check and compliance measurements, when obtaining accuracy data or setting out, it is important that the operator investigate that the accuracy in use of the measuring equipment is appropriate to the intended measuring task. This International Standard recommends that the operator carry out test measurements under field conditions to establish the accuracy achieved when he uses a particular EDM instrument with a particular prism or combination of prisms.

The procedures assume that the particular EDM instrument and its ancillary equipment are in known and acceptable state of permanent adjustment according to methods detailed in the manufacturers' manuals.

The accuracy in use is expressed in terms of the root mean square errors.

The testing method described in this part of ISO 8322 is carried out on a building site using calibrated steel tapes. The same method can also be applied on baselines, provided that the required distances are available or can be established.

3.2 Figure 1 indicates schematically the decisions to be made when establishing that the accuracy associated with a given surveying method and particular measuring equipment is appropriate to the intended measuring task. Where the contract documentation specifies the required tolerance for the intended measuring task, it is recommended that this tolerance, which is normally given in terms of the permitted deviation $\pm P$ ($P = 2,5\sigma$) of the measuring task, be compared with the accuracy-in-use data obtained either from previous accuracy-in-use

tests or from general data A which indicate the expected accuracy in use of given measuring equipment. On those occasions that the previously obtained data indicate that the accuracy in use associated with the given measuring equipment does not meet the specified permitted deviation of the measuring task, consideration should be given to either selecting a different method and/or a more precise instrument, or discussing with the designer the need for such a small permitted deviation. See ISO 4463-1.

Before the rejection of a particular EDM equipment for a required measuring task, a second series of measurements should be carried out in accordance with clause 7, as indicated in figure 1. If the second result is similar to the first one, the equipment in question should not be used for the required task, unless further investigations in accordance with annex A can identify the main sources of systematic errors inherent in the instrument, and their values.

4 Accuracy specification of EDM instruments

The accuracy of an EDM instrument together with its associated prism is often specified by the manufacturers as the sum (in millimetres) of a constant component a and a distance-related component b :

$$\hat{s} = \pm (a + b \text{ ppm})$$

where \hat{s} is the root mean square error.

EXAMPLE

A manufacturer might specify the accuracy of an instrument by

$$\hat{s} = \pm (3 + 5 \text{ ppm}) \quad \dots (2)$$

or

$$\hat{s} = \pm \left(3 + \frac{5}{10^6} \times d \right) \quad \dots (3)$$

where d is the measured distance, in millimetres.

NOTE 1 The use of parts per million (ppm) has been retained in this International Standard as this is the term which appears on most instruments and in most instruction manuals.

If the manufacturer has not specified the accuracy in the above form he should be requested to do so.

Since in common construction work distances are usually short, i.e. shorter than 150 m, the factor b in the right-hand term of formula (1) is neglected in this part of ISO 8322. For longer distances it should be taken into account (see annex A).

The term a includes:

- the so-called zero error, caused by a lack of coincidence between the mechanical and electro-optical centres of the instrument;
- the cyclic error, a systematic error occurring as a periodic function of the unit length, in general caused by electronic or optical disturbance when transmitted measuring signals are received.

It is essential before the first use of the instrument selected, and periodically thereafter, to verify that the instrument is performing within the manufacturer's specification. The test procedures given in clause 7 are designed to do this with a minimum of additional work.

5 Sources of error

The accuracy in use of an EDM instrument is affected by factors other than the inherent ones of zero, scale and cyclic error. Some of these factors are

- centring errors;
- incorrect pointing;
- insufficient voltage;
- unsuitable signal strength¹⁾;
- neglect of instructions given in the manufacturer's manual;
- error in meteorological data;
- incorrect setting of the meteorological switch;
- changes in the modulation frequency of the unit length;
- other unforeseen factors on site.

Many errors can be reduced by following the correct surveying or maintenance procedures. Other errors are caused by ageing of certain components in the instrument. It is therefore very important to check the instrument frequently.

1) This can be either too low because of, for example, condensation or fog, or too high because of incorrect automatic reduction of the external signal.

Assumptions: P is the permitted deviation of the measuring task

A is the accuracy in use, generally expressed as deviation $\pm A$; (both $\pm P$ and $\pm A$ are considered to include the dimensional variability associated with $\pm 2,5$ times the standard deviation σ)

\hat{s} are the root mean square errors obtained in the field tests




Figure 1 — Flow diagram for accuracy-in-use tests

6 State of adjustment

Before any EDM instrument is used, the requirements given in 6.1 to 6.6 should be observed.

6.1 Instruction manual

Read the instruction manual issued by the manufacturer for the particular EDM instrument.

6.2 Initial warm-up

The warming-up of the instrument shall be carried out in accordance with the instruction manual.

6.3 Frequency

A change in the modulation frequency of the unit length is a cause of change of the scale factor. Frequencies should be verified using a calibrated frequency meter in accordance with national standards prior to delivery and checked from time to time thereafter and before carrying out any field calibration procedure. The accuracy of the frequency meter should be 1×10^{-6} or better.

The determination of the scale factor using long baselines involves the risk that the results will be influenced by undetected meteorological factors.

6.4 Slope reduction

Many EDM instruments can reduce the observed slope distance to the horizontal distance without any manual calculation. The accuracy of this feature can be checked by calculating the horizontal distance using the displayed slope distance and a relevant measured vertical angle. The vertical angle should be greater than 15° (≈ 15 gon).

6.5 Correction for non-coaxial instruments

A vertical separation between the line of collimation of the telescope of the theodolite and that of the EDM instrument affects the reduction of a short slope distance to a horizontal one. The influence depends on the magnitude of the vertical angle and the vertical separation and should be calculated from the values for a specific set of equipment.

6.6 Meteorological corrections

Most EDM instruments have a direct input facility for meteorological data. The accuracy of this feature can be checked by measuring in the following way:

Measure a distance D (preferably about 150 m) with a random value d of the input facility. Immediately

after, measure the same distance with the value $1,000\ 006d$. Repeat the sequence with value d and value $1,000\ 006d$ three times. The means of the sets value d and value $1,000\ 006d$ must differ by $0,000\ 006d$ (i.e. 9 mm for 150 m).

7 Test procedure for the accuracy in use of EDM instruments

The following test procedure shall be adopted for determining the accuracy in use for a particular instrument and its ancillary equipment [especially the prism (reflector) or combination of prisms (reflectors)] to be used before starting work. Changing prisms can introduce additional errors. When setting up EDM equipment for different series of observations, special care shall be taken when centring both the instrument and the prism over the station. Easily achievable accuracies of centring expressed in terms of standard deviation are as follows.

Optical plummet:	0,5 mm (its own state of permanent adjustment shall be checked)
Centring rod:	1 mm
Plumb line:	1 mm to 2 mm (worse in windy weather)

ISO 8322-8:1992-7.1 Measurement of distances

<https://standards.iteh.ai/catalog/standards/sist/51784c77-0410-4402-acdb-4694a03b627e/iso-8322-8-1992-7.1>

7.1.1 Observation procedure

7.1.1.1 Establish a straight line of points in an approximately flat area, as shown in figure 2. The points should be stable for the duration of the procedure including any repeat measurements or further investigations and should be clearly defined.




Figure 2 — Layout of measuring points

The suggested lengths are:

$$AB = 30,5 \text{ m}; AC = 42,5 \text{ m}; AD = 74,5 \text{ m};$$

$$AE = 86,5 \text{ m}; AF = 158 \text{ m.}^{2)}$$

7.1.1.2 Measure each distance twice using a calibrated tape in accordance with national standards corrected for temperature, tension and slope (see table 1-A, columns 3 and 4) or using an EDM instru-

2) To obtain the influence of zero and cyclic error, the distances should be different from those used in annex A.

ment with an accuracy of ± 1 mm. Temperatures should preferably be measured using a contact thermometer.

For example, see No. 1 in column 3: 30,467 m

It is recommended that a 100 m steel tape be used. If a shorter tape is used, special care shall be taken of the reading and position error of each tape length.

7.1.1.3 Centre the instrument over A and measure in accordance with the instruction manual AB, AC, AD, AE and AF three times by keeping the same prism (reflector) or the same combination of prisms (see clause 7) over points B, C, D, E and F in succession. After each series of measurements, a new setting-up of the instrument shall be made.

See table 1-A, columns 6, 7 and 8.

For example, see No. 1, column 6: 30,483 m

7.1.1.4 Centre the instrument over F and measure FA, FB, FC, FD and FE as in 7.1.1.3.

7.1.1.5 Record the relevant measuring conditions and the time of measuring: e.g. temperature, atmospheric pressure, relative humidity.

7.1.2 Calculation procedure

A complete example of the analysis is given in table 1-A (see columns 5, 9, 10 and 11). It is recommended that this form of presentation be generally adopted.

7.1.2.1 Calculate the mean of the tape measurement for each distance AB, AC, ..., AF, in column 5.

For example, see No. 1: 30,466 m

7.1.2.2 Calculate the values for the distances FA, FB, FC from the means of AB, AC, ..., AF.

For example, see No. 8:

$$FC = AF - AC = 158,014 - 42,526 = 115,488 \text{ m}$$

7.1.2.3 The values in column 5 are accepted as true values.

7.1.2.4 Calculate the mean \hat{m} of the three EDM measurements reduced by the vertical angle, temperature and pressure, in column 9.

For example, see No. 1: 30,482 m

7.1.2.5 Calculate the error ε_1 (i.e. $\varepsilon_1 = \hat{m} - \bar{x}$) in column 10 for each distance as the difference: column 9 minus column 5.

For example, see No. 1:

$$30,482 \text{ m} - 30,466 \text{ m} = + 16 \text{ mm}$$

7.1.2.6 Calculate the squares (column 11) of all values in column 10 and the overall sum of squares (column 11).

For example see No. 1: $(+16)^2 = 256 \text{ mm}^2$

The overall sum of the squares = 784 mm²

7.1.2.7 Calculate the root mean square error \hat{s}_1 of a distance measurement by three pointings to the prism (target) or combination of prisms as the square root of the sum of squares divided by 10 (number of observations).

For example, $\hat{s}_1 = \pm \sqrt{784/10} = \pm \sqrt{78,4} \approx 8,9 \text{ mm}$

NOTE 2 In this and the following clauses and in annex A, three different root mean square errors are used:

\hat{s}_1 reflects the accuracy in use directly after the testing on the test line, i.e. without applying any corrections (7.1.2.7 and tables 1-A and 1-B);

\hat{s}_2 after applying the calculated correction for the zero error (A.1.2.4.1 and tables A.4-A and A.4-B);

\hat{s}_3 after applying the calculated corrections for both the zero error and the cyclic error (A.2.2 and tables A.5-A and A.5-B).

The error ε is given subscripts in the same way.

7.1.3 If the calculated root mean square error is too large for the intended task, repeat the whole procedure given in 7.1.1 and 7.1.2. If the second result is similar to the first result, the EDM equipment should not be used for the required task. The necessary steps then to be taken are either to take another instrument or to make further investigations in accordance with annex A in order to identify the main sources of systematic errors inherent in the instrument and their values.

The results of the measurements given in table 1-A indicate that there are systematic errors inherent in the instrument. All values ε_1 have the same sign.

Table 1-A — Example of field observations and calculation

Date:

Location:

Observer:

Instrument:

Conditions: temperature 15 °C, relative humidity 45 %, atmospheric pressure 1 000 mbar, time of measurement 11.30, road surface

Unit length λ of the EDM: 10 m

No.	Dis- tance	Horizontal tape measurement, corrected for temperature and tension		Accepted as true value	EDM measurement reduced for vertical angle, temperature and pressure			Mean	Error	ε_1^2
		m		\bar{x}	m			\hat{m}	ε_1	mm ²
1	2	3	4	5	6	7	8	9	10	11
1	AB	30,467	30,465	30,466	30,483	30,481	30,483	30,482	+ 16	256
2	AC	42,526	42,527	42,526	42,532	42,536	42,535	42,534	+ 8	64
3	AD	74,500	74,500	74,500	74,503	74,505	74,502	74,503	+ 3	9
4	AE	86,494	86,497	86,496	86,504	86,504	86,501	86,503	+ 7	49
5	AF	158,016	158,012	158,014	158,022	158,027	158,024	158,024	+ 10	100
6	FA			158,014	158,026	158,025	158,027	158,026	+ 12	144
7	FB			127,548	127,554	127,552	127,551	127,552	+ 4	16
8	FC			115,488	115,499	115,492	115,495	115,495	+ 7	49
9	FD			83,514	83,520	83,518	83,515	83,518	+ 4	16
10	FE			71,518	71,529	71,524	71,527	71,527	+ 9	81
										$\Sigma = 784$ $\hat{s}_1 = \pm 8,9 \text{ mm}$

Table 1-B — Field observations and calculation

Date:										
Location:										
Observer:										
Instrument:										
Conditions:										
Unit length λ of the EDM:										
No.	Dis- tance	Horizontal tape measurement, corrected for temperature and tension		Accepted as true value	EDM measurement reduced for vertical angle, temperature and pressure			Mean	Error	ε_1^2
		m		m	m			m	mm	mm ²
1	2	3	4	5	6	7	8	9	10	11
1	AB									
2	AC									
3	AD									
4	AE									
5	AF									
6	FA									
7	FB									
8	FC									
9	FD									
10	FE									
										$\Sigma =$ $\hat{\delta}_1 = \pm \text{ mm}$

8 Long-term stability

To obtain an indication of the long-term stability of the components of the measuring equipment, establish a stable measuring station and a stable prism (reflector) station so that the distance is between 300 m and 500 m and the distance is a multiple of the unit length of the EDM instrument plus 1/4 of the unit length. Establish a stable point for the instrument near the office. A stable prism (reflector)

may be fixed to a building (chimneys or similar slender constructions should not be used because of movements caused by sunshine or wind effects). At certain intervals (at least once a month) measure and correct the distance between the established points using meteorological data and record the results. On each occasion three pointings should be made. The comparison of the results against those of earlier measurements will indicate whether the equipment is stable or if readjustment is required.