

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Installation couplers intended for permanent connection in fixed installations

Coupleurs d'installation pour connexions permanentes dans les installations fixes

IEC 61535:2009

<https://standards.iteh.ai/catalog/standards/iec/3eb191c5-bd4f-4b84-98f1-6286c84640b5/iec-61535-2009>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Installation couplers intended for permanent connection in fixed installations

Coupleurs d'installation pour connexions permanentes dans les installations fixes

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

X

ICS 29.120.99

ISBN 978-2-88910-533-5

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references	6
3 Terms and definitions	7
4 General requirements	9
5 General notes on tests	9
6 Ratings.....	10
7 Classification.....	11
7.1 rated impulse voltage:	11
7.2 method of connecting the cable:.....	11
7.3 degree of protection against ingress of foreign solid objects and ingress of water according to IEC 60529 (IP-Code)	11
7.4 location where installation couplers will be installed:.....	11
7.5 existence of an earthing contact:.....	11
7.6 type of conductor to be connected:.....	11
7.7 type of terminals for rewirable installation couplers only:.....	11
8 Marking and documentation.....	12
9 Dangerous compatibility	13
10 Protection against electric shock	14
11 Terminals, terminations and connectable conductors.....	15
11.1 Terminals and terminations.....	15
11.2 Connectable conductors.....	15
12 Construction.....	16
13 Protection against harmful ingress of solid foreign objects and against harmful ingress of water.....	19
13.1 Protection against harmful ingress of foreign solid objects.....	19
13.2 Protection against harmful ingress of water	19
14 Insulation resistance and electric strength.....	20
15 Construction of contacts.....	21
16 Temperature rise.....	22
17 Breaking capacity.....	22
18 Forces necessary to disengage the parts of the installation coupler.....	23
19 Cables and their connection	23
20 Mechanical strength	27
21 Resistance to heat and ageing	28
22 Screws, current-carrying parts and connections.....	30
23 Clearances, creepage distances and distances through solid insulation	32
24 Resistance to abnormal heat and to tracking	33
24.1 Resistance to abnormal heat	33
24.2 Resistance to tracking.....	35
25 Resistance to rusting.....	35
Annex A (normative) Routine Earth (PE) continuity tests.....	37
Annex B (normative) Test circuits for temperature rise test (see Clause 16).....	38

Annex C (normative) Number of sets of test samples used for the tests and sequence of tests for each set	43
Annex D (informative) Guide to use	45
Bibliography.....	47
Figure 1 – Apparatus for testing the cable anchorage	26
Figure 2 – Apparatus for the measuring of the distortion (example).....	27
Figure 3 – Ball-pressure apparatus	29
Figure 4 – Explanation of “small part”	35
Figure B.1 – 1P + N + PE installation couplers, including N (left figure), including PE (right figure).....	38
Figure B.2 – 3P + N + PE installation couplers, 3 phases loaded (left figure), N and PE loaded (right figure)	38
Figure B.3 – 1P + N + PE distribution block, phase and N loaded	39
Figure B.4 – 1P + N + PE distribution block, phase and PE loaded	40
Figure B.5 – 3P + N + PE - to 1P + N + PE distribution block, 3 phases loaded	41
Figure B.6 – 3P + N + PE - to 1P + N + PE distribution block, N and PE loaded.....	42
Figure D.1 – Examples of use of installation couplers.....	46
Table 1 – Voltage rating for installation couplers.....	10
Table 2 – Test currents for installation couplers.....	22
Table 3 – Forces to be applied to cable anchorages	24
Table 4 – Torque applied for the tightening and loosening test.....	31
Table 5 – Installation couplers intended for use in supply systems.....	32
Table 5a – Installation couplers intended for use in supply systems with a maximum voltage to earth of 150 V, rated impulse voltage 2,5 kV.....	32
Table 5b – Installation couplers intended for use in supply systems with a maximum voltage to earth of 300 V, rated impulse voltage 4,0 kV.....	33
Table C.1 – Sets of samples.....	43

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INSTALLATION COUPLERS INTENDED FOR PERMANENT CONNECTION IN FIXED INSTALLATIONS

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61535 has been prepared by technical committee 23: Electrical accessories.

The text of this standard is based on the following documents:

FDIS	Report on voting
23/466/FDIS	23/471/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this standard the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- Explanatory matter: in smaller roman type.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigendum of January 2014 have been included in this copy.

Withdawn

iTech Standards
(<https://standards.itih.ai>)
Document Preview

IEC 61535:2009
<https://standards.itih.ai/standards/iec/3eb191c5-bd4f-4b84-98f1-6286c84640b5/iec-61535-2009>

INSTALLATION COUPLERS INTENDED FOR PERMANENT CONNECTION IN FIXED INSTALLATIONS

1 Scope

This standard applies to two up to five wire installation couplers including earth, if provided, with a rated voltage up to and including 500 V a.c. and a rated connecting capacity up to and including 10 mm² for permanent connection in indoor electrical installations. Installation couplers with additional contacts for voltages other than mains voltages are outside the scope of this standard.

NOTE 1 Installation couplers according to this standard are used e.g. in prefabricated buildings, installation cavities, such as suspended floors and ceilings, or cable tray systems, cable ladder systems, cable ducting systems and cable trunking systems or in commercial show rooms, in partition walls and in any similar application or in furniture complying with IEC 60364-7-713.

NOTE 2 This standard may be used as a guide for installation couplers with additional contacts for voltages other than mains voltages.

NOTE 3 In the UK, where installation couplers have more than 5 wires, they shall meet the requirements of IEC 61535 as though they were included in the scope and shall be tested in such a way that all of the mains voltage pins are subjected to the same level of testing.

NOTE 4 In the USA, these installation couplers are not permitted to be used where they will not be visible after installation.

An installation coupler consists of an installation female connector and an installation male connector for permanent connection not intended to be engaged or disengaged under load nor to be engaged or disengaged other than during first installation or during reconfiguration or maintenance of the wiring system in which installation couplers have been installed. This means that installation couplers are only intended for infrequent use.

Installation couplers are not suitable for use in place of socket-outlet systems. Installation couplers are not suitable for use in place of devices for connecting luminaires (DCLs) according to IEC 61995 or luminaire supporting couplers (LSCs).

NOTE 5 For lower limits of in-service temperatures the necessary information is given in the manufacturer's installation instructions.

In locations where special conditions prevail, as in ships, vehicles and the like and in hazardous locations, for example where explosions are liable to occur, special constructions may be required.

NOTE 6 Particular requirements for installation couplers e.g. for use at higher ambient temperatures, with higher mechanical durability (e.g. metal housings), with higher fire resistance and for use in control circuits (e.g. SELV), are under consideration.

NOTE 7 National rules may have requirements concerning the accessibility of installation couplers.

NOTE 8 Installation couplers are intended to be installed by instructed or skilled persons.

NOTE 9 National rules may specify who is allowed to carry out the connection and disconnection of installation couplers.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-31:2008, *Environmental testing – Part 2-31: Tests - Test Ec: Rough handling shocks, primarily for equipment-type specimens*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60364 (all parts), *Electrical installations of buildings*

IEC 60529:2001, *Degrees of protection provided by enclosures (IP Code)*

IEC 60664-1:2007, *Insulation co-ordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60998-2-3:2002, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-3: Particular requirements for connecting devices as separate entities with insulation-piercing clamping units*

IEC 60999-1:1999, *Connecting devices - Electrical copper conductors - Safety requirements for screw-type and screwless-type clamping units - Part 1: General requirements and particular requirements for clamping units for conductors from 0,2 mm² up to 35 mm² (included)*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

Where the terms "voltage" and "current" are used in this standard, they are r.m.s. values, unless otherwise specified.

3.1

rated voltage

voltage assigned to the installation coupler by the manufacturer

3.2

rated current

maximum current assigned to the installation coupler by the manufacturer

NOTE Rated current refers to the installation coupler itself and not to an electric circuit.

3.3

rated connecting capacity

cross-sectional area of the largest conductor(s) to be connected as stated by the manufacturer of the installation coupler

3.4

permanent connection

connecting method in an installation which is only opened for maintenance or wiring system re-configuration

NOTE The expression "permanent connection" is to be understood as a connection which is maintained as long as an installation exists.

**3.5
installation coupler**

connecting device consisting of an installation female connector and an installation male connector provided with retaining means for permanent connection not intended to be engaged or disengaged under load nor to be engaged or disengaged other than during first installation, during maintenance of the wiring system or during re-configuration of the wiring system

**3.5.1
installation male connector**

load side portion of an installation coupler which contains the male contacts

**3.5.2
installation female connector**

supply side portion of an installation coupler which contains the female contacts

**3.6
installation coupler system**

family of installation couplers consisting of one or more installation female connectors compatible by mechanical coding features with one or more installation male connectors, with the same ratings produced according to the specification of one manufacturer

**3.7
wiring system**

assembly made up of a cable or cables or busbars and the parts which secure and if necessary enclose the cables or busbars

NOTE See IEC 60364-5-52.

**3.8
rewirable installation coupler**

installation coupler so constructed that the cable can be replaced

**3.9
non-rewirable installation coupler**

installation coupler so constructed that it forms a complete unit with the cable after connection and assembly by the manufacturer

NOTE See also 12.15.

**3.9.1
non-rewirable moulded-on installation coupler**

non-rewirable installation coupler so constructed that the contacts, terminals or connections and the attached cable end are surrounded by insulating material manufactured by a moulding process

**3.9.2
non-rewirable non-moulded-on installation coupler**

non-rewirable installation coupler so constructed that the contacts, terminals or connections and the attached cable end are surrounded by separate parts of insulating material

**3.10
distribution block**

device intended for branching of circuits

**3.11
retaining means**

arrangement by which an installation female connector and an installation male connector are held in position when they are properly engaged and prevents unintentional disengagement

NOTE The disengagement may be made by hand or by the use of a tool.

3.12

cap

removable barrier to prevent ready accessibility to an unused installation female connector

3.13

routine test

test to which each device is subjected during and/or after manufacture to ascertain whether it complies with certain criteria

3.14

type test

test of one or more devices made to a certain design to show that the design meets certain requirements

3.15

readily accessible

accessibility to touch extending from any point on a surface where persons usually stand or move about to the limits which a person can reach with the hand, in any direction without assistance

NOTE See IEC 60364-4-41 Annex B.

3.16

terminal

part of an accessory to which a conductor is attached, providing a reusable connection

3.17

termination

part of an accessory to which a conductor is permanently attached

[IEV 442-06-06]

4 General requirements

Installation couplers shall be so designed and constructed that, in normal use, their performance is reliable and without danger to the user or damage to the surroundings.

Compliance is checked by carrying out all the relevant tests specified.

5 General notes on tests

5.1 Tests shall be carried out to check compliance with the relevant requirements of this standard.

Tests are as follows:

- type tests shall be made on representative specimens of each type of installation coupler;
- routine tests shall be made on each installation coupler as required in this standard.

Tests of 5.2 to 5.6 are applicable to type tests and 5.7 to routine tests.

5.2 Unless otherwise specified, the tests shall be carried out on specimens as delivered and under conditions of normal use at an ambient temperature between 15 °C and 35 °C.

Where the value of the temperature is of importance, the test shall be carried out at 20 °C ± 5 °C.

5.3 For testing purposes non-rewirable installation couplers shall be provided with cables of at least 1 m length unless otherwise specified in this standard.

5.4 If not otherwise specified in this standard, the tests shall be carried out in the order of the clauses as specified in Table C.1. Installation male connectors, caps, installation female connectors and distribution blocks shall be tested in connection with their matching counterparts complying with this standard.

5.5 The sets of test specimens shall undergo the tests as specified in Table C.1.

5.6 Specimen are deemed not to comply with this standard if there is more than one specimen failure in any one of the tests.

If one specimen of a given set fails in a test due to an assembly or manufacturing fault, that test and those preceding, which may have influenced the result of that test, are repeated on another set of specimens of the same set number as specified in Table C.1, all of which shall then comply with the repeated tests.

NOTE The applicant may submit, together with the specified number of specimens, the additional set of specimens, which may be required, should one specimen fail. The testing station will then, without further request, test additional specimens and will reject only if a further failure occurs. If the additional set of specimens is not submitted at the same time, the failure of one specimen will entail rejection.

5.7 Routine tests for non-rewirable installation couplers are specified in Annex A.

6 Ratings

6.1 Installation couplers should preferably have a rated voltage chosen from Table 1.

All components of the same installation coupler system shall have the same phase to neutral voltage rating.

Table 1 – Voltage rating for installation couplers

Nominal voltage of power supply system V	Rated voltage V	Rated impulse voltage kV
100	125	2,5
100/200	125/250	2,5
230	250	4,0
230/400	250/400	4,0
277/480	320/500	4,0

6.2 Installation couplers should preferably have a rated current chosen from the following values:

- 10 A
- 16 A
- 20 A
- 25 A
- 32 A

6.3 The preferred values for rated connecting capacities are 1,5 mm², 2,5 mm², 4 mm², 6 mm², 10 mm².

Compliance of 6.1, 6.2 and 6.3 is checked by inspection of markings according to Clause 8.

7 Classification

Installation couplers are classified according to the

7.1 rated impulse voltage:

- 7.1.1 rated impulse voltage of 2,5 kV;
- 7.1.2 rated impulse voltage of 4 kV.

7.2 method of connecting the cable:

- 7.2.1 rewirable installation couplers;
- 7.2.2 non-rewirable installation couplers.

7.3 degree of protection against ingress of foreign solid objects and ingress of water according to IEC 60529 (IP-Code)

7.4 location where installation couplers will be installed:

- 7.4.1 readily accessible installation couplers;
- 7.4.2 non-readily accessible installation couplers.

NOTE 1 Installation couplers for readily accessible areas can also be used in non-readily accessible areas.

7.5 existence of an earthing contact:

- 7.5.1 installation couplers with earthing contact;
- 7.5.2 installation couplers without earthing contact.

7.6 type of conductor to be connected:

- 7.6.1 solid conductor only;
- 7.6.2 rigid (solid and stranded) conductor only;
- 7.6.3 flexible conductor only;
- 7.6.4 both rigid (solid and stranded) and flexible conductors.

7.7 type of terminals for rewirable installation couplers only:

- 7.7.1 installation couplers with screw-type terminals;
- 7.7.2 installation couplers with screwless terminals;
- 7.7.3 installation couplers with insulation piercing terminals.

8 Marking and documentation

8.1 Installation couplers shall be marked with

- a) rated current in amperes (A);
- b) rated voltage in volts (V);
- c) manufacturer's or responsible vendor's name, trade mark or identification mark;
- d) IP-code if higher than IP43 as follows:

The first characteristic numeral for the degree of protection against access to hazardous parts and against harmful effects due to ingress of solid foreign objects shall be marked if declared to be higher than 4, in which case the second characteristic numeral shall also be marked.

The second characteristic numeral for the degree of protection against harmful effects due to ingress of water shall be marked if declared to be higher than 1, in which case the first characteristic numeral shall also be marked.

- e) type reference;
- f) rated connecting capacity for rewirable installation coupler in mm²;
- g) connected conductor size in mm² for non-rewirable installation coupler.

8.2 When symbols or letters are used, they shall be as follows:

rated connecting capacity in square millimetres mm² or □

volts V

amperes A

alternating current ~ or AC

neutral N

earth  or PE

8.3 Markings on the installation coupler according to items in 8.1 shall be readily visible before installation.

8.4 Terminal markings shall be L1, L2, L3 or 1, 2, 3 or equivalent. Earthing terminals in rewirable installation couplers shall have the relevant marking. Neutral terminals shall be marked with N. These markings shall not be placed on screws, removable washers or any other easily removable parts.

If terminals are designed to accept only one type of conductor, e.g. flexible, or rigid (stranded or solid), this shall either be clearly marked on the installation coupler by the letter "f" for flexible or "r" for rigid or "s" for solid or shall be indicated on the smallest packaging unit or in the technical information and catalogue.

8.5 Markings shall be durable and clearly legible.

Compliance is checked by inspection and by the following test:

The marking is rubbed by hand for 15 s with a piece of cloth soaked with water and again for 15 s with a piece of cloth soaked with petroleum spirit.