

INTERNATIONAL STANDARD

NORME INTERNATIONALE

GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-23: Particular requirements and tests for transformers and power supply
units for construction sites**

**Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et des
combinaisons de ces éléments –
Partie 2-23: Règles particulières et essais pour les transformateurs et les blocs
d'alimentation pour chantiers**





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

[IEC 61558-2-23.2010](mailto:IEC.61558-2-23.2010)

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00



IEC 61558-2-23

Edition 2.0 2010-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

GROUP SAFETY PUBLICATION
PUBLICATION GROUPEE DE SÉCURITÉ

**Safety of transformers, reactors, power supply units and combinations thereof –
Part 2-23: Particular requirements and tests for transformers and power supply
units for construction sites**

**Sécurité des transformateurs, bobines d'inductance, blocs d'alimentation et des
combinaisons de ces éléments –
Partie 2-23: Règles particulières et essais pour les transformateurs et les blocs
d'alimentation pour chantiers**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

S

ICS 29.180

ISBN 978-2-88912-162-5

CONTENTS

FOREWORD.....	3
1 Scope.....	5
2 Normative references.....	6
3 Terms and definitions	6
4 General requirements	6
5 General notes on tests.....	7
6 Ratings.....	7
7 Classification	8
8 Marking and other information.....	8
9 Protection against electric shock.....	10
10 Change of input voltage setting	10
11 Output voltage and output current under load	10
12 No-load output voltage	10
13 Short-circuit voltage.....	11
14 Heating.....	11
15 Short-circuit and overload protection.....	12
16 Mechanical strength.....	12
17 Protection against harmful ingress of dust, solid objects and moisture.....	13
18 Insulation resistance, dielectric strength and leakage current	13
19 Construction	13
20 Components	16
21 Internal wiring	16
22 Supply connection and other external flexible cable or cords	16
23 Terminals for external conductors	16
24 Provisions for protective earthing	16
25 Screws and connections	16
26 Creepage distances, clearances and distances through insulation	17
27 Resistance to heat, fire and tracking	17
28 Resistance to rusting	17
Annexes.....	19
Annex L Routine tests (production tests)	19
Bibliography.....	20
Figure 101 – Impact test for horizontal surface	18
Figure 102 – Impact test for vertical surface	18
Table 101 – Ratio of output voltages for safety isolating transformers	11
Table 102 – Ratio of output voltages for isolating transformers	11

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SAFETY OF TRANSFORMERS, REACTORS,
POWER SUPPLY UNITS AND COMBINATIONS THEREOF –****Part 2-23: Particular requirements and tests for transformers
and power supply units for construction sites**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61558-2-23 has been prepared by IEC Technical Committee 96: Transformers, reactors, power supply units, and combinations thereof.

This second edition cancels and replaces the first edition published in 2000. It constitutes a technical revision. The main changes consist of updating this Part 2-23 in accordance with IEC 61558-1:2005.

This part has the status of a group safety publication in accordance with IEC Guide 104: *The preparation of safety publications and the use of basic safety publications and group safety publications*.

The text of this standard is based on the following documents:

FDIS	Report on voting
96/359/FDIS	96/368/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This part is intended to be used in conjunction with the latest edition of IEC 61558-1 and its amendments. It is based on the second edition (2005) of that standard.

This part supplements or modifies the corresponding clauses in IEC 61558-1, so as to convert that publication into the IEC standard: *Particular requirements and tests for transformers and power supply units for construction sites*.

A list of all parts of the IEC 61558 series, under the general title: *Safety of transformers, reactors, power supply units and combinations thereof*, can be found on the IEC website.

Future standards in this series will carry the new general title as cited above. Titles of existing standards in this series will be updated at the time of the next edition.

Where a particular subclause of Part 1 is not mentioned in this part, that subclause applies as far as is reasonable. Where this part states "addition", "modification" or "replacement", the relevant text of Part 1 is to be adapted accordingly.

In this part, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

In the text of this part, the words in **bold** are defined in Clause 3.

Subclauses, notes, figures and tables additional to those in Part 1 are numbered starting from 101; supplementary annexes are entitled AA, BB, etc.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The attention of National Committees is drawn to the fact that equipment manufacturers and testing organizations may need a transitional period following publication of a new, amended or revised IEC publication in which to make products in accordance with the new requirements and to equip themselves for conducting new or revised tests.

It is the recommendation of the committee that the content of this publication be adopted for implementation nationally not earlier than 12 months from the date of publication.

SAFETY OF TRANSFORMERS, REACTORS, POWER SUPPLY UNITS AND COMBINATIONS THEREOF –

Part 2-23: Particular requirements and tests for transformers and power supply units for construction sites

1 Scope

Replacement:

This part of IEC 61558 deals with the safety of **transformers for construction sites** and **power supply units** incorporating **transformers for construction sites**. Transformers incorporating **electronic circuits** are also covered by this standard.

NOTE 1 Safety includes electrical, thermal and mechanical aspects.

Unless otherwise specified, from here onward, the term **transformer** covers **transformers for construction sites** and **power supply units** incorporating **transformers for construction sites**.

This part is applicable to **stationary** or **portable**, single-phase or polyphase, air-cooled (natural or forced) **independent** or **associated transformers, being isolating or safety isolating dry-type transformers** for the use on **construction sites**. The windings may be encapsulated or non-encapsulated.

IEC 61558-2-23:2010

The **rated supply voltage** does not exceed 1 000 V a.c., and the **rated supply frequency** and the **internal operating frequencies** do not exceed 500 Hz.

This standard used in combination with Part 2-16 for **Switch mode power supply units (SMPS)** is also applicable to **power supplies** with **internal operating frequencies** higher than 500 Hz. Where the two requirements are in conflict the most severe take precedence

The **rated output** does not exceed:

- 25 kVA for single-phase **transformers**;
- 40 kVA for poly-phase **transformers**.

This part is applicable to **transformers** without limitation of the **rated output** subject to an agreement between the purchaser and the manufacturer.

NOTE 2 **Transformers** intended to supply distribution networks are not included in the scope.

Isolating transformers and **power supply units** incorporating **isolating transformers for construction sites** have a **no-load output voltage** and a **rated output voltage** exceeding 50 V a.c. and not exceeding 250 V a.c.

Safety isolating transformers and **power supply units** incorporating **safety isolating transformers for construction sites** have a **no-load output voltage** and a **rated output voltage** not exceeding 50 V a.c.

NOTE 3 This standard is applicable to **transformers** for the supply of electricity in locations as specified in IEC 60364-7-704. The latter also specifies the protection by using an earthed midpoint or starpoint of the **output winding**.

Transformers and power supply units covered by this part are used in applications where it is required by the installation rules or by the appliance specification for protection purposes.

When the **transformers** or **power supply units** are incorporated into **low voltage switchgear and controlgear assemblies for construction sites** as specified in IEC 60439-4, the additional requirements of IEC 60439-4 will apply to the assembly.

NOTE 4 For **transformers** filled with liquid dielectric or pulverised material, such as sand, additional requirements are under consideration.

NOTE 5 Attention is drawn to the following:

- measures to protect the **enclosure** and the components inside the **enclosure** against external influences like fungus, vermin, termites, solar-radiation and icing should also be considered;
- the different conditions for transportation, storage, and operation of the **transformers** and **power supply units** should also be considered;
- additional requirements in accordance with other appropriate standards and national rules may be applicable to **transformers** and **power supply units** intended for use in special environments such as tropical environment.

NOTE 6 Future technological development of **transformers** may necessitate a need to increase the upper limit of the frequencies, until then this standard may be used as a guidance document.

2 Normative references

This clause of Part 1 is applicable except as follows:

Addition:

IEC 60068-2-27, *Environmental testing – Part 2-27: Tests – Test Ea and guidance: Shock*
<https://standards.iteh.ai/catalog/standards/sist/7d87539d-e9aa-4a26-b6f5-dae02075a10/iec-61558-2-23-2010>

IEC 60439-4, *Low-voltage switchgear and controlgear assemblies – Part 4: Particular requirements for assemblies for construction sites (ACS)*
<https://standards.iteh.ai/catalog/standards/sist/7d87539d-e9aa-4a26-b6f5-dae02075a10/iec-61558-2-23-2010>

IEC 61558-1:2005, *Safety of power transformers, power supplies, reactors and similar products – Part 1: General requirements and tests*

3 Terms and definitions

This clause of Part 1 is applicable except as follows:

Addition:

3.101

low voltage switchgear and controlgear assembly for construction sites (ACS)

combination of one or several transforming or switching devices with associated control, measuring, signalling, protective and regulating equipment complete with all their internal electrical and mechanical connections and structural parts, designed and built for use on all construction sites, indoors or outdoors.

4 General requirements

This clause of Part 1 is applicable.

5 General notes on tests

This clause of Part 1 is applicable.

6 Ratings

This clause of part 1 is applicable except as follows:

Addition:

6.101 The **rated output voltage** shall not exceed:

- 250 V a.c. for **isolating transformers** with a non-earthed mid-point (single-phase) or a non-earthed star-point (three-phase) or delta connection (three-phase) and for **power supply units** incorporating such **transformers**;
- 110 V a.c. for **isolating transformers** with a mid-point (single-phase) earthed in the construction or a star-point (three-phase) earthed in the construction and for **power supply units** incorporating such **transformers**;
- 50 V a.c. for **safety isolating transformers** and for **power supply units** incorporating **safety isolating transformers**.

The **rated output voltage** shall exceed:

- 50 V a.c. for **isolating transformers** and for **power supply units** incorporating **isolating transformers**.

Preferred values for the **rated output voltage** are

- 110 V and 230 V for **portable, single-phase isolating transformers**;
- 72 V, 110 V and 230 V for other **isolating transformers**;
- 6 V, 12 V, 24 V, 42 V and 48 V for **safety isolating transformers**.

6.102 The **rated output** shall not exceed:

- 25 kVA for single-phase **isolating** and **safety isolating transformers** and **power supply units** incorporating such **transformers**;
- 40 kVA for polyphase **isolating** and **safety isolating transformers** and **power supply units** incorporating such **transformers**;

Preferred values for the **rated output** are

- 25 VA, 40 VA, 63 VA, 100 VA, 160 VA, 250 VA, 400 VA, 630 VA, 1 000 VA, 1 600 VA,
- 2 500 VA, 4 000 VA, 6 300 VA, 10 kVA, 16 kVA and 25 kVA for single-phase **transformers**;
- 630 VA, 1 000 VA, 1 600 VA, 2 500 VA, 4 000 VA, 6 300 VA, 10 kVA, 16 kVA, 25 kVA and 40 kVA for poly-phase **transformers**.

Intermittent duty cycle may be assigned only to **portable transformers** and **power supply units** having a **rated output** not exceeding 6,3 kVA.

6.103 The **rated supply frequency** shall not exceed 500 Hz.

6.104 The **rated supply voltage** shall not exceed 1 000 V a.c.

6.105 **Transformers** with **intermittent duty cycle** shall be intended for a **rated** operating time of 5 min "on" and a resting time of 15 min "off".

6.106 The supply current is limited to a maximum of 125 A, and in the case of flexible cable or socket outlet, to 63 A.

Compliance with 6.101 to 6.106 is checked by inspection of the marking.

7 Classification

This clause of Part 1 is applicable except as follows:

7.5 Replacement:

According to their **duty type**:

- **continuous duty;**
- **intermittent duty cycle.**




8 Marking and other information







This clause of Part 1 is applicable except as follows:

8.1 h) Replacement:

The **transformers** shall be marked with one of the graphical symbols shown in 8.11;

8.11 Addition:

Symbol or graphical symbol	Explanation or title	Identification
	Isolating transformer for construction site, fail-safe	IEC 60417-6010-1
	Isolating transformer for construction site, fail- safe, safety	IEC 60417-6010-2
	Isolating transformer for construction site, fail-safe, mid-point or star-point earthed	IEC 60417-6010-3

Symbol or graphical symbol	Explanation or title	Identification
	Isolating transformer for construction sites, non-short-circuit proof	IEC 60417-6010-4
	Isolating transformer for construction sites, non-short-circuit proof, safety	IEC 60417-6010-5
	Isolating transformer for construction sites, non-short-circuit proof, mid-point or star-point earthed	IEC 60417-6010-6
	Isolating transformer for construction sites, short-circuit proof	IEC 60417-6010-7
	Isolating transformer for construction sites, short-circuit proof, safety	IEC 60417-6010-8
	Isolating transformer for construction sites, short-circuit proof, mid-point or star-point earthed	IEC 60417-6010-9

9 Protection against electric shock

This clause of Part 1 is applicable.

10 Change of input voltage setting

This clause of Part 1 is applicable.

11 Output voltage and output current under load

This clause of Part 1 is applicable.

12 No-load output voltage

This clause of Part 1 is applicable except as follows:

Addition:

12.101 The **no-load output voltage** shall not exceed:

- 250 V a.c. for **isolating transformers** with a non-earthed mid-point (single-phase) or a non-earthed star-point (three-phase) or delta connection (three-phase) and for **power supply units** incorporating such **transformers**;
- 116 V a.c. for **isolating transformers** with a mid-point (single-phase) earthed in the construction or a star-point (three-phase) earthed in the construction and for **power supply units** incorporating such **transformers**;
- 50 V a.c. for **safety isolating transformers** and for **power supply units** incorporating **safety isolating transformers**.

For **independent transformers**, the **no-load output voltage** limitation applies even when **output windings**, not intended for interconnection, are connected in series.

The **no-load output voltage** shall exceed:

- 50 V a.c. for **isolating transformers** and **power supply units** incorporating **isolating transformers**.

12.102 The difference between the **no-load output voltage** and the **output voltage** under load shall not be excessive.

*Compliance with the requirements of 12.101 and 12.102 is checked by measuring the **no-load output voltage** at the **ambient temperature** when the **transformer** is connected to the **rated supply voltage** at the **rated supply frequency**.*

*The difference between the **no-load output voltage** measured in this clause and the **output voltage** under load measured during the test of Clause 11, expressed as a percentage of the latter voltage, shall not exceed the values shown in Table 101 or Table 102.*

NOTE The ratio is defined as follows:
$$\frac{U_{\text{no-load}} - U_{\text{load}}}{U_{\text{load}}} \times 100 \%$$

Table 101 – Ratio of output voltages for safety isolating transformers

Type of transformer Rated output VA	Ratio between no-load output voltage and output voltage under load %
Inherently short-circuit proof transformers:	
-up to and including 63	100
-over 63 up to and including 630	50
-over 630	20
Other transformers:	
-up to and including 10	100
-over 10 up to and including 25	50
-over 25 up to and including 63	20
-over 63 up to and including 250	15
-over 250 up to and including 630	10
-over 630	5

Table 102 – Ratio of output voltages for isolating transformers

Rated output VA	Ratio between no-load output voltage and output voltage under load %
All type of transformers:	
-up to and including 63	100
-over 63 up to and including 250	50
-over 250 up to and including 630	20
-over 630	10
	5

For single phase **transformers** with earthed midpoint, the voltage between any pole of the **output circuit** and earth shall not exceed the $\left(\frac{\text{no - load output voltage}}{2} \right) \pm 2,5 \%$.

For three phase **transformers** with earthed star-point, the voltage between any pole of the **output circuit** and earth shall not exceed the $\left(\frac{\text{no - load output voltage}}{\sqrt{3}} \right) \pm 2,5 \%$.

13 Short-circuit voltage

This clause of Part 1 is applicable.

14 Heating

This clause of Part 1 is applicable.