

INTERNATIONAL
STANDARD

ISO
8573-2

First edition
1996-06-01

Compressed air for general use —

Part 2:

Test methods for aerosol oil content

iTeh STANDARD PREVIEW

(standards.iteh.ai)

Air comprimé pour usage général —

*Partie 2. Méthodes d'essai pour mesurer la teneur en huile présente sous
forme d'aérosols*

<https://standards.iteh.ai/catalog/standards/sist/a523de4f-1e56-429d-8562-afb7f2da23df/iso-8573-2-1996>



Reference number
ISO 8573-2:1996(E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

International Standard ISO 8573-2 was prepared by Technical Committee ISO/TC 118, *Compressors, pneumatic tools and pneumatic machines*, Subcommittee SC 4, *Quality of compressed air*. [ISO 8573-2:1996](https://standards.iteh.ai/catalog/standards/sist/a523de4f-1e56-429d-8562-222020000000/iso-8573-2-1996)

ISO 8573 consists of the following parts, under the general title *Compressed air for general use*:

- Part 1: *Contaminants and quality classes*
- Part 2: *Test methods for aerosol oil content*
- Part 3: *Determination of humidity*
- Part 4: *Determination of solid particles and microbiological contaminants*
- Part 6: *Determination of gaseous contaminants*

Users should note that the titles to future parts 3 to 6 are working titles only and that, while it is at present planned to publish all the parts listed above, one or more may nevertheless be deleted from the work programme before publication, which may, in turn, lead to renumbering of the remaining parts.

Annex A forms an integral part of this part of ISO 8573. Annex B is for information only.

© ISO 1996

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case Postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

Compressed air for general use —

Part 2:

Test methods for aerosol oil content

1 Scope

This part of ISO 8573 specifies test methods for the sampling and quantitative analysis of aerosol oil and liquid oil (excluding oil vapour) typically present in the air discharged from compressors and compressed air systems.

Using the sampling and analysing equipment as described, the accuracy of each method is better than $\pm 10\%$ of the measured value of oil content ranging from $0,001 \text{ mg/m}^3$ to approximately 20 mg/m^3 under Reference Atmosphere conditions¹⁾ (ANR) with varying sampling times.

This part of ISO 8573 gives detailed instructions on the equipment to be used and the test methods to be employed for the measurement of aerosol oil content in a compressed air supply system.

It applies to compressed air systems up to $30 \text{ bar}^{2)}$ working pressure and temperatures of the compressed air below 100 °C , but excluding systems intended to supply compressed air for medical use or for direct breathing.

Two different methods are described, Method A and Method B. Method B is subdivided into two parts to clearly distinguish between procedures for obtaining the quantity of oil for analysis.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this part of ISO 8573. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this part of ISO 8573 are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 65:1981, *Carbon steel tubes suitable for screwing in accordance with ISO 7-1.*

ISO 5167-1:1991, *Measurement of fluid flow by means of pressure differential devices — Part 1: Orifice plates, nozzles and Venturi tubes inserted in circular cross-section conduits running full.*

ISO 8573-1:1991, *Compressed air for general use — Part 1: Contaminants and quality classes.*

3 Definitions

For the purposes of this part of ISO 8573, the definitions given in ISO 8573-1 and the following definition apply.

3.1 wall flow: That proportion of oil contamination no longer suspended within the air flow in the pipe.

1) The air flow is stated at Reference Atmosphere conditions (ANR) of $1\ 000 \text{ mbar}$, 20 °C and 65% relative humidity.

2) $1 \text{ bar} = 10^5 \text{ N/m}^2 = 100 \text{ kPa}$

4 Units

General use of SI units as given throughout this part of ISO 8573 is recommended.

However, in agreement with accepted practice in the pneumatic field, some nonpreferred SI units accepted by ISO are also used; these are given in table 1.

5 Typical sampling points

5.1 General

The test methods may be used at any point in the compressed air system. The choice between Methods A and B depends upon the actual level of oil contamination present in the compressed air system.

Typical conditions at four points in a compressed air system are indicated in 5.2 to 5.4, together with the recommended test method. Figure 1 indicates the positions of typical sampling points. Table 2 presents a guide for selection of the appropriate method.

5.2 Position 1 (see figure 1)

Typical boundary conditions occurring after the compressor/separator at final compressor temperatures:

Oil-flooded rotary compressor: 70 °C to 100 °C, 7 bar to 10 bar

Degree of contamination typical at this point:

Oil mist: 5 mg/m³ to 20 mg/m³ (ANR) in a spectrum of 0,01 µm to 10 µm
 Oil vapour: 5 mg/m³ to 20 mg/m³ (ANR)
 Solid particles: less than 0,1 mg/m³ (ANR)
 Water condensate: none
 Water vapour: unknown

Test method: Method A

iteh STANDARD PREVIEW
 (standards.iteh.ai)

Table 1 — Nonpreferred SI units

Quantity	Unit name	Unit symbol	Definition
Pressure	bar	bar	1 bar = 10 ⁵ Pa
Volume	litre	l	1 l = 10 ⁻³ m ³
Time	minute	min	1 min = 60 s
	hour	h	1 h = 60 min = 3 600 s




Figure 1 — Typical sampling points in the compressed air system

Table 2 — Guide for selection of test method

Parameter	Method		
	A Full flow	B1 Full flow	B2 Partial flow
Contamination range	5 mg/m ³ to 20 mg/m ³	0,001 mg/m ³ to 5 mg/m ³	0,001 mg/m ³ to 5 mg/m ³
Maximum velocity (pipe)	See table 4	See table 4	See table 4
Maximum velocity (filter)	See 6.1.2.2	1 m/s	1 m/s
Maximum diameter of pipe	No limit	DN 25	No limit
Sensitivity	0,5 mg/m ³	0,001 mg/m ³	0,001 mg/m ³
Accuracy	± 10 % of actual value	± 10 % of actual value	± 10 % of actual value
Maximum temperature	100 °C	40 °C	40 °C
Testing time (typical)	50 h to 200 h	2 min to 3 h	2 min to 3 h
Filter construction	Coalescing line filter	Three-layer membrane	Three-layer membrane
Typical sampling points	Compressor outlet	After high-efficiency filters	After high-efficiency filters

5.3 Position 2 (see figure 1)

Typical boundary conditions occurring just after the aftercooler/centrifugal separator:

Operating temperature:	20 °C to 45 °C
Operating pressure:	5 bar to 10 bar
Water condensate:	slight traces
Water vapour:	saturated air
Oil mist:	5 mg/m ³ to 20 mg/m ³ (ANR) in a spectrum of 0,1 µm to 50 µm
Oil vapour:	0,1 mg/m ³ to 2 mg/m ³ (ANR)
Solid particles:	less than 0,1 mg/m ³ (ANR)

Test method: Method A

5.4 Position 3 (see figure 1)

Typical boundary conditions occurring downstream of prefilters and refrigeration dryers:

Operating temperature:	20 °C to 45 °C
Operating pressure:	5 bar to 10 bar
Water condensate:	none
Water vapour:	pressure dew-point 2 °C to 10 °C

Oil mist:

0,5 mg/m³ to 10 mg/m³
(ANR) in a spectrum of
0,01 µm to 5 µm

Oil vapour:

0,1 mg/m³ to 1 mg/m³
(ANR)

Solid particles:

less than 0,1 mg/m³
(ANR)

Test method: Method B

5.5 Position 4 (see figure 1)

Typical boundary conditions occurring downstream from high-efficiency coalescing filters:

Operating temperature:	20 °C to 45 °C
Operating pressure:	5 bar to 10 bar
Water condensate:	none (after dryers)
Water vapour:	pressure dew-point – 70 °C to + 10 °C (after dryers)
Oil mist:	less than 0,1 mg/m ³ (ANR) within the range 0,01 µm to 0,5 µm
Oil vapour:	0,01 mg/m ³ to 1 mg/m ³ (ANR)
Solid particles:	less than 0,01 mg/m ³ (ANR)

Test method: Method B

6 General description of test equipment and method

6.1 Method A

6.1.1 General

This method samples all of the air flow which is passed through two high-efficiency coalescing filters in series, and measures oil in both aerosol and wall flow forms. The equipment and method are designed to operate up to 100 °C.

The method may also be used to determine the amount of aerosol oil present typically in the air discharged from an oil-lubricated compressor when fitted with an air/oil separator. Oil concentrations in the region of 0,5 mg/m³ and above can be determined with an accuracy of ± 10 %. Typically all of the discharged air would be sampled over a time period of 50 h to 200 h. The method is also suitable for long-term testing over several thousand hours.

6.1.2 Test equipment

6.1.2.1 General description

The general arrangement of equipment used in Method A is shown in figure 2 and consists of the following items.

- 1 Compressor
- 2 Air/oil separator(s)
- 3 Separator oil sump
- 4 Discharge pipe
- 5 Oil scavenge return pipe
- 6 Aftercooler (optional)
- 7 Shut-off valve
- 8 "Y" piece (if required)
- 9 High-efficiency sampling filter housing
- 10 Coalescing filter element
- 11 Shut-off valve
- 12 Collecting vessel (transparent)
- 13 Drain valve
- 14 Measuring column
- 15 Differential pressure gauge
- 16 High-efficiency sampling filter housing
- 17 Coalescing filter element
- 18 Shut-off valve
- 19 Collecting vessel (transparent)

- 20 Drain valve
- 21 Measuring column
- 22 Differential pressure gauge
- 23 Pressure gauge
- 24 Flowmeter
- 25 Flow control valve
- 26 Silencer
- 27 Three-way valve
- 28 Discharge pressure gauge
- 29 Measuring column
- 30 Differential pressure gauge
- 31 Temperature gauge (t_1)
- 32 Shut-off valve
- 33 Ambient temperature gauge (t_2)
- 34 Hygrometer
- 35 Temperature gauge

iTeh STANDARD PREVIEW
(standards.iteh.ai)

6.1.2.2 Sampling filter [(9) and (10)]

Sampling filter elements shall be tested for integrity after manufacture and shall meet one of the following specifications:

- Particle penetration according to the dioctyl phthalate (DOP) method (see [1]): below 0,000 5 %.
- Particle penetration according to the NaCl method (see [2]): below 0,000 5 %.

NOTE 1 Filters passing the integrity tests (DOP or NaCl method) cannot be assumed to comply with the maximum oil content level using Method B1 or B2.

Air with entrained aerosol oil and wallflow oil enters the sampling filter housing (9) and flows out through the coalescing filter element (10) which will coalesce the oil into bulk liquid. The bulk liquid drains to the bottom of the housing and into the collecting vessel (12) (via open valve 11) awaiting measurement.

6.1.2.3 Back-up filter (16)

This filter is identical to the sampling filter and will, in the event of malfunction of the sampling filter, collect any oil which has passed through it.




Figure 2 — Apparatus for Test Method A

6.1.2.4 Collecting vessels [(12) and (19)]

Transparent plastic bowls with protective guards are fitted to enable the oil collection to be observed during operation. Shut-off valves (11) and (18) are closed only for removal or draining of collecting vessels and are normally left in the open position.

6.1.2.5 Drain valves [(13) and (20)]

Drain valves are used to drain the liquid contained in collecting vessels (12) and (19); they are normally left in the closed position.

6.1.2.6 Measuring columns [(14) and (21)]

Collected oil is measured in the measuring column(s) (graduated in millilitres).

6.1.2.7 Differential pressure gauges [(15) and (22)]

These gauges determine the pressure drop across the sample and back-up filters.

6.1.2.8 Air flowmeter (24)

A suitable flowmeter is used to determine the air sample volume. Many types are available; an accuracy of better than $\pm 5\%$ of the measured value is necessary. Temperature (35) and pressure (23) gauges are also required to relate measured flow to 1 bar absolute pressure, 20 °C and 65 % relative humidity air (see ISO 2787).

6.1.2.9 Flow control valve (25)

In order to adjust the flow accurately, a valve (25) with fine adjustment is required.

6.1.3 Flow range of test equipment

The equipment described should be capable of handling a flow of 200 l/s (ANR) at an effective (gauge) pressure of 7 bar. For greater flow, multiples of the test equipment can be used or excess air diverted using a "Y" piece (8). The velocity in the "Y" piece shall be matched in the outlet legs to ensure representative sampling. It is necessary to monitor diverted air flow only to determine the total discharge. The test equipment shall operate independently.

6.1.4 Other measurements

The following additional data are essential if the intention is to measure the efficiency of the air/oil separator in the compressor.

6.1.4.1 Temperature

In order to determine performance within a specified temperature range, the temperature is recorded during the entire period of the test. A temperature gauge measures temperature at the inlet. The temperature gauges shall have an accuracy of ± 1 K.

6.1.4.2 Air pressure before sampling filter

The air pressure shall be measured using a pressure gauge. The pressure gauge shall have an accuracy of $\pm 0,25$ % of the maximum scale reading.

6.2 Method B

6.2.1 Method B1 — Full flow sampling

6.2.1.1 General

Method B1 deals with the sampling and analysis of airborne aerosols at constant flowrate.

Within the constraints detailed above, this method permits the quantification of aerosol oil present in a compressed air system, provided wall flow contamination is not present. Air flow is normally diverted through the test equipment via suitable in-line valves which have been previously checked to ensure they do not contribute to the level of oil contamination already present. As this method concerns the measurement of relatively low concentrations of oil in air, particular attention shall be paid to the cleanliness of the test equipment and other precautions shall be taken, e.g. valve purging and stabilization to constant test conditions. Good analytical techniques will help improve the confidence level of the measurements.

The optimum duration of a test measurement may be determined after an initial test to determine the ap-

proximate oil concentration present. When carrying out full flow tests, it is possible to route the air back into the compressed air system, preventing loss of the product. Conversely, it is also possible to vent the flow to the atmosphere. Flow measurement is required to determine the volume of air used during the test, whichever method is adopted. As the test apparatus is portable, different test locations may be chosen, provided the stated parameters are not exceeded and suitable valving for insertion of the test equipment into the circuit exists. Obvious precautions to prevent shock depressurization, which may damage the test filter membrane, or ingress of atmospheric contamination, are necessary. Appropriate physical parameters, e.g. temperature, pressure, flowrate, etc., shall be recorded as stipulated for Method A.

The sampling and analysing equipment used as described give an accuracy of better than ± 10 % over the range from 0,001 mg/m³ to approximately 5 mg/m³ oil content, with sampling times from 30 min to 2 min respectively. The upper limit for the air velocity (at operating pressure) in front of the test membrane is 1 m/s. The test is performed under full flow conditions.

The temperature range should be from 0 °C to 40 °C. If the compressed air temperature is above 40 °C, the oil vapour shall also be taken into account.

Using Method B1, the total air flow passes through the test membrane.

6.2.1.2 Test equipment


The general arrangement of the test equipment is shown in figure 3.

6.2.1.2.1 Membrane

In order to obtain good measuring accuracy, a high-efficiency microfibre glass membrane should be used. To achieve the accuracy specified for this method, three layers of membrane in series and in intimate contact shall be used and the membrane shall meet the following requirements (see table 2):

surface mass:	88,5 g/m ²
pressure drop for air at 0,014 m/s:	23,1 mbar at atmospheric pressure
particle penetration:	below 0,000 5 % (see [2])

To fit the described equipment, the membrane must be circular. A diameter of 55 mm is typically used.

**Key**

- 1 }
4 } Full flow ball-type shut-off valves
5 }
- 2 Membrane holder
3 Valve for evacuating membrane holder
6 Flow control valve
7 Silencer
8 Bypass tube

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 8573-2:1996
<https://standards.iteh.ai/catalog/standards/sist/a523de4f-1e56-429d-8562-afb7f2da23df/iso-8573-2-1996>

Figure 3 — Test equipment for Method B1

6.2.1.2.2 Membrane support

In order to prevent the collection membrane from bursting, a stainless steel sintered disc must be placed as support just behind the membrane. This disc should also be circular and have the same diameter as the membrane. A suitable disc is 3 mm thick and can remove 95 % of all solid particles 40 µm or larger in size.

6.2.1.2.3 Pipes and valves

It is important that the pipe inner diameter, from the connection point in the compressed air system to the membrane holder, is constant and that the inner surface is smooth, to minimize system loss.

The shut-off valve (1) in figure 3 should be of a ball type, and the hole in the ball should have approximately the same diameter as the pipe.

The bypass pipe may consist of a flexible tube.


6.2.1.2.4 Membrane holder

A general diagram of a typical membrane holder is shown in figure 4.

6.2.1.2.5 Construction materials

Aluminium and its alloys shall not be used for any components which may come into contact with solvents.

Dimensions in millimetres



Crevice-free dairy joint to suit probe
 iTeh STANDARD PREVIEW
 (standards.iteh.ai)

A
 Typical crevice-free joint
 (seal and joint not shown)





Figure 4 — Typical membrane holder

6.2.2 Method B2 — Partial flow sampling

Method B2 uses the same test equipment employed in Method B1, with the addition of a sampling probe to allow partial flow sampling under isokinetic conditions from the main pipe flow should the velocity constraints of Method B1 be exceeded. Accuracy and limitations are as stated in Method B1.

The sampling probe may be inserted into any section of the pipe, using suitable connections and valves, and allows a sample of air to be taken from the main pipe flow under identical velocity conditions. Both main pipe flow and sample flows need to be known to define the test conditions. The probe may be inserted to an approximately central position across the main pipe diameter, and it is recommended that a number of preliminary tests be made. The design of the test membrane holder and probe allows back-flushing with solvent to remove any contamination deposited on the walls of the holder or probe to ensure it is included in the analysis.

It is also possible to leave the probe in position and analyse the oil deposited on the membrane and holder by using suitable in-line valves only. This allows the main pipe system to remain pressurized while analysis is performed and also permits intermittent tests to be carried out over a period of time. The pressure seals used in the probe/holder connectors must not release any hydrocarbon into solution when immersed in the analysing solvent. It is impractical to return the sample flow to the main pipe flow downstream from the membrane holder, and it is usual to vent this flow to atmosphere.

At very low oil concentrations (0,01 mg/m³ and below) the recommended sampling time is 1 h to 3 h.

6.2.2.1 Isokinetic sampling — General

For sampling from high flow systems, isokinetic sampling may be used when wall flow is not present (e.g. below 5 mg/m³ total aerosol oil content).

Accurate isokinetic sampling is not critical for small particles (less than 1 µm), although approximate isokinetic conditions are advisable.

Isokinetic sampling devices should exhibit the following characteristics:

- a) The probe should be a minimum distance of 10 pipe diameters from upstream bends or restrictions and 3 diameters from downstream bends or restrictions (see reference [3]).

- b) The size of the probe should not influence the airstream. The nozzles may vary in shape and construction.
- c) Impaction onto the internal surface of the probe should be taken into account. Precautions are necessary to prevent surface condensation of oil vapours unless the internal surfaces are washed with solvent.
- d) Under the test conditions specified, scanning across the pipe with a sampling probe is unnecessary.
- e) Turbulent flow conditions within the main airstream are required for sampling (Reynolds number greater than 4 000).

In normal industrial use, compressed air is in a state of turbulent flow, which occurs when the following conditions are met:

$$Q > d/20$$

where

Q is the pipe flow, in litres per second (ANR);

d is the pipe bore, in millimetres.

6.2.2.2 Equipment set-up for isokinetic sampling

The experimental set-up for isokinetic sampling comprises the following elements (see figure 5):

- 1 Probe
- 2 Nozzle with gland
- 3 Membrane holder with vent valve
- 4 Full-flow ball valve

The ball valve (4) and flowmeter (5) allow adjustment and measurement of full pipe flow, respectively.

6.2.2.3 Design of the isokinetic probe

The general construction of the probe is shown in figure 6 and is intended for use with pipe velocities up to 15 m/s and sampling flowrates up to 3 l/s when used with a suitable membrane holder designed for a 55 mm diameter standard disc.

The probe should be of circular cross-section, the open end having a thickness of less than 1,3 mm and the internal and external surfaces having an inclination not greater than 30° to the axis of the nozzle (figure 6) (see references [5] and [7]).