

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 5-15: Application layer service definition – Type 15 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-15: Définition des services de la couche application – Éléments de
Type 15**

IEC 61158-5-15:2007

<https://standards.iteh.ai/Catalogue/standards/iec/05/042fd-9d74-4ccd-af17-e345d099c66e/iec-61158-5-15-2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 14 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 55 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 14 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 55 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 5-15: Application layer service definition – Type 15 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 5-15: Définition des services de la couche application – Éléments de
Type 15**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

XF

ICS 25.040.40; 35.100.70

ISBN 978-2-8322-1557-9

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview.....	8
1.2 Specifications.....	9
1.3 Conformance.....	9
1.4 Type overview.....	9
2 Normative references.....	10
3 Terms and definitions, abbreviations, symbols and conventions.....	10
3.1 Terms and definitions.....	10
3.2 Abbreviations and symbols.....	18
3.3 Conventions.....	19
4 Concepts.....	23
4.1 Common concepts.....	23
4.2 Client/server specific concepts.....	23
4.3 Publish/subscribe specific concepts.....	31
5 Data type ASE.....	40
5.1 General.....	40
5.2 Formal definition of data type objects.....	40
5.3 FAL defined data types.....	40
5.4 Data type ASE service specification.....	53
6 Client/server communication model specification.....	54
6.1 ASEs.....	54
6.2 ARs.....	113
6.3 Summary of FAL classes.....	115
6.4 Permitted FAL services by AREP role.....	116
7 Publish/subscribe communication model specification.....	117
7.1 ASEs.....	117
7.2 ARs.....	136
7.3 Summary of FAL classes.....	138
7.4 Permitted FAL services by AREP role and sub-role.....	138
Bibliography.....	139
Figure 1 – Client/server stacks.....	23
Figure 2 – Client/server communication on different buses or networks.....	23
Figure 3 – Client/server APOs services conveyed by the FAL.....	24
Figure 4 – [INFORMATIVE] Interpretation as distinct tables.....	25
Figure 5 – [INFORMATIVE] Interpretation as overlapping tables.....	26
Figure 6 – [INFORMATIVE] APO and real objects, non obvious possible interpretation.....	26
Figure 7 – ASE service conveyance.....	28
Figure 8 – Client/server confirmed interaction.....	29
Figure 9 – Client/server AR confirmed service primitives (positive case).....	30
Figure 10 – Client/server AR confirmed service primitives (negative case).....	30
Figure 11 – Client/server unconfirmed interaction.....	31

Figure 12 – Client/server AR unconfirmed service primitives	31
Figure 13 – Publish/subscribe communications stacks	32
Figure 14 – Publish/subscribe data-centric exchanges between decoupled network objects	33
Figure 15 – Publish/subscribe APOs services conveyed by the FAL	34
Figure 16 – [INFORMATIVE] Examples of publish/subscribe configurable behaviors via QoS	35
Figure 17 – Pull model interactions	37
Figure 18 – Push model interactions	38
Figure 19 – Publish/subscribe model interactions	39
Figure 20 – FAL ASEs	55
Figure 21 – Client/server encapsulated interface mechanism	102
Figure 22 – Publish/subscribe class derivations and relationships	117
Figure 23 – FAL ASEs and classes	118
Figure 24 – Publish/subscribe service request composition	128
Table 1 – Common client/server APOs	25
Table 2 – Class identification	48
Table 3 – Assigned vendor IDs	49
Table 4 – Filter service parameters	57
Table 5 – Read discretes service parameters	59
Table 6 – Read coils service parameters	63
Table 7 – Write single coil service parameters	64
Table 8 – Write multiple coils service parameters	66
Table 9 – Broadcast write single coil service parameters	67
Table 10 – Broadcast write multiple coils service parameters	68
Table 11 – Read input registers service parameters	71
Table 12 – Read holding registers service parameters	76
Table 13 – Write single holding register service parameters	78
Table 14 – Write multiple holding registers service parameters	79
Table 15 – Mask write holding register service parameters	81
Table 16 – Read/write holding registers service parameters	83
Table 17 – Read FIFO service parameters	85
Table 18 – Broadcast write single holding register service parameters	86
Table 19 – Broadcast write multiple holding registers service parameters	87
Table 20 – Read file service parameters	94
Table 21 – Write file service parameters	98
Table 22 – Device identification categories	104
Table 23 – Read device ID code	105
Table 24 – Conformity level	106
Table 25 – Requested vs. returned known objects	107
Table 26 – Read device identification service parameters	109
Table 27 – FAL class summary	115
Table 28 – Services by AREP role	116

Table 29 – Issue service parameters	120
Table 30 – Heartbeat service parameters.....	121
Table 31 – VAR service parameters	123
Table 32 – VAR service parameters	125
Table 33 – ACK service parameters	127
Table 34 – Header service parameters	130
Table 35 – INFO_DST service parameters	131
Table 36 – INFO_REPLY service parameters.....	132
Table 37 – INFO_SRC service parameters.....	134
Table 38 – INFO_TS service parameters	135
Table 39 – PAD service parameters	136
Table 40 – FAL class summary	138
Table 41 – Services by AREP role and sub-role	138

Withdrawing

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61158-5-15:2007](https://standards.iteh.ai/standards/iec/05/042fd-9d74-4ecc-af17-e345d099c66e/iec-61158-5-15-2007)

<https://standards.iteh.ai/standards/iec/05/042fd-9d74-4ecc-af17-e345d099c66e/iec-61158-5-15-2007>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –****Part 5-15: Application layer service definition – Type 15 elements**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the IEC 61784 series. Use of the various protocol types in other combinations may require permission of their respective intellectual-property-right holders.

International Standard IEC 61158-5-15 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This bilingual version (2014-06) corresponds to the English version, published in 2007-12.

This first edition and its companion parts of the IEC 61158-5 subseries cancel and replace IEC 61158-5:2003. This edition of this part constitutes a technical revision. This part and its Type 15 companion parts also cancel and replace IEC/PAS 62030, published in 2004.

This edition of IEC 61158-5 includes the following significant changes from the previous edition:

- a) deletion of the former Type 6 fieldbus for lack of market relevance;
- b) addition of new types of fieldbuses;
- c) partition of part 5 of the third edition into multiple parts numbered -5-2, -5-3, ...

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/475/FDIS	65C/486/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under <http://webstore.iec.ch> in the data related to the specific publication . At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

NOTE The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

The list of all the parts of the IEC 61158 series, under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

Withholding

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

IEC 61158-5-15:2007
<https://standards.iteh.ai/Catalogue/standards/iec/05/042fd-9d74-4ccd-af17-e345d099c66e/iec-61158-5-15-2007>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 5-15: Application layer service definition – Type 15 elements

1 Scope

1.1 Overview

In network communications, as in many fields of engineering, it is a fact that “one size does not fit all.” Engineering design is about making the right set of trade-offs, and these trade-offs must balance conflicting requirements such as simplicity, generality, ease of use, richness of features, performance, memory size and usage, scalability, determinism, and robustness. These trade-offs must be made in light of the types of information flow (e.g. periodic, one-to-many, request-reply, events), and the constraints imposed by the application and execution platforms.

The Type 15 fieldbus provides two major communication mechanisms that complement each others to satisfy communication requirements in the field of automation: the Client/Server and the Publish/Subscribe paradigms. They can be used concurrently on the same device.

Type 15 Client/Server operates in a Client/Server relationship. Its application layer service definitions and protocol specifications are independent of the underlying layers, and have been implemented on a variety of stacks and communication media, including EIA/TIA-232, EIA/TIA-422, EIA/TIA-425, HDLC (ISO 13239), fiber, TCP/IP, Wireless LANs and Radios.

Type 15 Publish/Subscribe operates in a Publish/Subscribe relationship. Its application layer service definitions and protocol specifications are independent of the underlying layers and can be configured to provide reliable behaviour and support determinism. The most common stack is UDP/IP.

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This part of IEC 61158 provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 15 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This part of IEC 61158 define in an abstract way the externally visible service provided by the Type 15 fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service,
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this part of IEC 61158 is to define the services provided to

- 1) the FAL user at the boundary between the user and the Application Layer of the Fieldbus Reference Model, and

2) Systems Management at the boundary between the Application Layer and Systems Management of the Fieldbus Reference Model.

This part of IEC 61158 specifies the structure and services of the Type 15 IEC fieldbus Application Layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI Application Layer Structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented Application Service Elements (ASEs) and a Layer Management Entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can send/receive is specified. This permits greater flexibility to the FAL users in standardizing such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

1.2 Specifications

The principal objective of this part of IEC 61158 is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal Application Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This part of IEC 61158 does not specify individual implementations or products, nor do they constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the Type 15 application layer services as defined in this part of IEC 61158.

1.4 Type overview

In network communications, as in many fields of engineering, it is a fact that “one size does not fit all.” Engineering design is about making the right set of trade-offs, and these trade-offs must balance conflicting requirements such as simplicity, generality, ease of use, richness of features, performance, memory size and usage, scalability, determinism, and robustness. These trade-offs must be made in light of the types of information flow (e.g. periodic, one-to-

many, request-reply, events), and the constraints imposed by the application and execution platforms.

The Type 15 fieldbus provides two major communication mechanisms that complement each others to satisfy communication requirements in the field of automation: the Client/Server and the Publish/Subscribe paradigms. They can be used concurrently on the same device.

Type 15 Client/Server operates in a Client/Server relationship. Its application layer service definitions and protocol specifications are independent of the underlying layers, and have been implemented on a variety of stacks and communication media, including EIA/TIA-232, EIA/TIA-422, EIA/TIA-425, HDLC (ISO 13239), fiber, TCP/IP, Wireless LANs and Radios.

Type 15 Publish/Subscribe operates in a Publish/Subscribe relationship. Its application layer service definitions and protocol specifications are independent of the underlying layers and can be configured to provide reliable behavior and support determinism. The most common stack is UDP/IP.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC/TR 61158-1 (Ed.2.0), *Industrial communication networks – Fieldbus specifications – Part 1: Overview and guidance for the IEC 61158 and IEC 61784 series*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 1: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824, *Information technology – Open Systems Interconnection – Specification of Abstract Syntax Notation One (ASN.1)*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

3 Terms and definitions, abbreviations, symbols and conventions

3.1 Terms and definitions

For the purposes of this document, the following terms as defined in these publications apply:

3.1.1 ISO/IEC 7498-1 terms

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation

- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 ISO/IEC 8822 terms

- a) abstract syntax
- b) presentation context

3.1.3 ISO/IEC 9545 terms

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.1.4 ISO/IEC 8824 terms

- a) object identifier
- b) type

3.1.5 IEC/TR 61158-1 terms

The following IEC/TR 61158-1 terms apply.

3.1.5.1 application

function or data structure for which data is consumed or produced

3.1.5.2 application layer interoperability

capability of application entities to perform coordinated and cooperative operations using the services of the FAL

3.1.5.3 application object

object class that manages and provides the run time exchange of messages across the network and within the network device

NOTE: Multiple types of application object classes may be defined.

3.1.5.4 application process

part of a distributed application on a network, which is located on one device and unambiguously addressed

3.1.5.5 application process identifier

distinguishes multiple application processes used in a device

3.1.5.6 application process object

component of an application process that is identifiable and accessible through an FAL application relationship

NOTE Application process object definitions are composed of a set of values for the attributes of their class.

3.1.5.7 application process object class

class of application process objects defined in terms of the set of their network-accessible attributes and services

3.1.5.8 application relationship

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation

NOTE This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities.

3.1.5.9 application relationship endpoint

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

NOTE Each application process involved in the application relationship maintains its own application relationship endpoint.

3.1.5.10 application service element

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.1.5.11 attribute

description of an externally visible characteristic or feature of an object

NOTE The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behaviour of an object. Attributes are divided into class attributes and instance attributes.

3.1.5.12 behavior

indication of how the object responds to particular events

NOTE Its description includes the relationship between attribute values and services.

3.1.5.13 class

set of objects, all of which represent the same kind of system component

NOTE A class is a generalization of the object; a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

3.1.5.14 class attributes

attribute that is shared by all objects within the same class

3.1.5.15 class code

unique identifier assigned to each object class

3.1.5.16 class specific service

service defined by a particular object class to perform a required function which is not performed by a common service