

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 6-18: Application layer protocol specification – Type 18 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 6-18: Spécification des protocoles des couches d'application – Éléments
de Type 18**

IEC 61158-6-18:2007

<https://standards.iteh.ai/standards/iec/1785618e-c572-4d87-b481-0f5565e3304a/iec-61158-6-18-2007>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2007 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 6-18: Application layer protocol specification – Type 18 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 6-18: Spécification des protocoles des couches d'application – Éléments
de Type 18**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 25.04.40; 35.100.70; 35.110

ISBN 978-2-8322-2984-2

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 Scope.....	8
1.1 General	8
1.2 Specifications	8
1.3 Conformance	8
2 Normative references	9
3 Terms and definitions	9
3.1 Terms and definitions from other ISO/IEC standards.....	9
3.2 Other terms and definitions	10
3.3 Abbreviations and symbols	19
3.4 Additional abbreviations and symbols for decentralized periphery	19
3.5 Conventions.....	21
4 Abstract syntax.....	21
4.1 M1 device manager PDU abstract syntax.....	21
4.2 M2 device manager PDU abstract syntax.....	21
4.3 S1 device manager PDU abstract syntax	22
4.4 S2 device manager PDU abstract syntax	22
4.5 M1 connection manager PDU abstract syntax.....	22
4.6 M2 connection manager PDU abstract syntax.....	23
4.7 S1 connection manager PDU abstract syntax.....	24
4.8 S2 connection manager PDU abstract syntax.....	24
4.9 M1 cyclic transmission PDU abstract syntax.....	24
4.10 M2 cyclic transmission PDU abstract syntax	25
4.11 S1 cyclic transmission PDU abstract syntax	25
4.12 S2 cyclic transmission PDU abstract syntax	26
5 Transfer syntax.....	26
5.1 M1 device manager PDU encoding	26
5.2 M2 device manager PDU encoding	28
5.3 S1 device manager PDU encoding.....	29
5.4 S2 device manager PDU encoding.....	30
5.5 M1 connection manager PDU encoding.....	31
5.6 M2 connection manager PDU encoding.....	35
5.7 S1 connection manager PDU encoding	35
5.8 S2 connection manager PDU encoding	36
5.9 M1 cyclic transmission PDU encoding.....	37
5.10 M2 cyclic transmission PDU encoding	38
5.11 S1 cyclic transmission PDU encoding.....	39
5.12 S2 cyclic transmission PDU encoding.....	40
5.13 Acyclic transmission PDU encoding.....	41
6 Structure of FAL protocol state machines	49

7	AP-context state machine	50
8	FAL service protocol machine (FSPM)	50
8.1	Overview	50
8.2	FAL service primitives	50
9	AR protocol machine (ARPM)	51
9.1	Overview	51
9.2	M1 master ARPM	51
9.3	M2 master ARPM	56
9.4	Slave ARPM	59
10	DLL mapping protocol machine (DMPM)	62
10.1	Overview	62
10.2	Primitives received from the ARPM	62
10.3	Indications received from the DL	62
	Bibliography	63
	Figure 1 – Parameter block 1 command parameter field	43
	Figure 2 – Parameter block 2 command parameter field	44
	Figure 3 – Relationships among protocol machines and adjacent layers	49
	Figure 4 – ARPM M1 master AR state diagram	52
	Figure 5 – ARPM M2 master AR state diagram	56
	Figure 6 – ARPM slave AR state diagram	59
	Table 1 – M1 device manager attribute format	21
	Table 2 – M2 device manager attribute format	22
	Table 3 – S1 device manager attribute format	22
	Table 4 – S2 device manager attribute format	22
	Table 5 – M1 connection manager attribute format	23
	Table 6 – M2 connection manager attribute format	24
	Table 7 – S1 connection manager attribute format	24
	Table 8 – S2 connection manager attribute format	24
	Table 9 – M1 cyclic transmission attribute format	25
	Table 10 – M2 cyclic transmission attribute format	25
	Table 11 – S1 cyclic transmission attribute format	25
	Table 12 – S2 cyclic transmission attribute format	26
	Table 13 – M1 device manager attribute encoding	27
	Table 14 – M2 device manager attribute encoding	29
	Table 15 – S1 device manager attribute encoding	30
	Table 16 – S2 device manager attribute encoding	31
	Table 17 – M1 connection manager attribute encoding	31
	Table 18 – M2 connection manager attribute encoding	35
	Table 19 – S1 connection manager attribute encoding	36
	Table 20 – S2 connection manager attribute encoding	36
	Table 21 – M1 cyclic transmission attribute encoding	37

Table 22 – M2 cyclic transmission attribute encoding 39

Table 23 – S1 cyclic transmission attribute encoding 39

Table 24 – S2 cyclic transmission attribute encoding 41

Table 25 – Acyclic transmission – message data encoding 41

Table 26 – Command header format 42

Table 27 – Command codes 42

Table 28 – System information command parameter field 45

Table 29 – System information command parameter field 45

Table 30 – System information command parameter field 45

Table 31 – System information command parameter field 46

Table 32 – Line test command parameter field 46

Table 33 – Memory read command parameter field 47

Table 34 – Memory write command parameter field 48

Table 35 – FSPM events 51

Table 36 – M1 master state-event table 1 – events 54

Table 37 – M1 master state-event table 2 – receipt of FSPM service primitives 54

Table 38 – M1 master state-event table 3 – receipt of DMPM service primitives 56

Table 39 – M2 master state-event table 1 – events 57

Table 40 – M2 master state-event table 2 – receipt of FSPM service primitives 58

Table 41 – M2 master state-event table 3 – receipt of DMPM service primitives 58

Table 42 – S1 connect monitoring time 60

Table 43 – S2 connect monitoring time 60

Table 44 – Slave state-event table 1 – events 61

Table 45 – Slave state-event table 2 – receipt of FSPM service primitives 61

Table 46 – Slave state-event table 3 – receipt of DMPM service primitives 61

Table 47 – ARPM to DL mapping 62

Table 48 – DL to ARPM mapping 62

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS –
FIELDBUS SPECIFICATIONS –

Part 6-18: Application layer protocol specification – Type 18 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in Type combinations as specified explicitly in the IEC 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

IEC draws attention to the fact that it is claimed that compliance with this standard may involve the use of patents as follows, where the [xx] notation indicates the holder of the patent right:

Type 18:

3343036/Japan	[MEC]	"Network System for a Programmable Controller"
5896509/USA	[MEC]	"Network System for a Programmable Controller"
246906/Korea	[MEC]	"Network System for a Programmable Controller"
Pending/Germany	[MEC]	"Network System for a Programmable Controller"

IEC takes no position concerning the evidence, validity and scope of these patent rights.

The holders of these patent rights have assured IEC that they are willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holders of these patent rights are registered with IEC. Information may be obtained from:

[MEC] Mitsubishi Electric Corporation
Corporate Licensing Division
7-3, Marunouchi 2-chome, Chiyoda-ku,
Tokyo 100-8310, Japan

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61158-6-18 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial-process measurement, control and automation.

This first edition and its companion parts of the IEC 61158-6 subseries cancel and replace IEC 61158-6:2003. This edition of this part constitutes a technical addition.

This edition of IEC 61158-6 includes the following significant changes from the previous edition:

- a) deletion of the former Type 6 fieldbus for lack of market relevance;
- b) addition of new types of fieldbuses;
- c) partition of part 6 of the third edition into multiple parts numbered -6-2, -6-3, ...

This bilingual version (2015-10) corresponds to the English version published in 2007-12.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/476/FDIS	65C/487/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under <http://webstore.iec.ch> in the data related to the specific publication. At this date, the publication will be:

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

NOTE The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

The list of all the parts of the IEC 61158 series, under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application protocol provides the application service by making use of the services available from the data-link or other immediately lower layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer application entities (AEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- as a guide for implementors and designers;
- for use in the testing and procurement of equipment;
- as part of an agreement for the admittance of systems into the open systems environment;
- as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

iTech Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC 61158-6-18:2007](https://standards.iteh.ai/standards/iec/17256f8e-c572-4d87-b481-0f5565e3304a/iec-61158-6-18-2007)

<https://standards.iteh.ai/standards/iec/17256f8e-c572-4d87-b481-0f5565e3304a/iec-61158-6-18-2007>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 6-18: Application layer protocol specification – Type 18 elements

1 Scope

1.1 General

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 18 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard specifies interactions between remote applications and defines the externally visible behavior provided by the Type 18 fieldbus application layer in terms of

- a) the formal abstract syntax defining the application layer protocol data units conveyed between communicating application entities;
- b) the transfer syntax defining encoding rules that are applied to the application layer protocol data units;
- c) the application context state machine defining the application service behavior visible between communicating application entities;
- d) the application relationship state machines defining the communication behavior visible between communicating application entities.

The purpose of this standard is to define the protocol provided to

- 1) define the wire representation of the service primitives defined in IEC 61158-5-18, and
- 2) define the externally visible behavior associated with their transfer.

This standard specifies the protocol of the Type 18 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI application layer structure (ISO/IEC 9545).

1.2 Specifications

The principal objective of this standard is to specify the syntax and behavior of the application layer protocol that conveys the application layer services defined in IEC 61158-5-18.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of protocols standardized in the IEC 61158-6 series.

1.3 Conformance

This standard does not specify individual implementations or products, nor do they constrain the implementations of application layer entities within industrial automation systems.

Conformance is achieved through implementation of this application layer protocol specification.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61158-5-18, *Industrial communication networks – Fieldbus specifications – Part 5-18: Application layer service definition – Type 18 elements*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model – Part 1: The Basic Model*

ISO/IEC 8822, *Information technology – Open Systems Interconnection – Presentation service definition*

ISO/IEC 8824, *Information technology – Open Systems Interconnection – Specification of Abstract Syntax Notation One (ASN.1)*

ISO/IEC 9545, *Information technology – Open Systems Interconnection – Application Layer structure*

3 Terms and definitions

3.1 Terms and definitions from other ISO/IEC standards

3.1.1 ISO/IEC 7498-1 terms

For the purposes of this document, the following terms as defined in ISO/IEC 7498-1 apply:

- a) application entity
- b) application process
- c) application protocol data unit
- d) application service element
- e) application entity invocation
- f) application process invocation
- g) application transaction
- h) real open system
- i) transfer syntax

3.1.2 ISO/IEC 8822 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8822 apply:

- a) abstract syntax
- b) presentation context

3.1.3 ISO/IEC 9545 terms

For the purposes of this document, the following terms as defined in ISO/IEC 9545 apply:

- a) application-association
- b) application-context
- c) application context name
- d) application-entity-invocation
- e) application-entity-type
- f) application-process-invocation
- g) application-process-type
- h) application-service-element
- i) application control service element

3.1.4 ISO/IEC 8824 terms

For the purposes of this document, the following terms as defined in ISO/IEC 8824 apply:

- a) object identifier
- b) type

3.2 Other terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.2.1

active connection control object

instance of a certain FAL class that abstracts the interconnection facility (as Consumer and Provider) of an automation device

3.2.2

alarm

activation of an event that shows a critical state

3.2.3

alarm ack

acknowledgment of an event that shows a critical state

3.2.4

alarm data object

object(s) which represent critical states referenced by device/slot/subslot/alarm type

3.2.5

allocate

take a resource from a common area and assign that resource for the exclusive use of a specific entity

3.2.6

application

function or data structure for which data is consumed or produced

3.2.7

application layer interoperability

capability of application entities to perform coordinated and cooperative operations using the services of the FAL

3.2.8

application objects

multiple object classes that manage and provide a run time exchange of PDUs across the network and within the network device

3.2.9**application process**

part of a distributed application on a network, which is located on one device and unambiguously addressed

3.2.10**application process identifier**

distinguishes multiple application processes used in a device

NOTE Application process identifier is assigned by PROFIBUS International (PI).

3.2.11**application process object**

component of an application process that is identifiable and accessible through an FAL application relationship

NOTE Application process object definitions are composed of a set of values for the attributes of their class (see the definition for Application Process Object Class Definition). Application process object definitions may be accessed remotely using the services of the FAL Object Management ASE. FAL Object Management services can be used to load or update object definitions, to read object definitions, and to dynamically create and delete application objects and their corresponding definitions.

3.2.12**application process object class**

a class of application process objects defined in terms of the set of their network-accessible attributes and services

3.2.13**application relationship**

cooperative association between two or more application-entity-invocations for the purpose of exchange of information and coordination of their joint operation. This relationship is activated either by the exchange of application-protocol-data-units or as a result of preconfiguration activities

3.2.14**application relationship application service element**

application-service-element that provides the exclusive means for establishing and terminating all application relationships

3.2.15**application relationship endpoint**

context and behavior of an application relationship as seen and maintained by one of the application processes involved in the application relationship

NOTE Each application process involved in the application relationship maintains its own application relationship endpoint.

3.2.16**attribute**

description of an externally visible characteristic or feature of an object

NOTE The attributes of an object contain information about variable portions of an object. Typically, they provide status information or govern the operation of an object. Attributes may also affect the behavior of an object. Attributes are divided into class attributes and instance attributes.

3.2.17**backup**

status of the IO AR, which indicates that it, is in the standby state

3.2.18**behavior**

indication of how an object responds to particular events

**3.2.19
channel**

representation of a single physical or logical link of an input or output application object of a server to the process in order to support addressing of diagnosis information

NOTE The channel typically represents a single connector or clamp as a real interface of a module or sub-module. This reference is used to identify points of failure within diagnosis PDUs.

**3.2.20
channel related diagnosis**

information concerning a specific element of an input or output application object, provided for maintenance purposes

EXAMPLE open loop.

**3.2.21
class**

a set of objects, all of which represent the same kind of system component

NOTE A class is a generalization of an object; a template for defining variables and methods. All objects in a class are identical in form and behavior, but usually contain different data in their attributes.

**3.2.22
class attributes**

attribute that is shared by all objects within the same class

**3.2.23
class code**

unique identifier assigned to each object class

**3.2.24
class specific service**

service defined by a particular object class to perform a required function which is not performed by a common service

NOTE A class specific object is unique to the object class which defines it.

**3.2.25
clear**

status of the IO controller, which indicates that the control algorithm is currently not running

**3.2.26
client**

- a) object which uses the services of another (server) object to perform a task
- b) initiator of a PDU to which a server reacts

**3.2.27
common profile**

a collection of device independent information and functionality providing consistency between all devices

**3.2.28
communication data object**

object(s) which are parameter of communication relationships and referenced by device/slot/subslot/ index