

INTERNATIONAL STANDARD

NORME INTERNATIONALE



High-voltage direct current (HVDC) installations – System tests

Installations en courant continu à haute tension (CCHT) – Essais systèmes

Document Preview

[IEC 61975:2010](#)

<https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

65 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.



IEC 61975

Edition 1.1 2016-09
CONSOLIDATED VERSION

INTERNATIONAL STANDARD

NORME INTERNATIONALE



High-voltage direct current (HVDC) installations – System tests

Installations en courant continu à haute tension (CCHT) – Essais systèmes

Document Preview

[IEC 61975:2010](https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010)

<https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.130.10; 31.080.01

ISBN 978-2-8322-3631-4

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

REDLINE VERSION

VERSION REDLINE



High-voltage direct current (HVDC) installations – System tests

Installations en courant continu à haute tension (CCHT) – Essais systèmes

Document Preview

[IEC 61975:2010](#)

<https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>

CONTENTS

FOREWORD	4
INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	7
3.1 Test classifications terms	7
3.2 Operation state terms	8
4 General Objectives of system tests	9
4.1 Purpose Categories of system tests	9
4.2 Structure of the HVDC system	10
4.3 Structure of the control and protection system	12
4.4 Logical steps of system test	13
4.5 Structure of system test	14
4.6 Precondition for on-site test	14
4.7 Acceptance tests	15
5 Converter station test	17
5.1 General	17
5.2 Converter unit test	18
5.3 Energizing Energization of reactive components	19
5.4 Changing the d-c DC system configuration	20
5.5 Electromagnetic compatibility	21
5.6 Trip test	22
5.7 Open line test	23
5.8 Back-to-back test	25
5.9 Short circuit test	27
6 Transmission tests	28
6.1 Low power transmission tests	28
6.2 Operator control mode transfer	36
6.3 Changes of d-c DC configuration	42
6.4 Main circuit equipment switching	45
6.5 Dynamic performance testing	49
6.6 AC and d-c DC system staged faults	59
6.7 Loss of telecom, auxiliaries or redundant equipment	62
6.8 High power transmission tests	66
6.9 Final acceptance tests	70
7 Trial operation	77
7.1 General	77
7.2 Purpose of test	77
7.3 Test precondition	77
7.4 Test procedure	77
7.5 Test acceptance criteria	78
8 System test plan and documentation	78
8.1 General	78
8.2 Plant documentation and operating manual	78
8.3 System study reports and technical specification	78

8.4	Inspection and test plan.....	78
8.5	System test program	79
8.6	Test procedure for each test.....	80
8.7	Documentation of system test results.....	80
8.8	Deviation report.....	80
	Bibliography	82
	Figure 1 – Relation among five major aspects of system test.....	10
	Figure 2 – Structure of the HVDC system.....	12
	Figure 3 – Structure of the HVDC control and protection	13
	Figure 4 – Structure of system test	16
	Figure 5 – Sequence for low power transmission tests	30
	Figure 6 – Step response test of current control at the rectifier.....	52
	Figure 7 – Step response test of extinction angle control at the inverter.....	52
	Figure 8 – Step response test of d.c. DC voltage control at the inverter.....	53
	Figure 9 – Step response test of current control at the inverter.....	53
	Figure 10 – Step response test of power control at the rectifier	54

iTeh Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 61975:2010](https://standards.itih.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010)

<https://standards.itih.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**HIGH-VOLTAGE DIRECT CURRENT (HVDC) INSTALLATIONS –
SYSTEM TESTS****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC 61975 edition 1.1 contains the first edition (2010-07) [documents 22F/221/FDIS and 22F/227/RVD] and its amendment 1 (2016-09) [documents 22F/375/CDV and 22F/394A/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

International Standard IEC 61975 has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This version constitutes a technical revision incorporating engineering experience.

The French version of this standard has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

Document Preview

[IEC 61975:2010](#)

<https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>

INTRODUCTION

The standard is structured in eight clauses:

- a) Clause 1 – Scope
 - b) Clause 2 – Normative references
 - c) Clause 3 – **Terms and definitions**
 - d) Clause 4 – **General Objectives of system tests**
 - e) This clause addresses the purpose of this standard, the HVDC system structure, the control and protection structure, the logical steps of commissioning, the structure of the system test and that of the system commissioning standard.
 - f) Clause 5 – Converter station test
 - g) This clause addresses the commissioning of converter units and verifies the steady state performance of units as well as switching tests.
 - h) Clause 6 – ~~Power~~ Transmission tests
 - i) This clause concerns the commissioning of the transmission system, and verifies station coordination, steady-state and dynamic performance, interference, as well as interaction between the ~~d.c.~~ DC and ~~a.c.~~ AC systems.
 - j) Clause 7 – Trial operation
 - k) After completion of the system test, the period of trial operation is normally specified to verify the normal transmission.
 - l) Clause 8 – System test plan and documentation
- Clauses 5 to 7 comprise individual sections providing an introduction and covering ~~objects~~ **objectives**, preconditions and procedures and general acceptance criteria as well as detailed descriptions of the individual tests.

[IEC 61975:2010](https://standards.iteh.ai/)

<https://standards.iteh.ai/catalog/standards/iec/d11d02d3-5f09-4bb0-ad6c-125e192a2cdd/iec-61975-2010>

HIGH-VOLTAGE DIRECT CURRENT (HVDC) INSTALLATIONS – SYSTEM TESTS

1 Scope

This International Standard applies to system tests for high-voltage direct current (HVDC) installations which consist of a sending terminal and a receiving terminal, each connected to an ~~a.c.~~ AC system.

The tests specified in this standard are based on bidirectional **monopolar** and bipolar high-voltage direct current (HVDC) installations which consist of a sending terminal and a receiving terminal, each connected to an ~~a.c.~~ AC system. The test requirements and acceptance criteria should be agreed for back-to-back installations, while multi-terminal systems and voltage sourced converters are not included in this standard. For monopolar HVDC installations, the standard applies except for bipolar tests.

For the special functions or performances that are claimed by specific projects, ~~some~~ extra test items not included in this standard should be added according to the technical specification requirements.

This standard only serves as a guideline to system tests for high-voltage direct current (HVDC) installations. The standard gives potential users guidance, regarding how to plan commissioning activities. The tests described in the guide may not be applicable to all projects, but represent a range of possible tests which should be considered.

Therefore, it is preferable that the project organization establishes the individual test program based on this standard and in advance assigns responsibilities for various tasks/tests between involved organisations (e.g. user, supplier, manufacturer, operator, purchaser etc.) for each specific project.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For ~~updated~~ **undated** references, the latest edition of the referenced document (including any amendments) applies.

IEC 60633:1998, *Terminology for high-voltage direct current (HVDC) power transmission*

IEC/TR 60919-2:2008, *Performance of high-voltage direct current (HVDC) systems with line commutated converters – Part 2: Faults and switching*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 60633 as well as the following terms and definitions apply.

3.1 Test classifications terms

3.1.1

converter station tests

converter **station** system test including items which verify the function of individual equipment of the converter station in energized state

3.1.2**system test**

test verifying functions and performances of HVDC system as a whole as well as the interaction with adjacent ~~a.c.~~ AC systems

3.1.3**transmission tests**

test verifying functions and performances of HVDC system when transmitting power between both terminals

NOTE It is also referred to as an "end to end test".

3.1.4**on-site tests**

tests which are performed at the final construction site consisting of converter station test and transmission test

3.2 Operation state terms

NOTE There are five defined states in the HVDC system: earthed, stopped, standby, blocked, de-blocked.

3.2.1**earthed**

state in which the pole or converter is isolated and earthed on the ~~a.c.~~ AC and ~~d.c.~~ DC sides and no energizing of the pole or converter equipment is possible

NOTE The earthed state provides the necessary safety for carrying out maintenance work, and is the only one that permits the pole or converter maintenance. In this state maintenance work is possible on the converter transformers, the isolated and earthed part of the ~~a.c.~~ AC high voltage bus equipment, ~~d.c.~~ DC and valve hall installed equipment of this pole or converter.

3.2.2**stopped/isolated**

state in which the pole or converter is isolated from the ~~a.c.~~ AC and ~~d.c.~~ DC side, but all the earthing switches are open

NOTE In this state the ~~d.c.~~ DC yard can be prepared for power transmission (earth electrode line, pole and ~~d.c.~~ DC line connect).

3.2.3**standby**

state which is to be used when the ~~d.c.~~ HVDC system is not being utilized but is ready for power transmission

NOTE In this state the converter transformer is to be ready; tap-changer is automatically brought to the start position, which ensures that the transformer will be energized with minimum voltage to minimize the inrush current. The disconnector of the ~~a.c.~~ AC bay should be closed, but the circuit breakers in the feeding bay of the converter transformer should be open. In this state the ~~d.c.~~ DC configuration can still be changed (earth electrode line, pole and ~~d.c.~~ DC line connect). The standby state is also referred to as "Ready for energization".

3.2.4**blocked**

state in which the pole is prepared to transmit power at a moment's notice

NOTE The converter transformer is connected to the energized ~~a.c.~~ AC bus by means of closing of the respective circuit breaker. The valve cooling system is ~~ready for~~ in operation ~~if~~, and the cooling water conductivity, flow rate and water temperature are within the specified limits. A defined ~~d.c.~~ DC configuration shall have been established. Further changes are not possible in this state. The thyristor pre-check is carried out after the converter transformer has been energized. The pre-check is considered as passed when in every valve the redundancy is not lost. To change the blocked state, the states stopped, standby and de-blocked are selectable. The blocked state is also referred to as "Ready for operation".

3.2.5

de-blocked

state representing the following two operating modes: power transmission and open line test

NOTE Power transmission is the normal operating mode. In the de-blocked status the pole transmits power in normal operating mode if both terminals are in the deblocked stage and there is a voltage difference between the terminals. A minimum number of ~~a.c.~~ AC filters should be available.

3.2.6

off-site tests

tests which are performed before on-site testing

EXAMPLE Routine and type tests performed at the suppliers' factory.

4 **General Objectives of system tests**

4.1 **Purpose Categories of system tests**

System test completes the commissioning of an HVDC system.

The supplier can verify the suitability of the station equipment installed and the functional completeness of the system. Moreover, adjustments and optimizations can be made.

It is shown for the user that the requirements and stipulations in the contract are met and that there is correlation with studies and previous off-site tests.


For the user, the completion of system testing marks the beginning of commercial operation of the HVDC system.

When adapting the HVDC system to the connected ~~a.c.~~ AC systems, there may be various constraints which require coordination within the economic schedules of the ~~a.c.~~ AC system operators. System tests prove to the public that tolerable values of phenomena concerning the public interest are not exceeded.

Five major aspects are subject to system tests:

- a) HVDC station equipment and ~~d.c.~~ DC line/cable/bus including earth electrode, if any;
- b) HVDC control and protection equipment and their settings;
- c) environmental considerations;
- d) ~~a.c./d.c.~~ AC/DC system interaction;
- e) system performance when jointly operated with a connected ~~a.c.~~ AC system.

The interrelation between these aspects is shown in Figure 1.



IEC 1895/10

Figure 1 – Relation among five major aspects of system test

Thorough and complete system test of the above components can be achieved with the tests described in the standard.

Acceptance tests are the acceptance requirements for a successful completion of works and a basis for the final acceptance of the HVDC system by its users. Acceptance tests shall be defined between supplier and user in advance and may be performed at an appropriate time during the test schedule.

System tests may affect more than the actual contract parties. Those parties shall be informed in time.

The complexity and the diversified areas concerned during system test require thorough planning and scheduling, cooperation of all involved parties, as well as complete and organized documentation.

NOTE The suggested "Test Procedures" are recommendations and alternative test procedures may be used subject to the agreement between supplier and user.

4.2 Structure of the HVDC system

From a functional point of view an HVDC system consists of a sending terminal and a receiving terminal, each connected to an ~~a.c.~~ AC system. The two terminals have one or several converters units connected in series on the ~~d.c.~~ DC side and in parallel on the ~~a.c.~~ AC side. The terminals are connected by a transmission line or cable or a short piece of busbar (back-to-back station). Two terminals in connection constitute a HVDC system. If the configuration comprises a single pole, it is defined as a monopolar HVDC system. If the configuration comprises two poles of opposite polarities with respect to earth, it is called a bipolar HVDC system. Multi-terminal systems are not addressed in this standard.

The structure of the HVDC system is shown in Figure 2.