
High-voltage switchgear and controlgear -- Part 108: High-voltage alternating current disconnecting circuit-breakers for rated voltages of 72,5 kV and above

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 62271-108:2006](https://standards.iteh.ai/catalog/standards/sist/f48792bb-3ce0-4707-8644-31f4926503cf/sist-en-62271-108-2006)

<https://standards.iteh.ai/catalog/standards/sist/f48792bb-3ce0-4707-8644-31f4926503cf/sist-en-62271-108-2006>



17A/695/CDV

COMMITTEE DRAFT FOR VOTE (CDV) PROJET DE COMITÉ POUR VOTE (CDV)

Project number Numéro de projet IEC 62271-108, Ed 1.0			
IEC/TC or SC: SC 17A CEI/CE ou SC:	Date of circulation Date de diffusion 2004-04-09	Closing date for voting (Voting mandatory for P-members) Date de clôture du vote (Vote obligatoire pour les membres (P)) 2004-09-10	
Titre du CE/SC: Appareillage à haute tension		TC/SC Title: High-voltage switchgear and controlgear	
Secretary: Mr. A. Bosma (Sweden) Secrétaire: E-mail: anne.bosma@se.abb.com			
Also of interest to the following committees Intéresse également les comités suivants SC 17C		Supersedes documents Remplace les documents 17A/666/CD, 17A/676/CC and item 5.5 of 17A/685/RM	
Functions concerned Fonctions concernées			
<input type="checkbox"/> Safety Sécurité	<input type="checkbox"/> EMC CEM	<input type="checkbox"/> Environment Environnement	<input type="checkbox"/> Quality assurance Assurance qualité

CE DOCUMENT EST TOUJOURS À L'ÉTUDE ET SUSCEPTIBLE DE MODIFICATION. IL NE PEUT SERVIR DE RÉFÉRENCE.
LES RÉCIPIENDAIRES DU PRÉSENT DOCUMENT SONT INVITÉS À PRÉSENTER, AVEC LEURS OBSERVATIONS, LA NOTIFICATION DES DROITS DE PROPRIÉTÉ DONT ILS AURAIENT ÉVENTUELLEMENT CONNAISSANCE ET À FOURNIR UNE DOCUMENTATION EXPLICATIVE.

THIS DOCUMENT IS STILL UNDER STUDY AND SUBJECT TO CHANGE. IT SHOULD NOT BE USED FOR REFERENCE PURPOSES.
RECIPIENTS OF THIS DOCUMENT ARE INVITED TO SUBMIT, WITH THEIR COMMENTS, NOTIFICATION OF ANY RELEVANT PATENT RIGHTS OF WHICH THEY ARE AWARE AND TO PROVIDE SUPPORTING DOCUMENTATION.

Titre : CEI 62271-108, Ed. 1: Appareillage à haute tension - Partie 108: Disjoncteur-sectionneur à courant alternatif à haute tension de tension assignée supérieure ou égale à 72,5 kV

Titre : IEC 62271-108, Ed. 1: High-voltage switchgear and controlgear - Part 108: High voltage alternating current disconnecting circuit-breakers for rated voltages of 72,5 kV and above

Note d'introduction

Introductory note

ATTENTION CDV soumis en parallèle au vote (CEI) et à l'enquête (CENELEC)	ATTENTION Parallel IEC CDV/CENELEC Enquiry
---	---

Copyright © 2004 International Electrotechnical Commission, IEC. All rights reserved. It is permitted to download this electronic file, to make a copy and to print out the content for the sole purpose of preparing National Committee positions. You may not copy or "mirror" the file or printed version of the document, or any part of it, for any other purpose without permission in writing from IEC.

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR

**Part 108: High voltage alternating current disconnecting circuit-breakers
for rated voltages of 72,5 kV and above**

FOREWORD

- 1) The IEC (International Electrotechnical Commission) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of the IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, the IEC publishes International Standards. Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. The IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of the IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested National Committees.
- 3) The documents produced have the form of recommendations for international use and are published in the form of standards, technical specifications, technical reports or guides and they are accepted by the National Committees in that sense.
- 4) In order to promote international unification, IEC National Committees undertake to apply IEC International Standards transparently to the maximum extent possible in their national and regional standards. Any divergence between the IEC Standard and the corresponding national or regional standard shall be clearly indicated in the latter.
- 5) The IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with one of its standards.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-108 has been prepared by subcommittee 17A, High-voltage switchgear and controlgear of IEC technical committee 17: Switchgear and controlgear.

The text of this standard is based on the following documents:

FDIS	Report on voting
17A/XX/FDIS	XX/XX/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

Annex A is for information only.

The committee has decided that the contents of this publication will remain unchanged until 2014. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-108:2006

<https://standards.iteh.ai/catalog/standards/sist/f48792bb-3ce0-4707-8644-31f4926503cf/sist-en-62271-108-2006>

CONTENTS

FOREWORD.....	2
1 General	5
1.1 Scope.....	5
1.2 Normative References.....	5
1.101 Object 5	
2 Normal and Special Service Conditions	5
3 Definitions	6
3.1 General terms	6
3.2 Assemblies of switchgear and controlgear.....	6
3.3 Parts of assemblies.....	6
3.4 Switching devices.....	6
3.5 Parts of switchgear and controlgear	6
3.6 Operation.....	6
3.7 Characteristic quantities.....	6
4 Ratings.....	7
4.2 Rated insulation level	8
5 Design and construction	11
5.10 Nameplates.....	11
5.11 Interlocking devices.....	12
5.12 Position indication.....	12
6 Type tests	12
6.1 General	12
6.2 Dielectric tests	13
6.3 Radio interference (r.i.v.) tests	13
6.4 Measurement of the resistance of the main circuit	13
6.5 Temperature-rise tests	13
6.6 Short-time withstand current and peak withstand current tests	13
6.7 Verification of the degree of protection	13
6.8 Tightness tests.....	13
6.9 Electromagnetic compatibility	13
6.114 Combined function test	15
7 Routine tests	18
8 Guide to the selection of disconnecting circuit-breakers for service	19
9 Information to be given with enquires, tenders and orders	19
10 Rules for transport, storage, installation, operation and maintenance	19
11 Safety.....	19
Annex A.....	20
Explanatory notes and examples of disconnecting circuit-breakers	20
A.1 Introduction	20

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR – Part 108: High-voltage alternating current disconnecting circuit-breakers for rated voltages of 72,5 kV and above

1 General

1.1 Scope

This International Standard applies to high-voltage alternating current disconnecting circuit-breakers) for operation at frequencies of 50 Hz and 60 Hz on systems having voltages of 72,5 kV and above.

This standard identifies which requirements of IEC 60694, 62271-100 and 62271-102 standards are applicable. It also gives the additional requirements specific to these devices.

1.2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050 (441): *International Electrotechnical vocabulary – Chapter 441: Switchgear, controlgear and fuses*

IEC 60694: *Common specifications for high-voltage switchgear and controlgear standards*

IEC 62271-100: *High-voltage switchgear and controlgear – Part 100: High-voltage alternating current circuit-breakers*

IEC 62271-102: *High-voltage switchgear and controlgear – Part 102: High-voltage alternating current disconnectors and earthing switches*

IEC 62271-310: *High-voltage switchgear and controlgear – Part 310: Electrical endurance testing for circuit-breakers rated 72,5 kV and above*¹

1.101 Object

This standard covers a circuit-breaker which, when in the open position, satisfies the requirements of both a circuit-breaker and a disconnector.

As there is interaction between the requirements of the separate functions it is necessary to consider the standardisation of requirements. This standard details the requirements for a disconnecting circuit-breaker, identifying where these differ from the separate requirements of a discrete circuit-breaker and a disconnector.

NOTE For design examples of disconnecting circuit-breakers refer to Annex A.

2 Normal and special service conditions

Clause 2 of IEC 60694 is applicable.

¹ To be published.

3 Definitions

For the purpose of this international standard, the definitions of IEC 60050 (441) and IEC 60694 apply. Some of them are recalled here for ease of reference.

Additional definitions given here are classified in a manner that aligns with the classification used in IEC 60050 (441).

3.1 General terms

3.1.1

switchgear and controlgear

[IEV 441-11-01]

3.2 Assemblies of switchgear and controlgear

No particular definitions.

3.3 Parts of assemblies

No particular definitions.

3.4 Switching devices

3.4.101

circuit-breaker

[IEV 441-14-20]

3.4.102

disconnector

[IEV 441-14-05]

3.4.103

disconnecting circuit-breaker

circuit-breaker satisfying the requirements of a disconnector, when the contacts are in open position

3.5 Parts of switchgear and controlgear

No particular definitions.

3.6 Operation

3.6.101

closed position (of a mechanical switching device)

[IEV 441-16-22]

3.6.102

open position (of a mechanical switching device)

[IEV 441-16-23]

3.6.103

interlocking device

[IEV 441-16-49]

3.7 Characteristic quantities

3.7.101

insulation level

test voltage, under specified conditions, that the insulation of a device is designed to withstand

[IEV 151-04-14]

3.7.102**external insulation**

distances in atmospheric air, and surfaces of solid insulation of disconnectors and earthing switches in contact with the air, which are subject to dielectric stresses and to the effect of atmospheric and other external conditions such as pollution, humidity, vermin, etc.
[IEV 604-03-02, modified]

NOTE External insulation is either weather-protected or non-weather-protected, designed to operate outside or inside closed shelters, respectively

3.7.103**internal insulation**

internal solid, liquid or gaseous parts of the insulation of equipment which are protected from the effects of atmospheric and other external conditions
[IEV 604-03-03]

3.7.104**isolating distance (of a pole of a mechanical switching device)**

[IEV 441-17-35]

4 Ratings

Clause 4 of IEC 62271-100 is applicable, unless stated otherwise.

The characteristics of a disconnecting circuit-breaker, including its operating devices, and auxiliary equipment, that shall be used to determine the rating are the following:

Rated characteristics to be given for all disconnecting circuit-breakers

- a) rated voltage;
- b) rated insulation level;
- c) rated frequency;
- d) rated normal current;
- e) rated short-time withstand current;
- f) rated peak withstand current;
- g) rated duration of short-circuit;
- h) rated supply voltage of closing and opening devices and of auxiliary circuits;
- i) rated supply frequency of closing and opening devices and of auxiliary circuits;
- j) rated pressures of compressed gas supply and/or of hydraulic supply for operation, interruption and insulation, as applicable;
- k) rated short-circuit breaking current;
- l) transient recovery voltage related to the rated short-circuit breaking current;
- m) rated short-circuit making current;
- n) rated operating sequence;
- o) rated time quantities;
- p) rated static terminal load;
- q) rated line-charging breaking current;

Rated characteristics to be given in the specific cases indicated below

- r) characteristics for short-line faults related to the rated short-circuit breaking current, for disconnecting circuit-breakers designed for direct connection to overhead transmission lines at more than 12,5 kA rated short-circuit breaking current;

- s) rated cable-charging breaking current, for three-pole disconnecting circuit-breakers intended for switching cables.

Rated characteristics to be given on request

- t) rated out-of-phase making and breaking current;
u) rated single capacitor bank breaking current;
v) rated back-to-back capacitor bank breaking current;
w) rated capacitor bank inrush making current;
x) rated back-to-back capacitor bank inrush making current.

The rated characteristics of the disconnecting circuit-breaker are referred to the rated operating sequence.

NOTE 1 Disconnecting circuit-breakers need not be assigned to ratings with respect to bus-transfer current switching. The bus-transfer current switching capability is covered by the making and breaking tests in IEC 62271-100.

NOTE 2 Rated contact zone is not applicable for disconnecting circuit-breakers.

4.2 Rated insulation level

Subclause 4.2 of IEC 62271-100 is applicable with the following exception:

The standard values of rated withstand voltages across the open disconnecting circuit-breaker are given in columns 3 and 5 of Table 1a, columns 3, 3a and 5 of Table 1b and columns 3, 6 and 8 of Tables 2a-2b in IEC 60694.

4.112 Rated static terminal load

The rated static terminal load is the maximum resulting terminal forces (simultaneous action of ice, wind and connected conductors) to which the terminal of a disconnecting circuit-breaker is allowed to be subjected to.

Recommended values of forces due to flexible and tubular connected conductors (not including wind or ice load or the dynamic loads on the disconnecting circuit-breaker itself) are given in Table 1.

Table 1 – Recommended static terminal loads

Rated voltage range U_r kV	Rated current range I_r A	Static horizontal force F_{th}		Static vertical force (vertical axis-upward and downward) F_{tv} N
		Longitudinal F_{thA} N	Transversal F_{thB} N	
72,5	800 – 1 250	500	400	500
72,5	1 600 – 2 500	750	500	750
100 – 170	1 250 – 2 000	1 000	750	1 000
100 – 170	2 500 – 4 000	1 250	750	1 000
245	1 600 – 4 000	1 250	1 000	1 250
300 – 362	1 600 – 2 000	1 250	1 000	1 250
300 – 362	3 150 – 4 000	1 500	1 000	1 500
420 – 800	2 000	1 750	1 250	1 500
420 – 800	3 150 – 4 000	2 000	1 250	1 500

Forces due to wind and ice are applicable for outdoor disconnecting circuit-breaker only and shall be taken into account by the manufacturer. Ice coating and wind pressure on the disconnecting circuit-breaker shall be in accordance with 2.1.2 of IEC 60694.

The rated static terminal load shall be expressed in the resultant horizontal (F_{shA} and F_{shB}) and vertical (F_{sv}) forces (refer to Figure 1 and 2).

[SIST EN 62271-108:2006](https://standards.iteh.ai/catalog/standards/sist/f48792bb-3ce0-4707-8644-31f4926503cf/sist-en-62271-108-2006)

<https://standards.iteh.ai/catalog/standards/sist/f48792bb-3ce0-4707-8644-31f4926503cf/sist-en-62271-108-2006>