



SLOVENSKI STANDARD
SIST EN 60870-5-104:2007

01-september-2007

BÜXca Yý U
SIST EN 60870-5-104:2002

Oprema in sistemi za daljinsko vodenje – 5-104. del: Protokoli prenosa – Omrežni dostop za transportne profile po standardu IEC 60870-5-101 (IEC 60870-5-104:2006)

Telecontrol equipment and systems -- Part 5-104: Transmission protocols - Network access for IEC 60870-5-101 using standard transport profiles (IEC 60870-5-104:2006)

iTeh STANDARD PREVIEW
(standards.itih.eu)
Fernwirkrichtungen und -systeme -- Teil 5-104: Übertragungsprotokolle - Zugriff für IEC 60870-5-101 auf Netze mit genormten Transportprofilen (IEC 60870-5-104:2006)

SIST EN 60870-5-104:2007
Matériels et systèmes de téléconduite -- Partie 5-104: Protocoles de transmission - Accès aux réseaux utilisant des profils de transport normalisés pour la CEI 60870-5-101 (IEC 60870-5-104:2006)

Ta slovenski standard je istoveten z: EN 60870-5-104:2006

ICS:

33.200 Daljinsko krmiljenje, daljinske Telecontrol. Telemetering
meritve (telemetrija)

SIST EN 60870-5-104:2007

en,fr,de

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)

<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

English version

**Telecontrol equipment and systems
Part 5-104: Transmission protocols -
Network access for IEC 60870-5-101
using standard transport profiles
(IEC 60870-5-104:2006)**

Matériels et systèmes de téléconduite
Partie 5-104: Protocoles de transmission -
Accès aux réseaux utilisant
des profils de transport normalisés
pour la CEI 60870-5-101
(CEI 60870-5-104:2006)

Fernwirkleinrichtungen und -systeme
Teil 5-104: Übertragungsprotokolle -
Zugriff für IEC 60870-5-101 auf Netze
mit genormten Transportprofilen
(IEC 60870-5-104:2006)

ITEH STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 60870-5-104:2007

This European Standard was approved by CENELEC on 2006-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 57/812/FDIS, future edition 2 of IEC 60870-5-104, prepared by IEC TC 57, Power systems management and associated information exchange, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60870-5-104 on 2006-09-01.

This European Standard supersedes EN 60870-5-104:2001.

The main changes with respect to EN 60870-5-104:2001 are as follows: improvement of the sequences and interoperability of the protocol and addition of new functions for the handling of redundant connections.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2007-06-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2009-09-01

Annex ZA has been added by CENELEC.

iTeh **Endorsement notice** STANDARD PREVIEW

The text of the International Standard IEC 60870-5-104:2006 was approved by CENELEC as a European Standard without any modification. (standards.iteh.ai)

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)
<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | <u>EN/HD</u> | <u>Year</u> |
|---------------------------------|-----------------|--|----------------|-------------|
| IEC 60870-5-3 | 1992 | Telecontrol equipment and systems Part 5: Transmission protocols - Section 3: General structure of application data | EN 60870-5-3 | 1992 |
| IEC 60870-5-4 | 1993 | Telecontrol equipment and systems Part 5: Transmission protocols - Section 4: Definition and coding of application information elements | EN 60870-5-4 | 1993 |
| IEC 60870-5-5 | 1995 | Telecontrol equipment and systems Part 5: Transmission protocols - Section 5: Basic application functions | EN 60870-5-5 | 1995 |
| IEC 60870-5-101 | 2003 | Telecontrol equipment and systems Part 5-101: Transmission protocols - Companion standard for basic telecontrol tasks | EN 60870-5-101 | 2003 |
| IEC 60870-5-102 | 1996 | Telecontrol equipment and systems Part 5: Transmission protocols - Section 102: Companion standard for the transmission of integrated totals in electric power systems | EN 60870-5-102 | 1996 |
| ITU-T Recommendation X.25 | 1996 | Interface between Data Terminal Equipment - (DTE) and Data Circuit-terminating Equipment (DCE) for terminals operating in the packet mode and connected to public data networks by dedicated circuit | - | - |
| IEEE 802.3 | 1998 | Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications | - | - |
| RFC 791 | 1981 | Internet Protocol - DARPA Internet Program Protocol Specification | - | - |
| RFC 793 | 1981 | Transmission Control Protocol - DARPA Internet Program Protocol Specification | - | - |
| RFC 894 | - ¹⁾ | Standard for the Transmission of IP datagrams over Ethernet Networks | - | - |

¹⁾ Undated reference.

| <u>Publication</u> | <u>Year</u> | <u>Title</u> | <u>EN/HD</u> | <u>Year</u> |
|--------------------|-----------------|--------------------------------------|--------------|-------------|
| RFC 1661 | - ¹⁾ | Point-to-Point Protocol (PPP) | - | - |
| RFC 1662 | - ¹⁾ | PPP in HDLC Framing | - | - |
| RFC 1700 | 1994 | Assigned Numbers | - | - |
| RFC 2200 | 1997 | Internet Official Protocol Standards | - | - |

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)

<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

INTERNATIONAL STANDARD

IEC 60870-5-104

Second edition
2006-06

Telecontrol equipment and systems –

Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles

(standards.iteh.ai)

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)

<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

© IEC 2006 Copyright - all rights reserved

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembe, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

PRICE CODE **XB**

For price, see current catalogue

CONTENTS

| | |
|---|----|
| FOREWORD..... | 9 |
| INTRODUCTION..... | 13 |
| 1 Scope and object..... | 15 |
| 2 Normative references | 15 |
| 3 General architecture | 17 |
| 4 Protocol structure | 21 |
| 5 Definition of Application Protocol Control Information (APCI)..... | 23 |
| 5.1 Protection against loss and duplication of messages | 29 |
| 5.2 Test procedures | 33 |
| 5.3 Transmission control using Start/Stop | 37 |
| 5.4 Portnumber | 45 |
| 5.5 Maximum number of outstanding I format APDUs (k)..... | 45 |
| 6 Selection of ASDUs defined in IEC 60870-5-101 and additional ASDUs | 45 |
| 7 Mapping of selected application data units and functions to the TCP services | 53 |
| 7.1 Station initialization (6.1.5 to 6.1.7 of IEC 60870-5-5)..... | 53 |
| 7.2 Data acquisition by polling (6.2 of IEC 60870-5-5)..... | 63 |
| 7.3 Cyclic data transmission (6.3 of IEC 60870-5-5)..... | 63 |
| 7.4 Acquisition of events (6.4 of IEC 60870-5-5)..... | 63 |
| 7.5 General interrogation (6.6 of IEC 60870-5-5)..... | 63 |
| 7.6 Clock synchronization (6.7 of IEC 60870-5-5)..... | 65 |
| 7.7 Command transmission (6.8 of IEC 60870-5-5)..... | 67 |
| 7.8 Transmission of integrated totals (6.9 of IEC 60870-5-5)..... | 69 |
| 7.9 Parameter loading (6.10 of IEC 60870-5-5)..... | 69 |
| 7.10 Test procedure (6.11 of IEC 60870-5-5)..... | 71 |
| 7.11 File transfer (6.12 of IEC 60870-5-5) Control and monitor direction | 71 |
| 8 ASDUs for process information in control direction with time tag | 73 |
| 8.1 TYPE IDENT 58: C_SC_TA_1 Single command with time tag CP56Time2a..... | 75 |
| 8.2 TYPE IDENT 59: C_DC_TA_1 Double command with time tag CP56Time2a | 77 |
| 8.3 TYPE IDENT 60: C_RC_TA_1 Regulating step command with time tag CP56Time2a | 79 |
| 8.4 TYPE IDENT 61: C_SE_TA_1 Set-point command with time tag CP56Time2a, normalized value | 81 |
| 8.5 TYPE IDENT 62: C_SE_TB_1 Set-point command with time tag CP56Time2a, scaled value | 83 |
| 8.6 TYPE IDENT 63: C_SE_TC_1 Set-point command with time tag CP56Time2a, short floating point number | 85 |
| 8.7 TYPE IDENT 64: C_BO_TA_1 Bitstring of 32 bit with time tag CP56Time2a | 87 |
| 8.8 TYPE IDENT 107: C_TS_TA_1 Test command with time tag CP56Time2a | 89 |
| 8.9 TYPE IDENT 127: F_SC_NB_1 QueryLog – Request archive file | 91 |

| | | |
|-----------|---|-----|
| 9 | Interoperability | 93 |
| 9.1 | System or device..... | 93 |
| 9.2 | Network configuration..... | 93 |
| 9.3 | Physical layer..... | 95 |
| 9.4 | Link layer | 95 |
| 9.5 | Application layer..... | 97 |
| 9.6 | Basic application functions | 107 |
| 10 | Redundant connections | 115 |
| 10.1 | General | 115 |
| 10.2 | General requirements..... | 115 |
| 10.3 | Initialisation of controlling station | 119 |
| 10.4 | Initialisation of controlled station | 123 |
| 10.5 | User data from controlling station | 127 |
| 10.6 | User data from controlled station..... | 131 |
| 10.7 | State transition diagrams..... | 135 |
| | | |
| Figure 1 | – General architecture (example)..... | 19 |
| Figure 2 | – Selected standard provisions of the defined telecontrol companion standard..... | 21 |
| Figure 3 | – Selected standard provisions of the TCP/IP protocol suite RFC 2200 (example) | 23 |
| Figure 4 | – APDU of the defined telecontrol companion standard..... | 25 |
| Figure 5 | – APCI of the defined telecontrol companion standard | 25 |
| Figure 6 | – Control field of type Information transfer format (I format) | 27 |
| Figure 7 | – Control field of type numbered supervisory functions (S format)..... | 27 |
| Figure 8 | – Control field of type unnumbered control functions (U format) | 27 |
| Figure 9 | – Undisturbed sequences of numbered I format APDUs | 29 |
| Figure 10 | – Undisturbed sequences of numbered I format APDUs acknowledged by an S format APDU | 31 |
| Figure 11 | – Disturbed sequence of numbered I format APDUs | 31 |
| Figure 12 | – Time-out in case of a not acknowledged last I format APDU | 33 |
| Figure 13 | – Undisturbed test procedure | 35 |
| Figure 14 | – Unconfirmed test procedure | 35 |
| Figure 15 | – Start data transfer procedure | 37 |
| Figure 16 | – Stop data transfer procedure..... | 39 |
| Figure 17 | – State transition diagram for Start/Stop procedure (controlled station)..... | 41 |
| Figure 18 | – State transition diagram for Start/Stop procedure (controlling station) | 43 |
| Figure 19 | – TCP connection establishment and close | 55 |
| Figure 20 | – Initialization of the controlling station | 57 |
| Figure 21 | – Local initialization of the controlled station | 59 |
| Figure 22 | – Remote initialization of the controlled station | 61 |
| Figure 23 | – ASDU: C_SC_TA_1 Single command with time tag CP56Time2a | 75 |
| Figure 24 | – ASDU: C_DC_TA_1 Double command with time tag CP56Time2a..... | 77 |
| Figure 25 | – ASDU: C_RC_TA_1 Regulating step command with time tag CP56Time2a | 79 |

| | |
|---|-----|
| Figure 26 – ASDU: C_SE_TA_1 Set-point command with time tag CP56Time2a, normalized value..... | 81 |
| Figure 27 – ASDU: C_SE_TB_1 Set-point command with time tag CP56Time2a, scaled value | 83 |
| Figure 28 – ASDU: C_SE_TC_1 Set-point command with time tag CP56Time2a, short floating point number | 85 |
| Figure 29 – ASDU: C_BO_TA_1 Bitstring of 32 bit with time tag CP56Time2a | 87 |
| Figure 30 – ASDU: C_TS_TA_1 Test command with time tag CP56Time2a | 89 |
| Figure 31 – ASDU: F_SC_NB_1 QueryLog – Request archive file..... | 91 |
| Figure 32 – Initialisation of controlling station with redundant connections..... | 121 |
| Figure 33 – Initialisation of controlled station with redundant connections..... | 125 |
| Figure 34 – Redundant connections – User data from controlling station | 129 |
| Figure 35 – Redundant connections – User data from controlled station | 133 |
| Figure 36 – State transition diagram for redundant connections (controlled station)..... | 137 |
| Figure 37 – State transition diagram for redundant connections (controlling station)..... | 139 |
| | |
| Table 1 – Process information in monitor direction..... | 47 |
| Table 2 – Process information in control direction..... | 49 |
| Table 3 – System information in monitor direction..... | 51 |
| Table 4 – System information in control direction..... | 51 |
| Table 5 – Parameter in control direction..... | 51 |
| Table 6 – File transfer..... | 51 |

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)
<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

TELECONTROL EQUIPMENT AND SYSTEMS –

**Part 5-104: Transmission protocols –
Network access for IEC 60870-5-101 using
standard transport profiles**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60870-5-104 Ed.2 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

This second edition cancels and replaces the first edition published in 2000 and constitutes a technical revision. The main changes of this second edition with respect to the previous edition are as follows: improvement of the sequences and interoperability of the protocol and addition of new functions for the handling of redundant connections.

The text of this standard is based on the following documents:

| | |
|-------------|------------------|
| FDIS | Report on voting |
| 57/812/FDIS | 57/819/RVD |

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC directives, Part 2.

IEC 60870-5 consists of the following parts, under the general title *Telecontrol equipment and systems – Part 5: Transmission protocols*

- Part 5: Transmission protocols – Section One: Transmission frame formats
- Part 5: Transmission protocols – Section 2: Link transmission procedures
- Part 5: Transmission protocols – Section 3: General structure of application data
- Part 5: Transmission protocols – Section 4: Definition and coding of application information elements
- Part 5: Transmission protocols – Section 5: Basic application functions
- Part 5-6: Guidelines for conformance testing for the IEC 60870-5 companion standards
- Part 5-101: Transmission protocols – Companion standard for basic telecontrol tasks
- Part 5: Transmission protocols – Section 102: Companion standard for the transmission of integrated totals in electric power systems
- Part 5-103: Transmission protocols – Companion standard for the informative interface of protection equipment
- Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles
- Part 5-601: Conformance test cases for the IEC 60870-5-101 companion standard

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed;
- withdrawn;
- replaced by a revised edition, or
- amended.

INTRODUCTION

IEC 60870-5-101 provides a communication profile for sending basic telecontrol messages between a central telecontrol station and telecontrol outstations, which uses permanent directly connected data circuits between the central station and individual outstations.

In some applications, it may be required to send the same types of application messages between telecontrol stations using a data network containing relay stations which store and forward the messages and provide only a virtual circuit between the telecontrol stations. This type of network delays messages by varying amounts of time depending on the network traffic load.

In general, the variable message delay times mean that it is not possible to use the link layer as defined in IEC 60870-5-101 between telecontrol stations. However, in some cases it is possible to connect telecontrol stations having all three layers of the companion standard IEC 60870-5-101 to suitable data networks using Packet Assembler Disassembler (PAD) type stations to provide access for balanced communication.

In all other cases this companion standard, which does not use the link functions of IEC 60870-5-101, may be used to provide balanced access via a suitable transport profile.

iTeh STANDARD PREVIEW (standards.iteh.ai)

[SIST EN 60870-5-104:2007](https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007)

<https://standards.iteh.ai/catalog/standards/sist/8d72e7e7-87b0-4eae-8349-dfd81b30535d/sist-en-60870-5-104-2007>

TELECONTROL EQUIPMENT AND SYSTEMS –

Part 5-104: Transmission protocols – Network access for IEC 60870-5-101 using standard transport profiles

1 Scope and object

This part of IEC 60870 applies to telecontrol equipment and systems with coded bit serial data transmission for monitoring and controlling geographically widespread processes. It defines a telecontrol companion standard that enables interoperability among compatible telecontrol equipment. The defined telecontrol companion standard utilizes standards of the IEC 60870-5 series. The specifications of this part present a combination of the application layer of IEC 60870-5-101 and the transport functions provided by a TCP/IP (Transmission Control Protocol/Internet Protocol). Within TCP/IP, various network types can be utilized, including X.25, FR (Frame Relay), ATM (Asynchronous Transfer Mode) and ISDN (Integrated Service Data Network). Using the same definitions, alternative ASDUs (Application Service Data Unit) as specified in other IEC 60870-5 companion standards (for example, IEC 60870-5-102) may be combined with TCP/IP, but this is not described further in this part.

NOTE Security mechanisms are outside the scope of this standard.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60870-5-3:1992, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 3: General structure of application data*

IEC 60870-5-4:1993, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 4: Definition and coding of application information elements*

IEC 60870-5-5:1995, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 5: Basic application functions*

IEC 60870-5-101:2003, *Telecontrol equipment and systems – Part 5-101: Transmission protocols – Companion standard for basic telecontrol tasks*

IEC 60870-5-102:1996, *Telecontrol equipment and systems – Part 5: Transmission protocols – Section 102: Companion standard for the transmission of integrated totals in electric power systems*

ITU-T Recommendation X.25:1996, *Interface between Data Terminal Equipment (DTE) and Data Circuit-terminating Equipment (DCE) for terminals operating in the packet mode and connected to public data networks by dedicated circuit*

IEEE 802.3:1998, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

RFC 791, *Internet Protocol, Request for Comments 791 (MILSTD 1777) (September, 1981)*

RFC 793, *Transmission Control Protocol, Request for Comments 793 (MILSTD 1778) (September, 1981)*

RFC 894, *Internet Protocol on Ethernet Networks*

RFC 1661, *Point-to-Point Protocol (PPP)*

RFC 1662, *PPP in HDLC Framing*

RFC 1700, *Assigned Numbers, Request for Comments 1700 (STD 2) (October, 1994)*

RFC 2200, *Internet Official Protocol Standards, Request for Comments 2200 (June, 1997)*

3 General architecture

This standard defines the use of an open TCP/IP-interface to a network, containing for example a LAN for telecontrol equipment, which transports IEC 60870-5-101 ASDUs. Routers which include the different WAN-types (for example, X.25, Frame Relay, ISDN, etc.) may be connected via a common TCP/IP-LAN-interface (see figure 1). Figure 1 shows a redundant configuration in the central station in addition to a non-redundant system.

Motivations:

(standards.iteh.ai)

The use of separate routers offers the following advantages.

- There is no need for network-specific software in end systems.
- There is no need for routing functionality in end systems.
- There is no need for network management in end systems.
- It facilitates obtaining end systems from manufacturers that specialize in telecontrol equipment.
- It facilitates obtaining individual separate routers, to suit a variety of networks from manufacturers specializing in this non-telecontrol specific field.
- It is possible to change the network type by replacing only the router type, without affecting the end systems.
- It is particularly suitable for converting existing end systems that conform to IEC 60870-5-101.
- It is suitable for present and future implementations.