

TECHNICAL REPORT



Performance of high-voltage direct current (HVDC) systems with line-commutated converters –
Part 3: Dynamic conditions

Document Preview

[IEC TR 60919-3:2009](#)

<https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2016 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing 20 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

65 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

[IEC TR 60919-3:2009](https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009)

<https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009>

TECHNICAL REPORT



**Performance of high-voltage direct current (HVDC) systems with line-commutated converters –
Part 3: Dynamic conditions**

Document Preview

[IEC TR 60919-3:2009](#)

<https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009>

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

ICS 29.200; 29.240.99

ISBN 978-2-8322-3241-5

Warning! Make sure that you obtained this publication from an authorized distributor.

REDLINE VERSION



**Performance of high-voltage direct current (HVDC) systems with line-commutated converters –
Part 3: Dynamic conditions**

Document Preview

[IEC TR 60919-3:2009](#)

<https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009>

CONTENTS

FOREWORD.....	5
1 Scope	7
2 Normative references	7
3 Outline of HVDC dynamic performance specifications.....	8
3.1 Dynamic performance specification	8
3.2 General comments	9
4 AC system power flow and frequency control	9
4.1 General.....	9
4.2 Power flow control	9
4.2.1 Steady-state power control requirements	9
4.2.2 Step change power requirement	10
4.3 Frequency control.....	12
5 AC dynamic voltage control and interaction with reactive power sources.....	13
5.1 General.....	13
5.2 Voltage and reactive power characteristics of an HVDC substation and other reactive power sources	13
5.2.1 General	13
5.2.2 Converter as active/reactive power source.....	14
5.2.3 Voltage characteristics of a.c. networks depending on the power loading at the busbar of the HVDC substation.....	16
5.2.4 Voltage characteristics of a.c. filters, capacitor banks and shunt reactors for power compensation at the HVDC substation	18
5.2.5 Voltage characteristics of static var compensator (SVC)	18
5.2.6 Voltage characteristics of synchronous compensator (SC)	19
5.2.7 Voltage characteristics of static synchronous compensator (STATCOM).....	19
5.3 Voltage deviations on the busbar of an HVDC substation.....	19
5.4 Voltage and reactive power interaction of the substation and other reactive power sources	20
5.4.1 HVDC converters, switchable a.c. filters, capacitor banks and shunt reactors	20
5.4.2 HVDC converters, switchable reactive power sources, SVC	21
5.4.3 HVDC converters, switchable reactive power sources and synchronous compensators	21
5.4.4 HVDC converters, switchable reactive power sources, STATCOM.....	22
6 AC system transient and steady-state stability.....	23
6.1 General.....	23
6.2 Characteristics of active and reactive power modulation	23
6.2.1 General	23
6.2.2 Large signal modulation	24
6.2.3 Small signal modulation	25
6.2.4 Reactive power modulation	25
6.3 Classification of network situations	26
6.4 AC network in parallel with the HVDC link	26
6.5 Improvement of the stability within one of the connected a.c. networks	30
6.6 Determination of the damping control characteristics	30

6.7	Implementation of the damping controller and telecommunication requirements	31
7	Dynamics of the HVDC system at higher frequencies	31
7.1	General	31
7.2	Types of instability	32
7.2.1	Loop instability (harmonic instability)	32
7.2.2	Current loop instability	32
7.2.3	Core saturation instability	32
7.2.4	Harmonic interactions	32
7.3	Information required for design purposes	33
7.4	Means available for preventing instabilities	34
7.5	Damping of low order harmonics by control action	34
7.6	Demonstration of satisfactory performance at higher frequencies	34
8	Subsynchronous oscillations	35
8.1	General	35
8.2	Criteria for subsynchronous torsional interaction with an HVDC system	36
8.3	Screening criteria for identifying generator units susceptible to torsional interactions	37
8.4	Performance considerations for utilizing subsynchronous damping controls controllers (SSDCs)	38
8.5	Performance testing	38
8.6	Turbine generator protection	38
9	Power plant interaction	39
9.1	General	39
9.2	Specific interactions	39
9.2.1	General	39
9.2.2	Frequency variation effects	39
9.2.3	Frequency controls interactions	40
9.2.4	Overvoltage effects	40
9.2.5	Harmonics	40
9.2.6	Subsynchronous and shaft impact effects	40
9.2.7	Resonance	41
9.2.8	Overvoltages	41
9.2.9	Stresses in a.c. switching equipment	41
9.2.10	Under-frequency	41
9.2.11	Starting procedure for an HVDC converter	41
9.3	Special considerations for a nuclear plant	41
	Bibliography	42
	Figure 1 – Elements for reactive power compensation at an HVDC substation	14
	Figure 2 – P/Q diagram of a converter	15
	Figure 3 – Reactive power requirements of a weak a.c. system depending on the active power loading for various constant voltage characteristics at the a.c. bus of an HVDC substation	17
	Figure 4 – Representation of the a.c. network	17
	Figure 5 – Example of voltage – current characteristic showing possible current modulation range in the absence of telecommunication between rectifier and inverter	25
	Figure 6 – Reactive power modulation in an HVDC transmission operating at minimum extinction angle γ_{\min}	27

Figure 7 – Reactive power modulation in an HVDC transmission operating at extinction angle $\gamma > \gamma_{\min}$	28
Figure 8 – Stability improvement of an a.c. link or network.....	29
Figure 9 – Principle arrangements of a damping controller.....	29

iTeh Standards
(<https://standards.iteh.ai>)
Document Preview

[IEC TR 60919-3:2009](#)

<https://standards.iteh.ai/catalog/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT (HVDC)
SYSTEMS WITH LINE-COMMUTATED CONVERTERS –**

Part 3: Dynamic conditions

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendment has been prepared for user convenience.

IEC TR 60919-3 edition 2.1 contains the second edition (2009-10) [documents 22F/183/DTR and 22F/192/RVC] and its amendment 1 (2016-03) [documents 22F/376/DTR and 22F/382A/RVC].

In this Redline version, a vertical line in the margin shows where the technical content is modified by amendment 1. Additions are in green text, deletions are in strikethrough red text. A separate Final version with all changes accepted is available in this publication.

The main task of IEC technical committees is to prepare International Standards. However, a technical committee may propose the publication of a technical report when it has collected data of a different kind from that which is normally published as an International Standard, for example "state of the art".

IEC 60919-3, which is a technical report, has been prepared by subcommittee 22F: Power electronics for electrical transmission and distribution systems, of IEC technical committee 22: Power electronic systems and equipment.

This edition includes the following significant technical changes with respect to the previous edition:

- a) this report concerns only line-commutated converters;
- b) significant changes have been made to the control system technology;
- c) some environmental constraints, for example audible noise limits, have been added;
- d) the capacitor coupled converters (CCC) and controlled series capacitor converters (CSCC) have been included.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 60919 series, under the general title: *Performance of high-voltage direct current (HVDC) systems with line-commutated converters*, can be found on the IEC website.

The committee has decided that the contents of the base publication and its amendment will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

A bilingual version of this publication may be issued at a later date.

PERFORMANCE OF HIGH-VOLTAGE DIRECT CURRENT (HVDC) SYSTEMS WITH LINE-COMMUTATED CONVERTERS –

Part 3: Dynamic conditions

1 Scope

This Technical Report provides general guidance on the dynamic performance of high-voltage direct current (HVDC) systems. Dynamic performance, as used in this specification, is meant to include those events and phenomena whose characteristic frequencies or time domain cover the range between transient conditions and steady state. It is concerned with the dynamic performance due to interactions between two-terminal HVDC systems and related a.c. systems or their elements such as power plants, a.c. lines and buses, reactive power sources, etc. at steady-state or transient conditions. The two-terminal HVDC systems are assumed to utilize 12-pulse converter units comprised of three-phase bridge (double way) connections. The converters are assumed to use thyristor valves as bridge arms, with gapless metal oxide arresters for insulation coordination and to have power flow capability in both directions. Diode valves are not considered in this specification. While multi-terminal HVDC transmission systems are not expressly considered, much of the information in this specification is equally applicable to such systems.

Only line-commutated converters are covered in this report, which includes capacitor commutated converter circuit configurations. General requirements for semiconductor line-commutated converters are given in IEC 60146-1-1, IEC 60146-1-2 and IEC 60146-1-3. Voltage-sourced converters are not considered.

This report (IEC 60919-3) which covers dynamic performance, is accompanied by publications for steady-state (IEC 60919-1) and transient (IEC 60919-2) performance. All three aspects should be considered when preparing two-terminal HVDC system specifications.

A difference exists between system performance specifications and equipment design specifications for individual components of a system. While equipment specifications and testing requirements are not defined herein, attention is drawn to those which would affect performance specifications for a system. There are many possible variations between different HVDC systems, therefore these are not considered in detail. This report should not be used directly as a specification for a specific project, but rather to provide the basis for an appropriate specification tailored to fit actual system requirements for a particular electric power transmission scheme. This report does not intend to discriminate between the responsibility of users and manufacturers for the work specified.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60146-1-1, *Semiconductor converters – General requirements and line commutated converters – Part 1-1: Specification of basic requirements*

IEC/TR 60146-1-2, *Semiconductor converters – General requirements and line commutated converters – Part 1-2: Application guide*

IEC 60146-1-3, *Semiconductor converters – General requirements and line commutated converters – Part 1-3: Transformers and reactors*

IEC TR 60919-1:2005 2010, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 1: Steady-state conditions*

IEC TR 60919-1:2010/AMD1:2013

IEC TR 60919-2:2008, *Performance of high-voltage direct current (HVDC) systems with line-commutated converters – Part 2: Faults and switching*

IEC TR 60919-2:2008/AMD1:2015

3 Outline of HVDC dynamic performance specifications

3.1 Dynamic performance specification

A complete dynamic performance specification for an HVDC system should consider the following clauses:

- a.c. system power flow and frequency control (see Clause 4);
- a.c. dynamic voltage control and interaction with reactive power sources (see Clause 5);
- a.c. system transient and steady-state stability (see Clause 6);
- dynamics of the HVDC system at higher frequencies (see Clause 7);
- subsynchronous oscillations (see Clause 8);
- power plant interaction (see Clause 9).

Clause 4 deals with using active power control of the HVDC system to affect power flow and/or frequency of related a.c. systems in order to improve the performance of such a.c. systems. The following aspects should be considered at the design of HVDC active power control modes:

- a) to minimize the a.c. power system losses under steady-state operation;
- b) to prevent a.c. line overload under steady-state operation and under a disturbance;
- c) to coordinate with the a.c. generator governor control;
- d) to suppress a.c. system frequency deviations under steady-state operation and under a disturbance.

In Clause 5, the voltage and reactive power characteristics of the HVDC substation and other reactive power sources (a.c. filters, capacitor banks, shunt reactors, SVC (static var compensator), synchronous compensators) as well as interaction between them during control of the a.c. bus voltage are considered.

In Clause 6, a discussion is provided concerning methods of controlling active and reactive power of an HVDC link to improve the steady-state and/or transient stability of the interconnected a.c. system by counteracting electromechanical oscillations.

Clause 7 deals with dynamic performance of an HVDC system in the range of half fundamental frequency and above due to both characteristic and non-characteristic harmonics generated by converters. Means for preventing instabilities are also discussed.

In Clause 8, the phenomenon of amplification of torsional, mechanical oscillations in turbine-generators of a thermal power plant at their natural frequencies, due to interaction with an HVDC control system (constant power and current regulation modes), is considered. Specifications for subsynchronous damping control are defined.

The interaction between a power plant and an HVDC system located electrically near to it is considered in Clause 9, taking into account some special features of the nuclear power plant and requirements for the reliability of the HVDC system.

3.2 General comments

Any design requirements for future HVDC systems being specified should fall within the design limits covered in publications on steady-state (IEC 60919-1) and transient (IEC 60919-2) performance. It is recommended that during preparation of the dynamic HVDC system performance specification, the proper HVDC system control strategy should be identified based on detailed power system studies. The priorities of control signal inputs and the way they are processed should be specified.

4 AC system power flow and frequency control

4.1 General

Active power control of an HVDC system can be used to control the power flow and/or frequency in related a.c. systems in order to improve the performance of a.c. systems in steady-state operation and under disturbance.

In this clause, the HVDC active power operation modes, which are used to improve the a.c. system performance for the following purposes, will be covered:

- HVDC power control to minimize the total power system losses under steady-state operation;
- HVDC power control for prevention of a.c. line overload under a disturbance as well as steady state;
- coordinated HVDC power control with an a.c. system generator governor control;
- HVDC power control for suppression of an a.c. system frequency deviation under a disturbance as well as steady state.

HVDC active and/or reactive power modes used to improve a.c. system dynamic and transient stability or improve a.c. voltage control is discussed in Clauses 5 and 6.

[IEC TR 60919-3:2009](https://standards.iteh.org/standards/iec/b497bab4-4f96-497c-8694-fbd8d5d67337/iec-tr-60919-3-2009)

4.2 Power flow control

4.2.1 Steady-state power control requirements

The power of an HVDC system is sometimes controlled to minimize overall power system losses, to prevent a.c. line overloading, and to coordinate with the governor control of a.c. system generators. Such power control requirements differ from time to time according to the role of HVDC systems in the overall power system.

When an HVDC system is used to transmit power from remote generating stations, the HVDC transmission power control is coordinated with the governor control of the power station generators. In this case, the generator voltage, frequency or the rotor speed may be used as a reference to the HVDC power control system.

When two a.c. power systems are connected by an HVDC link, the HVDC power is controlled to a pre-determined pattern under normal circumstances, but an additional function can be incorporated to this HVDC power control so that the frequency of either or both a.c. power systems is controlled. When one of the a.c. systems is an isolated system, such as one supplying a separate island, frequency control of this isolated a.c. system may have to be realized by the HVDC system.

The a.c. system frequency control by an HVDC system is discussed in 4.3.

When two a.c. systems are interconnected by more than one d.c. link or d.c. and a.c. links, or when a d.c. system exists within an a.c. system, HVDC power may be controlled in order to minimize the total transmission losses of the interconnected systems.

In some cases of a.c./d.c. system configurations described above, the HVDC power change control can be used to prevent overloading of one or more transmission lines in the power system.

In certain special HVDC control schemes, such as the one designed to improve a.c. system performance by increasing the d.c. power during and after a disturbance, the steady-state d.c. transmission power may have to be set at a restricted value so that the d.c. power does not exceed the d.c. rated power, including overload capability, when the control is initiated. It is important to consider also the additional reactive power supply required both by the HVDC converters and the a.c. systems in such a situation.

The following items a) to g) need to be considered in the specification of steady-state control requirements. Note that at the time of preparing the specification, the complete steady-state control requirements may not have been determined or designed, but allowance for possible future inputs is necessary.

- a) When a power flow control system is designed to have more than one function, including the a.c. system frequency control, the HVDC control system should be so designed that priorities are set between each control function.
- b) Under steady-state conditions, the control for prevention of a.c. line overloading is usually given higher priority over other power flow controls. The control for minimization of power system losses is implemented either by setting the d.c. power to a pattern which has been pre-determined by the power system data, or in response to an on-line computation which is conducted in the central load dispatching office. Usually, its control response is relatively slow, being several seconds or several minutes, even in the latter case.
- c) In isolated systems or systems with a relatively large d.c. infeed, frequency is often maintained by the HVDC power. In such a case, HVDC frequency control could have a priority over system loss minimization, but may be limited by overload protection.
- d) The change in reactive power demand accompanying the power changes may result in frequent switching of reactive power equipment. In such a case, it is necessary to figure out particular a.c. voltage control measures such as reactive power control by converter units, or to set limits of the magnitude of HVDC power change.
- e) The need for special power order adjustment signals unique to the power system should be identified, studied, and specified. The signals cannot be permitted to cause d.c. current or power, or a.c. voltage to deviate beyond equipment and system ratings and limits. The priority of two or more input signals having simultaneous demand on d.c. link power should be established and coordinated.
- f) Bipolar d.c. links normally require that d.c. power and current be effectively shared between poles. For loss of one pole, an overload strategy for the remaining pole could be developed to minimize disruption to a.c. system power flow, voltage and frequency.
- g) Disruption of the telecommunication link between the sending and receiving system of the d.c. link should not cause disruption to the a.c. power system. A minimum specification requirement is that power transmission is maintained at the same power level which existed before the telecommunication failure. If additional functions such as frequency control are required during temporary outage of the telecommunication link, these should be specified.

4.2.2 Step change power requirement

Under certain power system conditions, it may be required to change the HVDC power in steps in order to improve the performance of a.c. systems during and after power system disturbances. Under certain circumstances, the step change may involve d.c. power reversal.

A step change of d.c. power is realized by changing the set value of d.c. power order or by changing the power range in response to an input signal. The rate of change of power and limit to the magnitude of the d.c. power change demanded by the step change should be