
Visokonapetostne stikalne in krmilne naprave – 3. del: Digitalni vmesniki, ki temeljijo na IEC 61850 (IEC 62271-3:2006)

High-voltage switchgear and controlgear -- Part 3: Digital interfaces based on IEC 61850 (IEC 62271-3:2006)

Hochspannungs-Schaltgeräte und -Schaltanlagen - Teil 3: Digitale Schnittstellen nach IEC 61850 (IEC 62271-3:2006)

Appareillage a haute tension -- (Partie 3: Interfaces numériques basées sur la CEI 61850 (IEC 62271-3:2006)

iTeh STANDARD PREVIEW

(standard.it-eh.ai)

[SIST EN 62271-3:2007](https://standards.it-eh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d6554b3ed3/sist-en-62271-3-2007)

Ta slovenski standard je istoveten z: EN 62271-3:2006

<https://standards.it-eh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d6554b3ed3/sist-en-62271-3-2007>

ICS:

29.130.10	Visokonapetostne stikalne in krmilne naprave	High voltage switchgear and controlgear
-----------	--	---

SIST EN 62271-3:2007

en,fr,de

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-3:2007

<https://standards.iteh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d855483ed3/sist-en-62271-3-2007>

**High-voltage switchgear and controlgear
Part 3: Digital interfaces based on IEC 61850
(IEC 62271-3:2006)**

Appareillage à haute tension
Partie 3: Interfaces numériques
basées sur la CEI 61850
(CEI 62271-3:2006)

Hochspannungs-Schaltgeräte
und -Schaltanlagen
Teil 3: Digitale Schnittstellen
nach IEC 61850
(IEC 62271-3:2006)

iTeh STANDARD PREVIEW

This European Standard was approved by CENELEC on 2006-09-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 17C/369/FDIS, future edition 1 of IEC 62271-3, prepared by SC 17C, High-voltage switchgear and controlgear assemblies, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62271-3 on 2006-09-01.

This standard has the status of a product family standard and may be used as a normative reference in a dedicated product standard for highvoltage switchgear and controlgear.

This standard is to be read in conjunction with the following documents:

- EN 61850 series "Communication networks and systems in substations"
- EN 62271 series "High-voltage switchgear and controlgear".

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2007-06-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2009-09-01 |

Annex ZA has been added by CENELEC.

iTeh STANDARD PREVIEW
(standards.iteh.ai)
Endorsement notice

The text of the International Standard IEC 62271-3:2006 was approved by CENELEC as a European Standard without any modification.

Editorial modifications to IEC 62271-3:2006:

Clause 2, Normative references

Delete the reference to IEC 62271-103.

Add:

IEC 62271-102, *High-voltage switchgear and controlgear - Part 102: Alternating current disconnectors and earthing switches*

Clause C.2

In the note below Table C.2, **replace** "IEC 62271-103" by "IEC 62271-102".

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-191	1990	International Electrotechnical Vocabulary (IEV) Chapter 191: Dependability and quality of service	-	-
IEC 60265-2	- ¹⁾	High-voltage switches Part 2: High-voltage switches for rated voltages of 52 kV and above	EN 60265-2	1993 ²⁾
IEC 60694	- ¹⁾	Common specifications for high-voltage switchgear and controlgear standards	EN 60694 + corr. May	1996 ²⁾ 1999
IEC 60794	Series	Optical fibre cables	-	-
IEC 60870-4	1990	Telecontrol equipment and systems Part 4: Performance requirements	HD 546.4 S1	1992
IEC 60874-10-3	1997	Connectors for optical fibres and cables Part 10-3: Detail specification for fibre optic adaptor type BFOC/2,5 for single and multimode fibre	-	-
IEC/TR 61850-1	2003	Communication networks and systems in substations Part 1: Introduction and overview	-	-
IEC/TS 61850-2	2003	Communication networks and systems in substations Part 2: Glossary	-	-
IEC 61850-3	2002	Communication networks and systems in substations Part 3: General requirements	EN 61850-3	2002
IEC 61850-4	2002	Communication networks and systems in substations Part 4: System and project management	EN 61850-4	2002
IEC 61850-5	2003	Communication networks and systems in substations Part 5: Communication requirements for functions and device models	EN 61850-5	2003

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61850-6	2004	Communication networks and systems in substations Part 6: Configuration description language for communication in electrical substations related to IEDs	EN 61850-6	2004
IEC 61850-7-1	2003	Communication networks and systems in substations Part 7-1: Basic communication structure for substation and feeder equipment - Principles and models	EN 61850-7-1	2003
IEC 61850-7-2	2003	Communication networks and systems in substations Part 7-2: Basic communication structure for substation and feeder equipment - Abstract communication service interface (ACSI)	EN 61850-7-2	2003
IEC 61850-7-3	2003	Communication networks and systems in substations Part 7-3: Basic communication structure for substation and feeder equipment - Common data classes	EN 61850-7-3	2003
IEC 61850-7-4	2003	Communication networks and systems in substations Part 7-4: Basic communication structure for substation and feeder equipment - Compatible logical node classes and data classes	EN 61850-7-4	2003
IEC 61850-8-1	2004	Communication networks and systems in substations Part 8-1: Specific Communication Service Mapping (SCSM) - Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3	EN 61850-8-1	2004
IEC 61850-9-1	2003	Communication networks and systems in substations Part 9-1: Specific Communication Service Mapping (SCSM) - Sampled values over serial unidirectional multidrop point to point link	EN 61850-9-1	2003
IEC 61850-9-2	2004	Communication networks and systems in substations Part 9-2: Specific Communication Service Mapping (SCSM) - Sampled values over ISO/IEC 8802-3	EN 61850-9-2	2004
IEC 61850-10	2005	Communication networks and systems in substations Part 10: Conformance testing	EN 61850-10	2005
IEC 62271-102	- ¹⁾	High-voltage switchgear and controlgear Part 102: Alternating current disconnectors and earthing switches	EN 62271-102 + corr. March	2002 ²⁾ 2005
ISO/IEC 7498	Series	Information technology - Open systems interconnection - Basic reference model	EN ISO/IEC 7498	Series

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8802-3	2001	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
ITU-T V.24	2000	List of definitions for interchange circuits between data terminal equipment (DTE) and data circuit-terminating equipment (DCE)	-	-

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-3:2007

<https://standards.iteh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d855483ed3/sist-en-62271-3-2007>

iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST EN 62271-3:2007

<https://standards.iteh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d855483ed3/sist-en-62271-3-2007>

NORME
INTERNATIONALE
INTERNATIONAL
STANDARD

CEI
IEC

62271-3

Première édition
First edition
2006-06

Appareillage à haute tension –

Partie 3:
Interfaces numériques basées sur la CEI 61850

STANDARD PREVIEW
iTech (standards.iteh.ai)
High-voltage switchgear and controlgear –

Part 3:
Digital interfaces based on IEC 61850

<https://standards.iteh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d855483ed3/sist-en-62271-3-2007>

© IEC 2006 Droits de reproduction réservés — Copyright - all rights reserved

Aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'éditeur.

No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Electrotechnical Commission, 3, rue de Varembé, PO Box 131, CH-1211 Geneva 20, Switzerland
Telephone: +41 22 919 02 11 Telefax: +41 22 919 03 00 E-mail: inmail@iec.ch Web: www.iec.ch



Commission Electrotechnique Internationale
International Electrotechnical Commission
Международная Электротехническая Комиссия

CODE PRIX
PRICE CODE

X

Pour prix, voir catalogue en vigueur
For price, see current catalogue

CONTENTS

FOREWORD.....	7
INTRODUCTION.....	11
1 Scope.....	13
2 Normative references	15
3 Terms and definitions	17
4 Normal and special service conditions	23
5 Ratings and classifications	25
5.1 LNs on the process level of a high-voltage substation	25
5.2 Additional data and LNs for switchgear monitoring	27
5.3 Communication services.....	29
5.4 Timing requirements.....	37
5.5 Rated classes for data resolution and precision.....	45
5.6 Data security	45
5.7 Data integrity.....	45
5.8 Performance requirements	45
6 Design and construction	47
6.1 General.....	47
6.2 Technological boundaries	57
6.3 Mechanical requirements.....	63
6.4 Electrical requirements.....	63
6.5 EMC.....	63
6.6 Electronic nameplates.....	65
7 Type tests	65
7.1 General.....	65
7.101 Switchgear communication interface conformance tests	65
7.102 Time measurement of switchgear	65
8 Routine tests	75
8.1 General.....	75
8.101 Time measurement on switchgear	75
9 Information to be given with enquiries, tenders and orders	75
10 Rules for transport, storage, installation, operation and maintenance	77
11 Safety.....	77
Annex A (normative) Test overview table	79
Annex B (normative) LNs for sensors and monitoring.....	81
Annex C (normative) Electronic nameplates.....	87

Figure 1 – Calculation of intelligent switchgear operating times (example 1)	39
Figure 2 – Calculation of intelligent switchgear operating times (example 2)	39
Figure 3 – Opening/closing command to intelligent switchgear	41
Figure 4 – Opening/closing command to switchgear	41
Figure 5 – Opening operation of an intelligent circuit-breaker	43
Figure 6 – Closing operation of an intelligent circuit-breaker	43
Figure 7 – GIS (example 1)	47
Figure 8 – AIS circuit-breaker (example 2)	49
Figure 9 – AIS circuit-breaker (example 3)	49
Figure 10 – GIS (example 1) with communication network	51
Figure 11 – GIS (variation of example 1) with serial communication network	53
Figure 12 – AIS circuit-breaker (example 2) with serial communication network	53
Figure 13 – AIS circuit-breaker (example 3) with serial communication network	55
Figure 14 – Switchgear with digital bay control function	57
Figure 15 – Performance test of an intelligent switchgear (configuration 1)	67
Figure 16 – Performance test of intelligent switchgear (configuration 2)	71
Figure B.1 – Switchgear monitoring	81
Table 1 – LNs on process level	25
Table 2 – Additional LNs on process level	27
Table 3 – ACSI basic conformance statement	31
Table 4 – ACSI models conformance statement	33
Table 5 – Additional restrictions for GOOSE	35
Table 6 – ACSI service conformance statement	37
Table 7 – Recommended fibre optic transmission systems	61
Table 8 – Recommended twisted-pair transmission systems	61
Table A.1 – Test overview table	79
Table B.1 – Logical node description for circuit-breaker monitoring	83
Table B.2 – Logical node description for all kinds of switchgear except circuit-breakers	85
Table C.1 – Electronic nameplate for circuit-breakers	87
Table C.2 – Electronic nameplate for switchgear other than circuit-breakers	89
Table C.3 – Conditions for attribute inclusion	91

INTERNATIONAL ELECTROTECHNICAL COMMISSION

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Digital interfaces based on IEC 61850

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardisation comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardisation in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardisation (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 62271-3 has been prepared by subcommittee 17C: High-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This standard has the status of a product family standard and may be used as a normative reference in a dedicated product standard for highvoltage switchgear and controlgear.

This standard is to be read in conjunction with the following documents:

- IEC 61850 series "Communication networks and systems in substations"
- IEC 62271 series "High-voltage switchgear and controlgear".

The text of this standard is based on the following documents:

FDIS	Report on voting
17C/369/FDIS	17C/376/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The following standards are also part of the IEC 62271 series under the general title *High voltage switchgear and controlgear*:

Part 1: Common specifications (in preparation)

Part 2: Seismic qualification for rated voltages of 72,5 kV and above.

The committee has decided that the contents of this publication will remain unchanged until the maintenance result date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

ITEH STANDARD PREVIEW
(standards.iteh.ai)

SIST EN 62271-3:2007

<https://standards.iteh.ai/catalog/standards/sist/7a03a0e2-59c9-4cf6-a6d8-70d855483ed3/sist-en-62271-3-2007>

0 Introduction

0.1 General

This standard is a product family standard for high-voltage switchgear and controlgear and assemblies thereof. It provides an application of the horizontal standard series IEC 61850 which details a layered substation communication architecture, in the world of high-voltage switchgear and controlgear.

By providing tutorial material such as examples and explanations, it also gives an access for switchgear experts to concepts and methods applied in the IEC 61850 series.

Compared to switchgear equipment, digital communication technology is subject to ongoing changes which are expected to continue in the future. Profound experience with electronics integrated directly into switchgear has yet to be gathered on a broader basis, as this type of equipment is not widely spread in the industry and a change of metabolism has not yet occurred.

This situation is taken into account in this standard by setting an appropriate validity date and by specifying several options to most of the communication-related requirements, such as connectors or fibres.

0.2 Position of this standard in relation to the IEC 61850 series

The IEC 61850 series is a horizontal standard intended to be used for communication and systems in the substation. The most important parts of this series define:

1. Information models for the substation automation system.
These information models include both the models of the switchgear (like circuit-breakers and disconnectors) and other process equipment (like instrument transformers), and the models of the substation automation system (like protection relays).
2. The communication between intelligent electronic devices (IEDs) of the substation automation system.
3. A configuration language used to describe the configuration aspects of the substation automation system.
4. Conformance testing of the communication interfaces of the IEDs of the substation automation system including their data models.

Typically, IEDs like bay level controllers interface to switchgear. In that case, the data models of the switchgear are implemented in these devices. However, this is not the only realization. In the case where electronics are integrated direct into switchgear, the above-mentioned data models should be implemented within the switchgear and the switchgear needs to support a communication interface.

IEC 61850, being a horizontal standard series, leaves many options open in order to support present and future requirements of all sizes of substations at all voltage levels.

HIGH-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 3: Digital interfaces based on IEC 61850

1 Scope

This International Standard is applicable to high-voltage switchgear and controlgear (scope of IEC SC 17A) and assemblies thereof (scope of IEC SC 17C) and specifies equipment for digital communication with other parts of the substation and its impact on testing. This equipment for digital communication, replacing metal parallel wiring, can be integrated into the high-voltage switchgear, controlgear, and assemblies thereof, or can be an external equipment in order to provide compliance for existing switchgear and controlgear and assemblies thereof with the standards of the IEC 61850 series.

This International Standard is a product standard based on the IEC 61850 series. It deals with all relevant aspects of switchgear and controlgear, and assemblies thereof with a serial communication interface according to the IEC 61850 series. In particular it defines:

- a) A selection of the information models from the IEC 61850 series that shall be supported by such switchgear and controlgear, and assemblies thereof.
- b) Conformance classes for the set of communication services that shall be supported by the switchgear and controlgear, and assemblies thereof.
- c) Modifications and extensions to type and routine tests of switchgear and controlgear, and assemblies thereof that are required due to the serial communication interface.
- d) An extension of the IEC 61850 series object model for switchgear monitoring.

NOTE 1 It is intended to integrate the extension of the IEC 61850 series object model for switchgear monitoring into a further revision of the IEC 61850 series. Once this integration is completed, the relevant parts will be removed from this standard.

The document is based on the IEC 61850 series, the horizontal standard series for communication, and specifies the requirements for digital communication equipment used within high-voltage switchgear, controlgear, and assemblies thereof, as well as the relevant testing requirements.

The relevant switchgear standards of the IEC 62271 series are applicable in general, with the additional specifications described in this standard.

NOTE 2 There is a limited activity today concerning switchgear with digital interface for rated voltage levels less than, or equal to, 52 kV. Such switchgear usually does not have integrated digital communication interfaces. If such products are to be developed, this should be done in accordance with the present standard.

NOTE 3 This standard intends to promote interoperability of communication interfaces. Interchangeability is outside the scope of this standard, as there is no requirement for it. Interchangeability is also outside the scope of the IEC 61850 series.

NOTE 4 For an introduction to substation communication and the related terms, definitions and models, refer to IEC 61850-1 which provides an overview of the objectives and requirements of the IEC 61850 series in general. IEC 61850-7-1 provides an overview of modelling techniques.