

### SLOVENSKI STANDARD SIST ISO 9164:1997

01-december-1997

## Hcd`chbU']nc`UW]/U!'=nfU i b'dchfYVbY'hcd`chY'nU'c[fYjUb^Y'dfcghcfcj'jghUbcjUb^g\_1\'n[fUXVU\

Thermal insulation -- Calculation of space heating requirements for residential buildings

Isolation thermique -- Calculs des besoins en chauffage pour les bâtiments résidentiels (standards.iteh.ai)

Ta slovenski standard je istoveten z: ISO 9164:1989

https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-

cad345faf6c2/sist-iso-9164-1997

ICS:

91.120.10 Toplotna izolacija stavb Thermal insulation

SIST ISO 9164:1997 en

SIST ISO 9164:1997

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 9164:1997 https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-cad345faf6c2/sist-iso-9164-1997 SIST ISO 9164:1997

# INTERNATIONAL STANDARD

**ISO** 9164

First edition 1989-08-15

## Thermal insulation — Calculation of space heating requirements for residential buildings

Isolation thermique — Calculs des besoins en chauffage pour les bâtiments iTeh S résidentiels ARD PREVIEW

(standards.iteh.ai)

SIST ISO 9164:1997 https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-cad345faf6c2/sist-iso-9164-1997



Reference number ISO 9164: 1989 (E)

#### **Contents**

|     |                 |  | age -                                   |
|-----|-----------------|--|---|
| Fo  | rewo            | rd   | iv                                      |
| Int | roduc           | V  |   |
| 1   | Scop            | pe   | 1                                       |
| 2   | Norr            | mative references  | 1                                       |
| 3   | Defi            | 1  |   |
| 4   | Gen             | eral considerations  | 2                                       |
| 5   | Calc            | culation method  | REVIEW                                  |
|     | 5.1             | Introduction (standards.iteh   | .a <sup>3</sup> )                       |
|     | 5.2             | Zones  | 3                                       |
| 6   | <b>5.3</b> Fact | Calculation procedure https://standards.itelh.ai/catalog/standards/sist/0e5etcors in equations cad345fat6c2/sist-iso-9164-19 | 8781-c65f-46ea-a5bf<br>997 <sub>4</sub> |
| •   |                 |  | 4                                       |
|     | 6.1             | Transmission and ventilation heat losses   | •                                       |
|     | 6.2             | Internal heat gains and solar gains  | 5                                       |
|     | 6.3             | Utilization factor   | 5                                       |
|     | 6.4             | Internal temperatures  | 5                                       |
|     | 6.5             | Accumulated temperature difference   | 5                                       |
| 7   | Rep             | ort  | 6                                       |
| ıΑ  | nnexe           | es   |   |
| Α   | Bas             | sis of calculation method  | 7                                       |
| В   | Air             | change rates   | 9                                       |

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization Case postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

<sup>©</sup> ISO 1989

| С | Internal heat gains                | 11 |
|---|------------------------------------|----|
| D | Solar heat gains                   | 13 |
| Ε | Utilization factors                | 17 |
| F | Daily average internal temperature | 19 |
| G | Accumulated temperature difference | 21 |

# iTeh STANDARD PREVIEW (standards.iteh.ai)

SIST ISO 9164:1997 https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-cad345faf6c2/sist-iso-9164-1997

#### **Foreword**

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council. They are approved in accordance with ISO procedures requiring at least 75 % approval by the member bodies voting.

International Standard ISO 9164 was prepared by Technical Committee ISO/TC 163,1 Thermal insulation.

SIST ISO 9164:1997

Annex A forms an integral part of this International Standard Annexes B/to/G are for 1-c65f-46ea-a5bf-information only.

cad345faf6c2/sist-iso-9164-1997

#### Introduction

Estimates of the space heating requirements for residential buildings may be needed for several purposes. These include judging compliance with regulations written in terms of energy targets, assessing the effect of possible energy-conserving measures or checking the effectiveness of measures which have been carried out and, on a wider national or international scale, predicting future energy resource requirements.

There exist many detailed and complex computer programs which simulate heat interchange within buildings and with their external environment. Often the use of these is not convenient as they usually require very detailed input information. This International Standard provides a relatively simple calculation procedure which will give sufficiently reliable results for the purposes mentioned above.

### iTeh STANDARD PREVIEW

The method predicts the annual heating requirements. It is based on the fundamental equations for heat transfer in which a number of simplifying assumptions are made, the principal one being to replace continuously varying quantities by appropriate averages. Where the data required cannot be obtained by simple calculation, this International Standard uses of refers to tabulated data.

https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-cad345faf6c2/sist-iso-9164-1997

SIST ISO 9164:1997

# iTeh This page intentionally left blank VIEW (standards.iteh.ai)

SIST ISO 9164:1997 https://standards.iteh.ai/catalog/standards/sist/0e5e8781-c65f-46ea-a5bf-cad345faf6c2/sist-iso-9164-1997

### Thermal insulation — Calculation of space heating requirements for residential buildings

### iTeh STANDARD PREVIEW

#### Scope

This International Standard identifies the terms in the heat 9164 balance equation, and describes a method for the calculation of lards/s1SO 6946-11: 1986, Thermal insulation — Calculation methods the annual energy requirements for the space heating 201st-iso-916 Part 17: Steady state thermal properties of building comresidential buildings. The method cannot be applied to special buildings such as those incorporating passive solar design, greenhouses or sunspaces.

#### Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions

(standards.iteh.ai)
of the standards listed below. Members of IEC and ISO maintain registers of currently valid International Standards.

ponents and building elements.

ISO 6946-2: 1986, Thermal insulation — Calculation methods Part 2 : Thermal bridges of rectangular sections in plane structures.

ISO 7345: 1987, Thermal insulation — Physical quantities and definitions.

#### 3 Definitions and symbols

The terms, symbols and units used are in accordance with ISO 7345. The following additional symbols are specific to this International Standard.

| Term and definition   |  |                        | Unit                     |
|---|--|------------------------|--------------------------|
| 3.1 accumulated temperature difference (to a base temperature): | Sum of (base temperature less mean daily external temperature, if positive) over all days in period considered.                                  | ATD (θ <sub>b</sub> )  | °C                       |
| 3.2 base temperature:   | Internal temperature less temperature increment produced by internal and solar gains.  | $	heta_{	extsf{b}}$    | °C                       |
| 3.3 external temperature  |  | $	heta_{e}$            | °C                       |
| 3.4 internal gains:   | Average rate of heat input to dwelling from internal sources other than space heaters.   | $oldsymbol{arPhi}_{i}$ | w                        |
| 3.5 internal temperature  |  | $\theta_{i}$           | °C                       |
| 3.6 space heating requirement (annual):                         | Energy output from space heaters in one year.  | $Q_{h}$                | J, MJ, GJ,<br>(kWh, MWh) |
| 3.7 space heating requirement (monthly):                        | Energy output from space heaters in one month.   | $Q_{h,m}$              | J, MJ, GJ,<br>(kWh, MWh) |
| 3.8 solar gains:  | Average rate of heat input to dwelling from solar radiation.   | $\Phi_{	extsf{S}}$     | w                        |
| 3.9 specific heat loss:   | Total heat loss from dwelling (by fabric transmission and ventilation) divided by the difference between the internal and external temperatures. | Н                      | W/K                      |
| 3.10 time step:   | Period of integration of the heat balance equation, ar usure at  | t                      | s                        |
| 3.11 utilization factor: https://standards.ii                   | Proportion of the internal and solar gains which contribute to reducing the space heating requirements. cad345faf6c2/sist-iso-9164-1997          | $\eta_{m}$             |                          |

#### **Conversion factors:**

1 W = 0,024 kWh/day 1 kWh/day = 41,7 W 1 MJ = 0,278 kWh 1 kWh = 3,6 MJ

#### 4 General considerations

- **4.1** The factors which together contribute to space heating energy requirements are
  - a) characteristics of the house transmission and ventilation heat losses (allowing for any heat recovery), and thermal capacity;
  - b) characteristics of the heating system particularly control systems and ability to respond to changes in heat requirements;
  - c) internal temperatures the temperature level required by the user and variations in this level both in different parts of the house and at different times of the day;
  - d) internal heat gains other than from the heating system from occupants, cooking and hot water, lighting and electrical appliances;

- e) solar gains;
- f) external weather conditions principally temperature.
- **4.2** This International Standard specifies a method which takes account of these factors, and it follows that data for each of them are required for a calculation. In many cases the necessary information may be contained in national standards or other suitable documents, and these should be used where available. Annexes to this International Standard are provided, however, giving representative values or methods for obtaining representative values for use when the required information is not otherwise available.

There is very wide variation in energy consumption in houses. This can be ascribed to variations in the factors listed above; in principle, to the extent that precise information is available, the calculation can be applied to a single specific dwelling.

However, it should be noted that large variations in consumptions have been observed over groups of nominally identical houses attributable to variations in user requirements and living patterns (e.g. internal temperatures, window opening). Where there is no detailed knowledge of user requirements and living patterns, the calculation is made for a "typical" household.

The calculation can be made either for an "average" year using weather data for the locality concerned averaged over a number of years, or for a particular year using the recorded weather data for that year, depending on the purpose of the calculation. The former would be appropriate for predictive purposes, and the latter when comparing with recorded fuel consumption.

This International Standard gives a method for the calculation of space heating requirements; the energy requirements for other purposes are not included.

The energy balance on which the calculation method is based is defined as including the following:

- a) transmission and ventilation losses from the internal to the external environment;
- b) the net output from the heating system (which differs from the energy input when the fan conversion efficiency is other than unity);
- c) the net internal heat gains, that is the heat actually released to the house from the factors in 4.1 d), which in the case of appliances involving water heating is somewhat less 9164: than the energy input to these appliances (the difference and so being lost in waste water);
- d) the net solar gains, not including any proportion either lost through increased ventilation during periods of high solar gain or contributing to the temperature rising above the set point.

#### 5 Calculation method

#### 5.1 Introduction

The calculation method is based on a steady-state energy balance for the house with an allowance for the dynamic effect of internal and solar gains. Part of the energy needed to maintain a given internal temperature  $\theta_{\rm i}$  comes from the internal and solar gains. The method calculates the remainder which is needed from the space heating system.

The calculation basis, described in annex A, allows for day-byday variations in external temperature, and month-by-month variations in mean solar radiation. The heating requirement for one month is obtained from a summation of the heating requirement for each day in the month, using the average daily values of the temperatures and average monthly values of the gains, thus

$$Q_{\text{h.m}} = \sum \left[ H(\theta_{\text{i}} - \theta_{\text{e}}) - \eta_{\text{m}} (\Phi_{\text{i}} + \Phi_{\text{s}}) \right]_{\text{d.pos}} t \qquad \dots (1)$$

where

 $Q_{\rm h,m}$  is the space heating requirement for month, in joules;

H is the specific heat loss, in watts per kelvin;

- $\theta_{\rm i}$  is the daily average internal temperature, in degrees Celsius:
- $heta_{
  m e}$  is the daily average external temperature, in degrees Celsius
- $\eta_{\rm m}$  is the utilization factor for gains;
- $\Phi_i$  are the average internal gains over month, in watts;
- $\Phi_s$  are the average solar gains over month, in watts;
- t is the number of seconds in a day (86 400);

d,pos signifies that the sum is carried out for all days in the month for which the expression is positive.

NOTE — In equation (1) the daily average internal temperature,  $\theta_{\rm i}$ , can be assumed to be the same for each day in the month, calculated from the monthly average temperatures. Thus only  $\theta_{\rm e}$  varies on a day-by-day basis in the equation.

Equation (1) is conveniently evaluated as

$$Q_{\rm h,m} = H \times ATD(\theta_{\rm b})$$

where  ${\rm ATD}(\theta_{\rm b})$  represents the accumulated daily mean temperature difference to base  $\theta_{\rm b}$  for the locality and month concerned 1).

The annual space heating requirement is obtained from a summation of the requirements for individual months.

NOTE — The above procedure gives the energy output required from the space heaters. This differs from the energy delivered to the dwelling because

- a) the space heating appliance may have a conversion efficiency other than unity;
- b) the delivered energy also includes that required for water heating, lighting and electrical appliances.

#### 5.2 Zones

When the house is heated to the same temperature throughout, it shall be treated as a single zone and the space heating requirement obtained in accordance with 5.3.

<sup>1)</sup> Also known as "variable-base degree-days".

If different design temperatures apply in different parts of the house, it shall be determined on a national basis whether the calculation is made

a) with the house as a single zone, or

b) with the house divided into two zones of different temperature standards.

In the case of a single zone calculation, the internal temperature  $\theta_i$  shall be a spatial average over the house.

In the case of a two-zone calculation, the procedure of 5.3 shall be followed for each zone and the space heating requirements for each zone added together. In this case the specific heat loss, the internal gains and solar gains shall be divided appropriately between the zones.

#### 5.3 Calculation procedure

The annual space heating requirement shall be calculated as follows.

5.3.1 Define the building envelope and calculate the specific thermal loss H in watts per kelvin (see 6.1).

NOTE — The heating season is defined to include all months for which the following apply:

- a) the accumulated temperature difference to the applicable base temperature is greater than zero; and
- b) the gross internal and solar gains do not exceed 2,5 times the

$$\Phi_i + \Phi_s \le 2.5H(\theta_i - \theta_e)$$

#### Factors in equations

Where national standards exist, these should be used to obtain the data required for the calculation, having regard to the considerations given below. If an appropriate national standard does not exist, or contains insufficient information, the necessary data can be obtained from the annexes to this International Standard.

#### Transmission and ventilation heat losses

The parameter H is given by

$$H = H_{\mathsf{T}} + H_{\mathsf{V}}$$

5.3.2 Specify the design internal temperature,  $\theta_{i,d}$ . ANDAwhere PREVIEW

5.3.3 For each month

(standards#itetaai+)∑ IUI

- a) calculate the mean value over the month of the gross in which internal and solar gains  $\Phi_i + \Phi_s$  (see 6.2); https://standards.iteh.ai/catalog/standards/sist/0.558781-66564668-75156. is the area of exposed fabric, in square metres; b) determine the utilization factor  $\eta_m$  for these 3 gains 6c2/sist-iso-9164-1997
- (see 6.3);
- c) for continuous heating, set the mean internal temperature  $\theta_{\rm i}$  equal to  $\theta_{\rm i,d}$  : otherwise determine the mean internal temperature (see 6.4);
- d) find the base temperature  $\theta_{\rm b}$  from

$$\theta_{b} = \theta_{i} - \frac{\eta_{m} (\Phi_{i} + \Phi_{s})}{H}$$

- e) find the accumulated temperature difference to this base temperature ATD( $\theta_h$ ), for the climate concerned (see 6.5):
- f) obtain the space heating requirement for the month

$$Q_{h,m} = H \times ATD(\theta_b)$$

NOTE - Any consistent system of units can be used in the above expression for  $Q_{\mathrm{h,m}}$ . With H expressed in watts per kelvin, then  $\mathrm{ATD}(\theta_{\mathrm{b}})$ expressed in degrees Celsius multiplied by day must be multiplied by 86 400 to obtain  $Q_{\rm h,m}$  in joules.

**5.3.4** Total the space heating requirements for each month in the heating season to obtain the annual requirement,  $Q_h$ :

$$Q_{\rm h} = \Sigma Q_{\rm h.m}$$

U is the thermal transmittance of exposed fabric, in watts per square metre kelvin;

*l* is the length of thermal bridge, in metres;

 $U_1$  is the linear thermal transmittance of thermal bridge, in watts per metre kelvin;

and

$$H_{V} = c \varrho \dot{V}$$

in which

- c is the specific heat capacity of air, in joules per kilogram;
- is the density of air, in kilograms per cubic metre;
- $\dot{V}$  is the volumetric air change rate, in cubic metres per second.

#### 6.1.1 Transmission losses

Simple U-values can be calculated by the methods given in ISO 6946-1. For other values a relevant national standard should be used to calculate U-values or to obtain suitable values from tabulated data.