INTERNATIONAL STANDARD





INTERNATIONAL ORGANIZATION FOR STANDARDIZATION ORGANISATION INTERNATIONALE DE NORMALISATION МЕЖДУНАРОДНАЯ ОРГАНИЗАЦИЯ ПО СТАНДАРТИЗАЦИИ

Bases for design of structures — Actions due to the self-weight of structures, non-structural elements and stored materials — Density

Bases de calculs des constructions – Actions dues au poids propre des structures, des éléments non structuraux et des matériaux entreposés – Masses volumiques

Document Preview

<u>ISO 9194:198'</u>

https://standards.iteh.ai/catalog/standards/iso/3d40413f-9ee7-4bae-831c-0f5d5e74d8c3/iso-9994-1987

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council. They are approved in accordance with ISO procedures requiring at least 75 % approval by the member bodies voting.

International Standard ISO 9194 was prepared by Technical Committee ISO/TC 98, Bases for design of structures.

Users should note that all International Standards undergo revision from time to time and that any reference made herein to any other International Standard implies its latest edition, unless otherwise stated.

<u>ISO 9194:1987</u>

https://standards.iteh.ai/catalog/standards/iso/3d40413f-9ee7-4bae-831c-0f5d5e74d8c3/iso-9194-1987

© International Organization for Standardization, 1987 •

Bases for design of structures — Actions due to the self-weight of structures, non-structural elements and stored materials — Density

0 Introduction

General principles on reliability of structures are given in ISO 2394.

Since at the moment, only insufficient statistical data of densities are available, the values given in this International Standard are deterministic ones. In general they may be interpreted as mean values of densities.

Even these mean values are in some cases different for the same material from one country to another. This is the reason for giving a range of two values for one material in this International Standard.

Each country in its relevant standards should use its traditional values which are in the indicated range.

1 Scope and field of application

This International Standard defines the actions due to the selfweight of structures, non-structural elements and stored materials. It gives the numerical values of their densities.

These actions are to be determined by multiplying the densities by the gravitational acceleration and by the actual volume. The actions caused by the weight of the earth placed on the structures are similarly calculated.

2 Reference

ISO 2394, General principles on reliability of structures.

3 General

3.1 The most important value in determining actions due to the self-weight of structures, non-structural elements and/or that of stored materials is the density.

3.2 For materials having all three dimensions of the same order of magnitude, the densities are expressed in kilograms per cubic metre (kg/m³). For roofings (sheeting materials) having one dimension of smaller order of magnitude than the other two dimensions, the similar quantity will be surface

density, expressed in kilograms per square metre (kg/m²) (mass related to surface area).

3.3 In some countries roofings are considered to be external load, causing pressure on the structure (by analogy with, for example, snow load) — consequently these are expressed in newtons per square metre (N/m^2) or in pascals ¹).

For this reason, roofings (see annex A) are given as surface pressures, together with the values of surface density.

3.4 Densities of stored materials substantially depend on how they are placed. Usually two methods of stocking are distinguished:

a) disorderly storage of materials;

b) orderly storage of materials.

Disorderly or bulky stored materials are stored without bales, forming a natural heap. Orderly stored materials are stored in stocks or piles with or without bales.

4 Density values

4.1 The representative value of the density of materials and/or components of structures, non-structural elements and stored materials is in general determined by the mean value.

The representative value is generally represented by a unique value. In actual design situations, densities may alter due to the difference in quality of workmanship, moisture content, etc. The representative value of the density of earth is represented in the same manner, bearing compactness in mind.

4.2 The representative values of densities of structures and non-structural elements are given in a table in annex A; the representative values of densities of stored materials and densities of earth placed on structures are similarly given in annex B.

4.3 Where the tables give only one density value for one material (or soil), this means that the corresponding nominal values do not normally differ significantly (up to ± 5 %) in dif-

^{1) 1} Pa = 1 N/m^2

ferent countries and the indicated mean value is the average of the nominal values. The range of two values of densities given in the annexes for one material indicates that the mean values of densities for different countries vary between the indicated ones.

This also refers to the angles of repose. However, it should be emphasized that in accordance with the national practice of different countries, angles of repose differ up to $\pm 30~\%$ from those indicated in annex B. Thus values of angles of repose given in annex B are approximate.

,

4.4 For the time being, only limited statistical data are available and the values given in annexes A and B are based on relevant national practice.

iTeh Standards (https://standards.iteh.ai) Document Preview

<u>ISO 9194:1987</u>

https://standards.iteh.ai/catalog/standards/iso/3d40413f-9ee7-4bae-831c-0f5d5e74d8c3/iso-9194-1987

Annex A

Representative values of densities of structural and of non-structural elements

(This annex forms an integral part of the Standard).

This annex gives representative values of the densities of structural and non-structural elements in the form of a table.

| Material | Density kg∕m³ | Material | Density kg∕m³ |
|--|-------------------------|--|-------------------------|
| Wood and substitutes ¹⁾ (air-dried, | | Building bricks and blocks | |
| about 15 % humidity) | | Solid burnt clay brick | |
| Hardwood | | up to 14 MPa (inclusive) compressive | |
| Beech tree (<i>Fagus sylvatica</i>) | 680 | strength | 1 600 |
| Oak tree (<i>Quercus</i>) | 690 | Perforated brick (boles through the brick | 1 000 |
| Peduncular oak (<i>Quercus robur</i>) Brazilian rosowood (<i>Dalbergia nigra</i>) | 640 800 | exceed 25 % of its volume) | |
| Turkey oak (<i>Quercus cerris</i>) | 640 to 770 | hollow brick | 820 to 1 350 |
| Yew tree (Taxus baccata) | 640 | perforated brick | 1 150 to 1 450 |
| Australian hardwood | | Lime-sand brick | 1 700 |
| Box grey (Eucalyptus microcarpa) | | Cob brick, adobe | 1 600 |
| Penda, brown (<i>Xanthostemon chrysanthus</i>) | 1 120 | Refractory brick for general purposes | |
| Softwood | /standa | fireclay | 1 850 |
| Black nine (<i>Pinus Jaricin</i>) | 570 | silica (dinas) | 2 100 |
| Larch tree (Larix decidua) | 550 | D magnesite | 2 800 |
| Norway spruce (<i>Picea</i>) | 430 | chrome magnesite | 3 000 |
| Spruce fir (<i>Pinus eccelsa</i>) | 380 to 440 | corundum | 2 600 |
| Scotch pine (<i>Pinus silvestris</i>) | 490 | Covering bricks | |
| VVnite Willow (Salix alba) Giant poplar (Populus alba) | 410 | Minside wall-covering | 1 600 |
| Trembling poplar (<i>Populus tremula</i>) | /iso/3d40450f- | eoutside façade covering 5e74d8c3/iso-914 | 4-1987 1 800 |
| Ocume (Ocume) | 410 | | 2 000 |
| Conifers | 400 to 600 | with 2 MPa compressive strength | 500 |
| Extruded chipboard | 500 to 750 | with 5 MPa compressive strength | 700 |
| Fibreboard | | with 7,5 MPa compressive strength | 900 |
| hard | 900 to 1 100 | Acid-resistant brick | 2 000 |
| medium-hard | 600 to 850 | Tuff block with 5 MPa compressive strength | 1 100 |
| porous insulating | 250 to 400 | Glass brick, double-walled | 870 to 1 100 |
| Plywood | 750 to 850 | Mortars | |
| Coreboard | 450 to 650 | Lime mortar | 1 200 to 1 800 |
| Natural building stance | | Lime cement mortar | 1 750 to 2 000 |
| Natural building stones | 2 650 to 2 000 | Cement mortar (with 2,5 MPa or greater | |
| Magmatic platonic rocks | 2 500 to 3 000 | compressive strength) | 2 100 |
| | 2 500 to 2 850 | Rock floor mortar | 1 600 |
| | 1 400 10 2 000 | Gypsum mortar | 1 200 to 1 800 |
| Sedimentary rocks | 0 700 | Fireciay mortar | 1 900 |
| sandstone | 2 700 | | 340 |
| porous limestone | 1 700 to 2 200 | avpsum | 340 |
| fresh-water limestone | 2 400 | cement | 440 |
| compact limestone | 2 650 to 2 800 | Bitumen mortar with river sand | 1 700 |
| dolomite | 2 800 | | |
| Transformed rocks | | Concrete ²⁾ | |
| clay slate | 2 600 | Gravel concrete | 2 250 to 2 500 |
| marble | 2 700 | Basalt concrete | 2 300 to 2 500 |

| Material | <mark>Density</mark> kg∕m³ | Material | <mark>Density</mark> kg∕m ³ |
|--|-------------------------------|--|---|
| Crushed rock concrete | 2 200 to 2 500 | Tuff concrete, medium size building block | 1 200 |
| C3-C35 Blast furnace foam slag concrete | 2 300 10 2 500 | Gas silicate, medium size building block | 600 to 800 |
| C3-C10 | 1 600 to 1 900 | 2,5 to 5 MPa compressive strength | 800 to 1 100 |
| Aerated and gas concrete | | 5 to 10 MPa compressive strength | 900 to 1 300 |
| C1,5-C5 | 600 to 1 500 | 10 to 20 MPa compressive strength | 1 000 to 1 600 |
| Expanded clay gravel concrete | 700 +- 1 700 | Inside wall-covering brick | 1 700 |
| | 700 to 1 700 | Outside façade brick Clinker brick | 2 000 |
| | 350 to 700 | Fireclay brick (in fireclay mortar) | 2 000 |
| | | Acid-resistant brick (in bitumen mortar) | 1 900 |
| C3-C6 | 1 400 to 1 600 | Glass brick, double-walled | |
| Lightweight aggregate concrete using sintered | | (in cement mortar) | 1 100 |
| pulverized fuel ash aggregates | 1 600 to 1 850 | Glass brick, coupled on one side | |
| Heat insulating gas concrete | 300 to 900 | (in cement mortar) | 870 |
| Heat insulating pearlite brick and pipeshell | 260 | | |
| Angragates and fillers | | Metals for structures | |
| Aggregates and mers | 1 550 | Structural steel | 7 850 |
| Sanu | 1 700 | Cast iron structure | 7 100 |
| | 1 500 to 1 600 | Aluminium | 2 700 |
| Blast furnace foam slag | 1 700 | | |
| Blast furnace slag, granulated | 1 200 | Covering and other building material | |
| Crushed slag stope of 5 to 40 mm grain size | 1 500 | Asphalt, pure | 2 200 |
| Aerated silicate | 1 000 | Bitumen | 1 000 to 1 400 |
| Pulverized fuel ash (pozzolan) for use as a | s://stai | Tar (pitch) | 1 100 to 1 400 |
| cementitious component in concrete (bulk | | Asbestos cement roofing and covering board | 1 800 to 2 100 |
| density) | 800 to 1 050 | Asbestos cement corrugated board | 1 600 |
| Lightweight concrete aggregate (Lytag) (bulk | 750 to 1 000 | Asbestos cement pipe | 1 800 |
| density) | 750 to 1 000 | Cellulose acetate panel | 1 300 |
| Lightweight aggregate using sintered pulverized | 1 700 to 2 000 | Cement tile | 2 400 |
| | | Mosaic tile | 2 200 |
| Masonry from natural stones | ndaras/1so/304(| Concrete flagstone | 2 200 |
| Rocks of initial setting | | Tile | 1 750 to 2 000 |
| basalt malphir, diorit, gabbro | 3 000 | Face brick (hard façade brick) | 2 500 |
| basalt lava | 2 400 | Stoneware tile | 2 400 |
| granite syngenit porphyt | 2 800 | Soft covering brick | 4 050 |
| trachyt | 2 600 | holed | 1 350 |
| Sedimentary rock | | Fnoxy resin | 1 000 |
| graywacke, sandstone, puddingstone | 2 700 | without filler | 1 150 |
| dense limestone, dolomite, shell limestone | 2 900 | with mineral matter | 2 000 |
| and marble | 2 000 | with fibreglass | 1 800 |
| (e.g. travertin, etc.) | 2 600 | Fenoplast | 1 500 |
| volcanic tuff | 2 000 | Rubber floor | 1 800 |
| Transformed rocks | | | 1 100 |
| gneiss, granulite | 3 000 | Polyamide (e.g. diamid) | 1 100 |
| slate serpantine | 2 800 | Polyester resin, without filler | 1 350 |
| os partano | | Polyethylene | 930 |
| Brick masonry ³⁾ | | Polyisobutylene-base board | 1 350 |
| Ordinary brick | 1 500 | Polymethylacrylate | 1 150 |
| Solid burnt clay brick | | Polypropylene | 930 |
| up to 14 MPa (inclusive) compressive strength | 1 500 to 1 700 | PVC hardboard | 1 400 |
| over 14 MPa compressive strength | 1 900 | PVC flooring board | 1 600 |
| Walls made from brick with holes | | PVC flooring tile | 1 700 |
| or ceramic blocks (depending on the | | Flat glass | 2 600 |
| type of brick and blocks used) | 1 150 to 1 450 | Armoured glass | 3 000 |