

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



Communication networks and systems for power utility automation –  
Part 7-1: Basic communication structure – Principles and models

Réseaux et systèmes de communication pour l'automatisation des systèmes  
électriques –  
Partie 7-1: Structure de communication de base – Principes et modèles



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

[IEC 61850-7-1:2011](mailto:IEC.61850-7-1:2011)

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE



---

**Communication networks and systems for power utility automation –  
Part 7-1: Basic communication structure – Principles and models**

**Réseaux et systèmes de communication pour l'automatisation des systèmes  
électriques –** <https://standards.iteh.ai/catalog/standards/sist/5e0b3350-e48c-436f-9f02-110616161616/iec-61850-7-1-2011>  
**Partie 7-1: Structure de communication de base – Principes et modèles**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

## CONTENTS

FOREWORD.....	8
INTRODUCTION.....	10
1 Scope.....	11
2 Normative references.....	12
3 Terms and definitions.....	13
4 Abbreviated terms.....	13
5 Overview of the IEC 61850 series concepts.....	14
5.1 Objective.....	14
5.2 Topology and communication functions of substation automation systems.....	16
5.3 The information models of substation automation systems.....	16
5.4 Applications modelled by logical nodes defined in IEC 61850-7-4.....	18
5.5 The semantic is attached to data.....	21
5.6 The services to exchange information.....	23
5.7 Services mapped to concrete communication protocols.....	24
5.8 The configuration of the automation system.....	25
5.9 Summary.....	26
6 Modelling approach of the IEC 61850 series.....	27
6.1 Decomposition of application functions and information.....	27
6.2 Creating information models by stepwise composition.....	28
6.3 Example of an IED composition.....	31
6.4 Information exchange models.....	31
6.4.1 General.....	31
6.4.2 Output model.....	33
6.4.3 Input model.....	36
6.4.4 Model for statistical and historical statistical data.....	46
6.4.5 Model for system functions.....	50
7 Application view.....	52
7.1 General.....	52
7.2 First modelling step – Logical nodes and data.....	53
7.3 Mode and behaviour of a logical node.....	57
7.4 Use of measurement ranges and alarms for supervision functions.....	57
7.5 Data used for limiting the access to control actions.....	58
7.6 Data used for blocking functions described by logical nodes.....	58
7.7 Data used for logical node inputs/outputs blocking (operational blocking).....	58
7.7.1 General.....	58
7.7.2 Blocking incoming commands.....	59
7.7.3 Blocking process outputs.....	59
7.7.4 Blocking oscillating inputs.....	60
7.8 Data used for testing.....	60
7.8.1 General.....	60
7.8.2 Multicast signals used for simulation.....	60
7.8.3 Input signals used for testing.....	61
7.8.4 Test mode.....	62
7.9 Logical node used for extended logging functions.....	62
8 Device view.....	63
8.1 General.....	63

8.2	Second modelling step – logical device model.....	64
8.2.1	The logical device concept .....	64
8.2.2	The device nameplate .....	65
8.2.3	Gateways and proxies .....	66
8.2.4	Logical devices for monitoring external device health .....	67
8.2.5	Logical devices management hierarchy .....	68
9	Communication view.....	70
9.1	General.....	70
9.2	The service models of the IEC 61850 series.....	70
9.3	The virtualisation.....	72
9.4	Basic information exchange mechanisms .....	73
9.5	The client-server building blocks .....	75
9.5.1	Server .....	75
9.5.2	Client-server roles .....	76
9.6	Logical nodes communicate with logical nodes.....	77
9.7	Interfaces inside and between devices .....	78
10	Where physical devices, application models and communication meet .....	79
11	Relationships between IEC 61850-7-2, IEC 61850-7-3 and IEC 61850-7-4 .....	80
11.1	Refinements of class definitions .....	80
11.2	Example 1 – Logical node and data class.....	81
11.3	Example 2 – Relationship of IEC 61850-7-2, IEC 61850-7-3, and IEC 61850-7-4... ..	85
12	Formal specification method (standards.iteh.ai).....	86
12.1	Notation of ACSI classes.....	86
12.2	Class modelling.....	87
12.2.1	Overview.....	87
12.2.2	Common data class.....	88
12.2.3	Logical node class.....	91
12.3	Service tables .....	92
12.4	Referencing instances.....	93
13	Name spaces .....	96
13.1	General.....	96
13.2	Name spaces defined in the IEC 61850-7-x series.....	97
13.3	Specification of name spaces .....	101
13.3.1	General .....	101
13.3.2	Specification.....	101
13.4	Attributes for references to name spaces .....	102
13.4.1	General .....	102
13.4.2	Attribute for logical device name space (ldNs) .....	103
13.4.3	Attribute for logical node name space (lnNs).....	103
13.4.4	Attribute for data name space (dataNs) .....	104
13.4.5	Attribute for common data class name space (cdcNs).....	104
14	Common rules for new version of classes and for extension of classes.....	104
14.1	General.....	104
14.2	Basic rules .....	104
14.3	Rules for LN classes .....	105
14.3.1	Use of standardized LN classes.....	105
14.3.2	Extensions to standardized LN classes made by third parties .....	106
14.3.3	New LN classes.....	106

14.3.4	New versions of standardized LN classes made by name space owners .....	107
14.4	Rules for common data classes and control block classes .....	107
14.4.1	New common data classes and control block classes .....	107
14.4.2	New versions of standardized common data classes .....	107
14.4.3	New versions of control block classes.....	107
14.5	Multiple instances of LN classes for dedicated and complex functions.....	108
14.5.1	Example for time overcurrent.....	108
14.5.2	Example for PDIS .....	108
14.5.3	Example for power transformer.....	108
14.5.4	Example for auxiliary network .....	108
14.6	Specialisation of data by use of number extensions.....	109
14.7	Examples for new LNs.....	109
14.8	Example for new Data .....	109
Annex A	(informative) Overview of logical nodes and data .....	110
Annex B	(informative) Allocation of data to logical nodes .....	113
Annex C	(informative) Use of the substation configuration language (SCL) .....	116
Annex D	(informative) Applying the LN concept to options for future extensions .....	118
Annex E	(informative) Relation between logical nodes and PICOMs .....	123
Annex F	(informative) Mapping the ACSI to real communication systems.....	124
Bibliography	.....	132
Figure 1	– Relations between modelling and mapping parts of the IEC 61850 series .....	14
Figure 2	– Sample substation automation topology.....	16
Figure 3	– Modelling approach (conceptual).....	17
Figure 4	– Logical node information categories .....	20
Figure 5	– Build-up of devices (principle) .....	20
Figure 6	– Position information depicted as a tree (conceptual) .....	21
Figure 7	– Service excerpt .....	23
Figure 8	– Example of communication mapping .....	25
Figure 9	– Summary .....	26
Figure 10	– Decomposition and composition process (conceptual).....	27
Figure 11	– XCBR1 information depicted as a tree.....	30
Figure 12	– Example of IED composition.....	31
Figure 13	– Output and input model (principle) .....	32
Figure 14	– Output model (step 1) (conceptual) .....	33
Figure 15	– Output model (step 2) (conceptual) .....	34
Figure 16	– GSE output model (conceptual).....	34
Figure 17	– Setting data (conceptual) .....	35
Figure 18	– Input model for analogue values (step 1) (conceptual) .....	37
Figure 19	– Range and deadbanded value (conceptual).....	38
Figure 20	– Input model for analogue values (step 2) (conceptual) .....	39
Figure 21	– Reporting and logging model (conceptual).....	40
Figure 22	– Data set members and reporting .....	41
Figure 23	– Buffered report control block (conceptual).....	42

  
 (standards.iteh.ai)

IEC 61850-7-1:2011

<https://standards.iteh.ai/catalog/standards/siv/5e0b3350-e48c-436f-9102-11d15b0074ee/iec-61850-7-1-2011>

Figure 24 – Buffer time .....	43
Figure 25 – Data set members and inclusion-bitstring .....	44
Figure 26 – Log control block (conceptual).....	44
Figure 27 – Peer-to-peer data value publishing model (conceptual) .....	45
Figure 28 – Conceptual model of statistical and historical statistical data (1) .....	47
Figure 29 – Conceptual model of statistical and historical statistical data (2) .....	49
Figure 30 – Concept of the service tracking model – Example: control service tracking.....	51
Figure 31 – Real world devices .....	52
Figure 32 – Logical nodes and data (IEC 61850-7-2) .....	53
Figure 33 – Simple example of modelling.....	55
Figure 34 – Basic building blocks.....	55
Figure 35 – Logical nodes and PICOM.....	56
Figure 36 – Logical nodes connected (outside view in IEC 61850-7-x series).....	56
Figure 37 – Mode and behaviour data (IEC 61850-7-4).....	57
Figure 38 – Data used for limiting the access to control actions (IEC 61850-7-4) .....	58
Figure 39 – Data used for logical node inputs/outputs blocking (IEC 61850-7-4) .....	59
Figure 40 – Data used for receiving simulation signals.....	60
Figure 41 – Example of input signals used for testing .....	61
Figure 42 – Test mode example.....	62
Figure 43 – Logical node used for extended logging functions (GLOG) .....	63
Figure 44 – Logical device building block.....	64
Figure 45 – Logical devices and LLN0/LPHD .....	65
Figure 46 – The common data class DPL .....	66
Figure 47 – Logical devices in proxies or gateways.....	67
Figure 48 – Logical devices for monitoring external device health .....	68
Figure 49 – Logical devices management hierarchy .....	69
Figure 50 – ACSI communication methods.....	71
Figure 51 – Virtualisation .....	73
Figure 52 – Virtualisation and usage .....	73
Figure 53 – Information flow and modelling .....	74
Figure 54 – Application of the GSE model.....	74
Figure 55 – Server building blocks .....	75
Figure 56 – Interaction between application process and application layer (client/server) .....	76
Figure 57 – Example for a service.....	76
Figure 58 – Client/server and logical nodes .....	77
Figure 59 – Client and server roles .....	77
Figure 60 – Logical nodes communicate with logical nodes.....	78
Figure 61 – Interfaces inside and between devices .....	79
Figure 62 – Component hierarchy of different views (excerpt).....	80
Figure 63 – Refinement of the DATA class.....	81
Figure 64 – Instances of a DATA class (conceptual) .....	84
Figure 65 – Relation between parts of the IEC 61850 series .....	85

Figure 66 – Abstract data model example for IEC 61850-7-x.....	87
Figure 67 – Relation of TrgOp and Reporting.....	90
Figure 68 – Sequence diagram.....	92
Figure 69 – References.....	93
Figure 70 – Use of FCD and FCDA.....	94
Figure 71 – Object names and object reference.....	95
Figure 72 – Definition of names and semantics.....	96
Figure 73 – One name with two meanings.....	97
Figure 74 – Name space as class repository.....	98
Figure 75 – All instances derived from classes in a single name space.....	99
Figure 76 – Instances derived from multiple name spaces.....	100
Figure 77 – Inherited name spaces.....	100
Figure 78 – Basic extension rules diagram.....	105
Figure B.1 – Example for control and protection LNs combined in one physical device.....	113
Figure B.2 – Merging unit and sampled value exchange (topology).....	114
Figure B.3 – Merging unit and sampled value exchange (data).....	114
Figure C.1 – Application of SCL for LNs (conceptual).....	116
Figure C.2 – Application of SCL for data (conceptual).....	117
Figure D.1 – Seamless communication (simplified).....	118
Figure D.2 – Example for new logical nodes.....	119
Figure D.3 – Example for control center view and mapping to substation view.....	121
Figure E.1 – Exchanged data between subfunctions (logical nodes).....	123
Figure E.2 – Relationship between PICO MS and client/server model.....	123
Figure F.1 – ACSI mapping to an application layer.....	124
Figure F.2 – ACSI mappings (conceptual).....	125
Figure F.3 – ACSI mapping to communication stacks/profiles.....	126
Figure F.4 – Mapping to MMS (conceptual).....	126
Figure F.5 – Mapping approach.....	127
Figure F.6 – Mapping detail of mapping to a MMS named variable.....	128
Figure F.7 – Example of MMS named variable (process values).....	128
Figure F.8 – Use of MMS named variables and named variable list.....	129
Figure F.9 – MMS information report message.....	130
Figure F.10 – Mapping example.....	131
Table 1 – LN groups.....	18
Table 2 – Logical node class XC BR (conceptual).....	29
Table 3 – Excerpt of integer status setting.....	36
Table 4 – Comparison of the data access methods.....	41
Table 5 – ACSI models and services.....	71
Table 6 – Logical node circuit breaker.....	82
Table 7 – Controllable double point (DPC).....	83
Table 8 – ACSI class definition.....	86
Table 9 – Single point status common data class (SPS).....	88



Table 10 – Quality components attribute definition .....	89
Table 11 – Basic status information template (excerpt) .....	89
Table 12 – Trigger option .....	90
Table 13 – GenLogicalNodeClass definition .....	91
Table 14 – Excerpt of logical node name plate common data class (LPL) .....	103
Table 15 – Excerpt of common data class .....	103
Table A.1 – Excerpt of data classes for measurands .....	111
Table A.2 – List of common data classes (excerpt) .....	112

## **iTeh STANDARD PREVIEW** **(standards.iteh.ai)**

[IEC 61850-7-1:2011](https://standards.iteh.ai/catalog/standards/sist/5e0b3350-e48c-436f-9f02-4b962c81cd0b/iec-61850-7-1-2011)

<https://standards.iteh.ai/catalog/standards/sist/5e0b3350-e48c-436f-9f02-4b962c81cd0b/iec-61850-7-1-2011>

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**COMMUNICATION NETWORKS AND  
SYSTEMS FOR POWER UTILITY AUTOMATION –**

**Part 7-1: Basic communication structure –  
Principles and models**

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61850-7-1 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this document is based on the following documents:

FDIS	Report on voting
57/1121/FDIS	57/1145/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This second edition cancels and replaces the first edition published in 2003. This second edition constitutes a technical revision.

Compared to the first edition, this second edition introduces:

- the model for statistical and historical statistical data,
- the concepts of proxies, gateways, LD hierarchy and LN inputs,
- the model for time synchronisation,
- the concepts behind different testing facilities,
- the extended logging function.

It also clarifies the following points:

- the use of numbers for data extension,
- the use of name spaces,
- the mode and behaviour of a logical node,
- the use of range and deadbanded values,
- the access to control actions and others.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61850 series, under the general title: *Communication networks and systems for power utility automation* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed, [IEC 61850-7-1:2011](#)
- withdrawn, <https://standards.iteh.ai/catalog/standards/sist/5e0b3350-e48c-436f-9f02-4b962c81cd0b/iec-61850-7-1-2011>
- replaced by a revised edition, or
- amended.

**IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.**

## INTRODUCTION

This part of the IEC 61850 series provides an overview of the architecture for communication and interactions between systems for power utility automation such as protection devices, breakers, transformers, substation hosts etc.

This document is part of a set of specifications which details a layered communication architecture for power utility automation. This architecture has been chosen to provide abstract definitions of classes (representing hierarchical information models) and services such that the specifications are independent of specific protocol stacks, implementations, and operating systems.

The goal of the IEC 61850 series is to provide interoperability between the IEDs from different suppliers or, more precisely, between functions to be performed by systems for power utility automation but residing in equipment (physical devices) from different suppliers. Interoperable functions may be those functions that represent interfaces to the process (for example, circuit breakers) or substation automation functions such as protection functions. This part of the IEC 61850 series uses simple examples of functions to describe the concepts and methods applied in the IEC 61850 series.

This part of the IEC 61850 series describes the relationships between other parts of the IEC 61850 series. Finally this part defines how interoperability is reached.

NOTE Interchangeability is the ability to replace a device from the same vendor, or from different vendors, utilising the same communication interface and as a minimum, providing the same functionality, with no impact on the rest of the system. If differences in functionality are accepted, the exchange may also require some changes somewhere else in the system. Interchangeability implies a standardisation of functions and, in a strong sense, of devices which are outside the scope of this standard. Interchangeability is outside the scope, but it will be supported following this standard for interoperability.

This part of the IEC 61850 series is intended for all stakeholders of standardised communication and standardised systems in the utility industry. It provides an overview of and an introduction to IEC 61850-7-4, IEC 61850-7-3, IEC 61850-7-2, IEC 61850-6, and IEC 61850-8-1.

## COMMUNICATION NETWORKS AND SYSTEMS FOR POWER UTILITY AUTOMATION –

### Part 7-1: Basic communication structure – Principles and models

#### 1 Scope

This part of the IEC 61850 series introduces the modelling methods, communication principles, and information models that are used in the various parts of the IEC 61850-7-x series. The purpose of this part of the IEC 61850 series is to provide – from a conceptual point of view – assistance to understand the basic modelling concepts and description methods for:

- substation-specific information models for power utility automation systems,
- device functions used for power utility automation purposes, and
- communication systems to provide interoperability within power utility facilities.

Furthermore, this part of the IEC 61850 series provides explanations and provides detailed requirements relating to the relation between IEC 61850-7-4, IEC 61850-7-3, IEC 61850-7-2 and IEC 61850-5. This part explains how the abstract services and models of the IEC 61850-7-x series are mapped to concrete communication protocols as defined in IEC 61850-8-1.

The concepts and models provided in this part of the IEC 61850 series may also be applied to describe information models and functions for:

- hydroelectric power plants,
- substation to substation information exchange,
- information exchange for distributed automation,
- substation to control centre information exchange,
- information exchange for metering,
- condition monitoring and diagnosis, and
- information exchange with engineering systems for device configuration.

NOTE 1 This part of IEC 61850 uses examples and excerpts from other parts of the IEC 61850 series. These excerpts are used to explain concepts and methods. These examples and excerpts are informative in this part of IEC 61850.

NOTE 2 Examples in this part use names of classes (e.g. XCBR for a class of a logical node) defined in IEC 61850-7-4, IEC 61850-7-3, and service names defined in IEC 61850-7-2. The normative names are defined in IEC 61850-7-4, IEC 61850-7-3, and IEC 61850-7-2 only.

NOTE 3 This part of IEC 61850 does not provide a comprehensive tutorial. It is recommended that this part be read first – in conjunction with IEC 61850-7-4, IEC 61850-7-3, and IEC 61850-7-2. In addition, it is recommended that IEC 61850-1 and IEC 61850-5 also be read.

NOTE 4 This part of IEC 61850 does not discuss implementation issues.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61850-2, *Communication networks and systems in substations – Part 2: Glossary*

IEC 61850-3, *Communication networks and systems in substations – Part 3: General requirements*

IEC 61850-4, *Communication networks and systems for power utility automation – Part 4: System and project management*

IEC 61850-5, *Communication networks and systems in substations – Part 5: Communication requirements for functions and device models*

IEC 61850-6, *Communication networks and systems for power utility automation – Part 6: Configuration description language for communication in electrical substations related to IEDs*

IEC 61850-7-2, *Communication networks and systems for power utility automation – Part 7-2: Basic information and communication structure – Abstract communication service interface (ACSI)*

IEC 61850-7-3, *Communication networks and systems for power utility automation – Part 7-3: Basic communication structure – Common data classes*

IEC 61850-7-4, *Communication networks and systems for power utility automation – Part 7-4: Basic communication structure – Compatible logical node classes and data object classes*

IEC 61850-8-1, *Communication networks and systems for power utility automation – Part 8-1: Specific Communication Service Mapping (SCSM) – Mappings to MMS (ISO 9506-1 and ISO 9506-2) and to ISO/IEC 8802-3*

IEC 61850-9-2, *Communication networks and systems in substations – Part 9-2: Specific Communication Service Mapping (SCSM) – Sampled values over ISO/IEC 8802-3*

IEC 61850-10, *Communication networks and systems in substations – Part 10: Conformance testing*

ISO/IEC 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO/IEC 8825 (all parts), *Information technology – ASN.1 encoding rules*

ISO 9506-1, *Industrial automation systems – Manufacturing Message Specification – Part 1: Service definition*

ISO 9506-2, *Industrial automation systems – Manufacturing Message Specification – Part 2: Protocol specification*

### 3 Terms and definitions

For the purposes of this document, the terms and definitions given in IEC 61850-2 as well as the following apply.

#### 3.1 information

knowledge concerning objects, such as facts, events, things, processes, or ideas, including concepts, that within a certain context has a particular meaning

[IEC 60050-101:1998, 101-12-01]

#### 3.2 information model

knowledge concerning power utility functions and devices in which the functions are implemented

This knowledge is made visible and accessible through the means of the IEC 61850 series. The model describes in an abstract way a communication-oriented representation of a real function or device.

#### 3.3 model

a representation of some aspect of reality

The purpose of creating a model is to help understand, describe, or predict how things work in the real world by exploring a simplified representation of a particular entity or phenomenon. The focus of the model defined in IEC 61850-7-x is on the communication features of the data and functions modelled.

<https://standards.iteh.ai/catalog/standards/sist/5e0b3350-e48c-436f-9f02-4b962c81cd0b/iec-61850-7-1-2011>

### 4 Abbreviated terms

ACSI	Abstract communication service interface
ASN.1	Abstract syntax notation one
API	Application program interface
CDC	Common data class
CT	Current transformer
DST	Daylight saving time
GOOSE	Generic oriented object system event
IED	Intelligent electronic device
LD	Logical device
LN	Logical node
LLNO	Logical node zero
LPHD	Logical node physical device
MMS	Manufacturing message specification
PHD	Physical device