

INTERNATIONAL STANDARD

ISO 9509

First edition
1989-10-15

Water quality — Method for assessing the inhibition of nitrification of activated sludge micro-organisms by chemicals and waste waters

iTeh STANDARD PREVIEW
(standards.iteh.ai)

*Qualité de l'eau — Méthode pour l'évaluation de l'effet inhibiteur sur la nitrification
par des micro-organismes de boues activées par des produits chimiques ou des
eaux résiduaires*

ISO 9509:1989

[https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-
ce34233f6a96/iso-9509-1989](https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989)



Reference number
ISO 9509 : 1989 (E)

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

Draft International Standards adopted by the technical committees are circulated to the member bodies for approval before their acceptance as International Standards by the ISO Council. They are approved in accordance with ISO procedures requiring at least 75 % approval by the member bodies voting.

International Standard ISO 9509 was prepared by Technical Committee ISO/TC 147 *Water quality*.

Annexes A and B form an integral part of this International Standard. Annex C is for information only.

<http://standards.iteh.ai/>

<http://standards.iteh.ai/iso-9509-1989>

© ISO 1989

All rights reserved. No part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from the publisher.

International Organization for Standardization
Case postale 56 • CH-1211 Genève 20 • Switzerland

Printed in Switzerland

Water quality — Method for assessing the inhibition of nitrification of activated sludge micro-organisms by chemicals and waste waters

WARNING — Activated sludges may contain pathogenic organisms, therefore take appropriate precautions when handling them.

Handle toxic test substances and those with unknown properties with care.

1 Scope

1.1 This International Standard specifies a method for assessing the short-term inhibitory effects of test substances on nitrifying bacteria in activated sludge. The inhibitory effect is estimated over an exposure period of 4 h.

1.2 The method is suitable for use with nitrifying activated sludge derived from domestic sewage. It is also possible to use nitrifying sludges derived from synthetic sewage.

1.3 Initially, the nitrifying activity of the activated sludge is verified by addition of a specific inhibitor (e.g. allylthiourea).

If the nitrification rate (see 8.1) is within a suitable range for the test [2 to 6,5 milligrams of nitrogen per gram suspended solids per hour (2 mg of N/(g.h) to 6,5 mg of N/(g.h)], the sludge is used directly; if not, adjustments are necessary (see clause 9).

1.4 The method is applicable to non-volatile chemical substances which are soluble in water and also to waste waters. It is possible to use insoluble substances, if care is taken to ensure as much homogeneity as possible.

1.5 It is important to stress that sludges from different sources respond differently to a given concentration of an inhibitor and this is probably due, at least in part, to reaction between the inhibitor and components of the sludge resulting in a partial nullifying of the toxic effect. Also, since the test lasts only 4 h, it must be borne in mind that any inhibitory effects may diminish, or increase, over a longer period, e.g. in the continuous activated sludge system.

2 Normative references

The following standards contain provisions which, through reference in this text, constitute provisions of this International Standard. At the time of publication, the editions indicated

were valid. All standards are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the standards indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

ISO 6107-1: 1986, *Water quality — Vocabulary — Part 1*.

ISO 6107-3: 1985, *Water quality — Vocabulary — Part 3*.

3 Definitions

For the purposes of this International Standard, the following definitions apply.

3.1 test chemical: Pure chemicals, mixtures, chemical products and waste waters.

3.2 activated sludge: Accumulated biological mass (floc) produced in the treatment of waste water by the growth of bacteria and other micro-organisms in the presence of dissolved oxygen. [ISO 6107-1.]

3.3 mixed liquor suspended solids (MLSS): The concentration of solids, expressed in a specified dried form, in the mixed liquor. [ISO 6107-3.]

NOTE — In this International Standard, the MLSS are determined after filtration of a known volume and drying at about 100 °C. They are expressed in milligrams per litre or grams per litre.

3.4 EC 50: Concentration of test material giving a calculated or interpolated inhibition of nitrification of 50 % compared with a control containing no test material.

3.5 nitrification: The oxidation of ammonium salts by bacteria. Usually, the end product of such an oxidation is nitrate. [ISO 6107-1].

NOTE — Nitrites may be formed as intermediate products.

4 Principle

Performance of the test at a constant temperature, usually between 20 °C and 25 °C, in an atmosphere free from dust and toxic vapours. Parallel aeration of a nitrifying sludge in the presence and absence of test material and assessment of the difference in concentration of oxidized nitrogen (nitrite N plus nitrate N) produced by the oxidation of ammonium salts. Calculation of the inhibition of nitrification of activated sludge micro-organisms by the test material.

5 Reagents and materials

5.1 Water, deionized or distilled.

5.2 Nitrifying activated sludge

Obtain a portion of sludge from a nitrifying treatment plant receiving domestic sewage or from a laboratory-scale plant treating domestic or synthetic sewage. Maintain the sludge in an aerobic condition and preferably use within 24 h of collection.

Before use, centrifuge the sludge (e.g. 1 100 g during 5 min) and discard the supernatant liquid. Wash the residue with an equal volume of water (5.1), dilute the resulting mixture with ten times the volume of medium (5.3), re-centrifuge and again discard the supernatant liquid. Finally, resuspend the sludge in an appropriate volume of medium (5.3) to give the required concentration of mixed liquor suspended solids (e.g. 3 g/l) and aerate until use.

5.3 Medium

Dissolve 5,04 g of sodium hydrogencarbonate (NaHCO_3) and 2,65 g of ammonium sulfate [$(\text{NH}_4)_2\text{SO}_4$] in 1 litre of water (5.1).

NOTE — This medium, when diluted 1 : 10, contains 56 mg/l of N and has a pH value of about 7,6. It allows the production of at least 25 mg/l of oxidized nitrogen without changing the pH.

5.4 Reference inhibitor

Dissolve 1,16 g of allylthiourea (ATU) in 1 litre of water (5.1)

NOTE — Other inhibitors may be used, e.g. 2-chloro-6-(trichloromethyl)pyridine, but the concentration required and mode of addition would have to be investigated.

5.5 Stock solution of test material

Prepare a stock solution or suspension of test substance in distilled water (5.1) at a suitable concentration, e.g. 1 g/l or 10 g/l. It is possible to use waste water without dilution.

6 Apparatus

6.1 Conical flasks, e.g. of capacity 500 ml.

6.2 Pasteur pipettes, or other aeration device.

6.3 Compressed air supply, humidified by passage through a wash bottle containing water.

6.4 Shaker (alternative to aeration during incubation of test mixtures).

6.5 Apparatus, necessary for analytical determination of ammonia and oxidized nitrogen in solution.

6.6 Filtration apparatus.

6.7 Filter, made of glass fibre or paper which does not release nitrogen.

7 Procedure

7.1 Use sludges with specific nitrification rates between 2 mg of N/(g·h) and 6,5 mg of N/(g·h). If the rate is outside this range, it is essential to modify the procedure (see clause 9).

7.2 Add equal volumes of washed nitrifying sludge (5.2) to a series of 500 ml conical flasks (6.1) so that the final concentration of mixed liquor suspended solids will be approximately 1 500 mg/l (see table B.1).

Add 25 ml of medium (5.3) to each flask and add one of a range of volumes (usually five) of test solution (5.5) and sufficient distilled water (5.1) to make the final volume up to 250 ml (see annex B).

Include a control flask with sludge, medium and water but no test substance, and a reference flask with sludge, medium, water and 2,5 ml of reference inhibitor (5.4). If required (as an extra check) take a sample of the control to determine the concentration of ammonia.

7.3 Incubate all flasks for 4 h at a constant temperature (see clause 4) and aerate either with humidified compressed air (6.3), using Pasteur pipettes, or shake to keep the sludge in suspension and the concentration of dissolved oxygen above 2 mg/l. Incubate in the dark or in diffused light.

NOTE — Strong waste waters may require extra aeration to maintain the concentration of dissolved oxygen above 2 mg/l.

7.4 After 4 h, take a suitable volume of sample from each flask for analysis of oxidized nitrogen and ammonia concentrations. Before analysis, filter the samples through a glass fibre or washed paper filter (6.7).

7.5 An example of the volumes required for setting up the test is shown in annex B.

8 Calculation and expression of results

8.1 Calculate the percentage inhibition of formation of oxidized nitrogen N as follows:

$$\% \text{ inhibition} = \frac{C_c - C_t}{C_c - C_b} \times 100 \quad \dots (1)$$

where

C_c is the concentration of oxidized nitrogen, N, in milligrams per litre, in the control flask without inhibitor, after incubation;

C_t is the concentration of oxidized nitrogen N, in milligrams per litre, in the flask containing the test substance, after incubation;

C_b is the concentration of oxidized nitrogen, in milligrams per litre, in the flask containing the reference inhibitor, after incubation.

If the sample tested contains nitrate, e.g. a waste water from an area where tap water contains significant concentrations of nitrate, make allowance for this by subtracting from C_t the concentrations of nitrate in the reaction mixtures derived from the sample.

NOTE — Although the measurement of oxidized nitrogen is preferable, the percentage inhibition of ammonia removal may be substituted as follows, but it is important to note that disappearance of ammonia is not necessarily due to nitrification.

$$\% \text{ inhibition} = \frac{C_i - C_e}{C_o - C_e} \times 100 \quad \dots (2)$$

where

C_i is the concentration of ammonia, in milligrams per litre, in the test flask after incubation;

C_e is the concentration of ammonia, in milligrams per litre, in the control after incubation;

C_o is the concentration of ammonia, in milligrams per litre, at the beginning of the test.

iTeh STANDARD PREVIEW

10 Test report

8.2 Plot a graph of the percentage inhibition against the log of the concentration of inhibitor and interpolate the EC 50 from this.

Alternatively, use a linear regression programme to estimate the EC 50.

The test report shall refer to this International Standard and contain the following information:

- a) name and specification of the test substance;
- b) the specific nitrification rate of the activated sludge;
- c) the source, concentration and pretreatment method of the activated sludge;
- d) the test results, the EC 50 and all measured data and the inhibition curve;
- e) the inhibition caused by the reference specific inhibitor;
- f) the test temperature, with limits;
- g) any other facts, not specified in this International Standard, that are relevant concerning the procedure followed.

9 Validity of results

Verify the nitrifying activity of the sludge by comparison of the results from the control and the flask containing the reference inhibitor. After the 4 h incubation period it is essential that the oxidized nitrogen concentration has not increased in the presence of the reference inhibitor, since this specifically inhibits nitrification. (See annex A.)

Annex A (normative)

Determination of the nitrifying activity of an activated sludge

Add equal volumes of washed activated sludge (e.g. 125 ml), of known suspended solids concentration (approximately 3 g/l) to two 500 ml conical flasks. Add 25 ml of medium (5.3) to each flask and 2,5 ml of reference inhibitor (5.4) to one flask only. Then make up the volume in each flask to 250 ml with distilled water (5.1). Aerate or shake the flasks for 4 h so that good mixing is achieved, the solids are kept in suspension and the concentration of dissolved oxygen is at least 2 mg/l.

After 4 h, take a sample from each flask and filter it, e.g. through glass fibre or paper filters and retain the filtrates for determination of the concentration of ammonia and oxidized nitrogen (nitrite plus nitrate).

Calculate from these results the specific nitrification rate in milligrams of nitrogen per gram hour as follows:

$$\frac{C_t - C_b}{MLSS \times 4} \quad \dots (A.1)$$

where

C_t is the concentration of oxidized nitrogen, in milligrams per litre, in the reaction mixture after 4 h;

C_b is the concentration of oxidized nitrogen, in milligrams per litre, in the mixture plus reference inhibitor, after 4 h;

$MLSS$ is the concentration, in grams per litre, of mixed liquor suspended solids in the test flask.

NOTE — Alternatively the concentration of ammonium after 4 h can be used as follows, but it is important to note that disappearance of ammonium may not necessarily be due to nitrification.

The specific rate of nitrification, in milligrams of ammonium N per gram hour is

$$\frac{C_b(NH_4) - C_t(NH_4)}{MLSS \times 4} \quad \dots (A.2)$$

where

$C_b(NH_4)$ is the concentration of ammonium, in milligrams per litre, in the mixture plus reference inhibitor;

$C_t(NH_4)$ is the concentration of ammonium, in milligrams per litre, in the reaction mixture.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

ISO 9509:1989
<https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989>

Annex B (normative)

Example for preparation of the test

Table B.1

Flask No.	1	2	3	4	5	6	7
Medium (5.3) (ml)	25	25	25	25	25	25	25
Activated sludge (ml)	125	125	125	125	125	125	125
Reference inhibitor ATU (5.4) (ml)	0	0	0	0	0	0	2,5
Distilled water (5.1) (ml)	100	99,75	99,2	97,5	92	75	97,5
Stock solution ¹⁾ of test material (ml)	0	0,25	0,8	2,5	8,0	25	0
Concentration of test substance (mg/l)	0	1	3,2	10	32	100	0
Total volume (ml)	250	250	250	250	250	250	250
Concentration of activated sludge = 3,0 g of suspended solids per litre.							
1) Stock solution: 1 g of test substance per litre.							
NOTE – Undiluted test substance must not be allowed to come into contact with the sludge.							

(standards.iteh.ai)

[ISO 9509:1989](https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989)

<https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989>

Annex C
(informative)

Bibliography

- [1] ISO 6777 : 1984, *Water quality — Determination of nitrite — Molecular absorption spectrometric method.*
- [2] ISO 7150-1 : 1984, *Water quality — Determination of ammonium — Part 1: Manual spectrometric method.*
- [3] ISO 7890-1 : 1986, *Water quality — Determination of nitrate — Part 1: 2,6-Dimethylphenol spectrometric method.*
- [4] EUROPEAN ECONOMIC COMMUNITIES, Activated sludge simulation tests. *EEC Directive 79/831 Annex V, DG XI/605/82 (1986).*
- [5] PAINTER, H.A., A review of literature on inorganic nitrogen metabolism in micro-organisms *Wat. Res.* **4**, 393-450 (1970).

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[ISO 9509:1989](https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989)

<https://standards.iteh.ai/catalog/standards/sist/35b2529f-1e9b-4f5c-aacc-ce34233f6a96/iso-9509-1989>

UDC 628.356 : 66.097.8

Descriptors : water, quality, sewage treatment sludges, micro-organisms, microbiological analysis, determination, inhibition.

Price based on 6 pages
