

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Switches for household and similar fixed electrical installations –
Part 2-1: Particular requirements – Electronic switches

Interrupteurs pour installations électriques fixes domestiques et analogues –
Partie 2-1: Prescriptions particulières – Interrupteurs électroniques

ITeH STANDARD PREVIEW
(standards.iteh.ai)

IEC 60669-2-1:2002+AMD1:2008 CSV
<http://standards.iteh.ai/catalog/standards/sist/5a061559-7ccb-4475-b0cb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00



INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Switches for household and similar fixed electrical installations –
Part 2-1: Particular requirements – Electronic switches**

**Interrupteurs pour installations électriques fixes domestiques et analogues –
Partie 2-1: Prescriptions particulières – Interrupteurs électroniques**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-1: Particular requirements – Electronic switches

INTERPRETATION SHEET 1

This interpretation sheet has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

The text of this interpretation sheet is based on the following documents:

ISH	Report on voting
23B/1012/ISH	23B/1030/RVD

Full information on the voting for the approval of this interpretation sheet can be found in the report on voting indicated in the above table.

iTeh STANDARD PREVIEW (standards.iteh.ai)

Interpretation of the application of IEC 60669-2-1:2002, Subclause 26.2.1, NOTE 2

<https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv>

According to NOTE 2 of 26.2.1 of IEC 60669-2-1:2002, independent dimmers for incandescent lamps up to and including 1 000 W are not tested according to IEC 61000-3-2.

Dimmers according to IEC 60669-2-1 are independent dimmers.

If they are designed to dim different kinds of loads including incandescent lamps they are considered as dimmers for incandescent lamps and according to IEC 61000-3-2 they need not to be tested with all different kinds of load.

As a consequence independent dimmers complying with IEC 60669-2-1 and designed to dim different kinds of loads including incandescent lamps need not to be tested according to Clause 7 of IEC 61000-3-2:2005 and its Amendments 1:2008 and 2:2009, if the rated power is less than or equal to 1000 W.

NOTE This interpretation sheet will be withdrawn once IEC 61000-3-2 will have been modified to cover also dimmers for other kinds of loads than incandescent lamps.

INTERRUPTEURS POUR INSTALLATIONS ÉLECTRIQUES FIXES DOMESTIQUES ET ANALOGUES –

Partie 2-1: Prescriptions particulières – Interrupteurs électroniques

FEUILLE D'INTERPRÉTATION 1

Cette feuille d'interprétation a été établie par le sous-comité 23B: Prises de courant et interrupteurs, du comité d'études 23: Petit appareillage, de la CEI.

Le texte de cette feuille d'interprétation est issue des documents suivants:

ISH	Rapport de vote
23B/1012/FDIS	23B/1030/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette feuille d'interprétation.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

Interprétation de l'application de la CEI 60669-2-1:2002, Paragraphe 26.2.1, NOTE 2

IEC 60669-2-1:2002+AMD1-2008 CSY
<https://standards.iteh.ai/catalog/standards/sist/5a801535-7cc6-4473-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv>

Selon la NOTE 2 de 26.2.1 de la CEI 60669-2-1:2002, les variateurs indépendants pour lampes à incandescence jusqu'à 1 000 W inclus ne sont pas vérifiés selon la CEI 61000-3-2.

Les variateurs selon la CEI 60669-2-1 sont variateurs indépendants.

S'ils sont conçus pour faire varier différentes types de charges inclus des lampes à incandescence, ils sont considérés comme des variateurs pour lampes à incandescence et selon la CEI 61000-3-2 ils n'ont pas besoin d'être vérifiés avec toutes les différentes types de charge.

En conséquence les variateurs indépendants conformes à la CEI 60669-2-1 et conçus pour faire varier différentes types de charge, lampes à incandescence inclus, n'ont pas besoin d'être vérifiés selon l'Article 7 de la CEI 61000-3-2:2005 et ses Amendements 1:2008 et 2:2009, si la puissance assignée est moins de ou égale à 1000 W.

NOTE Cette feuille d'interprétation sera retirée une fois que la CEI 61000-3-2 aura été modifiée pour inclure aussi les variateurs pour les autres types de charge que les lampes à incandescence.

CONTENTS

FOREWORD.....	4
1 Scope.....	6
2 Normative references.....	7
3 Definitions	8
4 General requirements	11
5 General notes on tests.....	11
6 Rating.....	12
7 Classification	12
8 Marking	13
9 Checking of dimensions	16
10 Protection against electric shock.....	16
11 Provision for earthing.....	18
12 Terminals	18
13 Constructional requirements	19
14 Mechanism	20
15 Resistance to ageing, protection provided by enclosures of switches, and resistance to humidity	20
16 Insulation resistance and electric strength.....	20
17 Temperature rise	21
18 Making and breaking capacity.....	24
19 Normal operation	26
20 Mechanical strength.....	29
21 Resistance to heat.....	29
22 Screws, current-carrying parts and connections	29
23 Creepage distances, clearances and distances through sealing compound.....	29
24 Resistance of insulating material to abnormal heat, to fire and to tracking	31
25 Resistance to rusting	31
26 EMC requirements	31
101 Abnormal conditions	37
102 Components	39
Annex A (normative) Survey of specimens needed for tests.....	44
Annex B (normative) Additional requirements for switches having facilities for the outlet and retention of flexible cables.....	45
Annex AA (informative) Examples of types of electronic switches and their functions.....	46
Bibliography.....	47

Figure 101 – Test pin for checking the protection against electric shock	43
Figure 102 – Circuit diagram for testing electronic switches according to 101.3.....	43
Table 101 – Number of specimens	11
Table 102 – Permissible temperature rise values (This table is based on table 3 of IEC 60065).....	23
Table 103 – Relationship between rated current and capacitance	28
Table 104 – Immunity tests	32
Table 105 – Voltage dip and short-interruption test values	32
Table 106 – Fast transient test values	33
Table 107 – Capacitors	41
Table B.1 – Maximum current and minimum cross-sectional area	45

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60669-2-1:2002+AMD1:2008 CSV](https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv)

[https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-
e234e64264c5/iec-60669-2-1-2002amd1-2008-csv](https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv)

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**SWITCHES FOR HOUSEHOLD AND SIMILAR
FIXED ELECTRICAL INSTALLATIONS –****Part 2-1: Particular requirements –
Electronic switches**

FOREWORD

- 1) La Commission Electrotechnique Internationale (CEI) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de la CEI). La CEI a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, la CEI – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de la CEI"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec la CEI, participent également aux travaux. La CEI collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de la CEI concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de la CEI intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de la CEI se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de la CEI. Tous les efforts raisonnables sont entrepris afin que la CEI s'assure de l'exactitude du contenu technique de ses publications; la CEI ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de la CEI s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de la CEI dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de la CEI et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) La CEI n'a prévu aucune procédure de marquage valant indication d'approbation et n'engage pas sa responsabilité pour les équipements déclarés conformes à une de ses Publications.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à la CEI, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de la CEI, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de la CEI ou de toute autre Publication de la CEI, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de la CEI peuvent faire l'objet de droits de propriété intellectuelle ou de droits analogues. La CEI ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de propriété et de ne pas avoir signalé leur existence.

International Standard IEC 60669-2-1 has been prepared by subcommittee 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

This consolidated version of IEC 60669-2-1 consists of the fourth edition (2002) [documents 23B/668/FDIS and 23B/682/RVD] and its amendment 1 (2008) [documents 23B/894/FDIS and 23B/907/RVD].

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 4.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

This part of IEC 60669-2 shall be used in conjunction with IEC 60669-1. It lists the changes necessary to convert that standard into a specific standard for electronic switches.

In this publication, the following print types are used:

- requirements proper: in roman type.
- *test specifications: in italic type.*
- notes: in smaller roman type.

Subclauses, figures, tables or notes which are additional to those in part 1 are numbered starting from 101.

Annex AA is for information only.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60669-2-1:2002+AMD1:2008 CSV](https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv)

<https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv>

SWITCHES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 2-1: Particular requirements – Electronic switches

1 Scope

This clause of part 1 applies except as follows.

Replacement:

This standard applies to electronic switches and to associated electronic extension units for household and similar fixed electrical installations either indoors or outdoors.

It applies to electronic switches for a.c. only, for the operation of lamp circuits and the control of the brightness of lamps (dimmers) as well as the control of the speed of motors (for example, those used in ventilating fans) and for other purposes (for example, heating controls), with a rated voltage not exceeding 250 V and a rated current not exceeding 16 A.

The operation and/or control as mentioned above are performed by a person via an actuating member, a sensing surface or a sensing unit, by means of touch, proximity, turn, optical, acoustic, thermal or any other influence.

This standard also applies to general purpose electronic switches with included automatic functions where the operation and/or the control is initiated by a change of a physical quantity, for example light, temperature, humidity, time, wind velocity, presence of persons, etc.

This standard also applies to boxes for electronic switches, with the exception of mounting boxes for flush-type electronic switches.

This standard also applies to electronic RCS and electronic TDS with a rated voltage not exceeding 440 V and a rated current not exceeding 25 A, intended for household and similar fixed electrical installations, either indoors or outdoors.

NOTE 1 Switches including only passive components such as resistors, capacitors, inductors, PTC and NTC components, varistors, printed wiring boards and connectors are not considered as electronic switches.

NOTE 2 Electronic switches may have control circuits with a.c. or d.c. rated control voltages.

Electronic switches complying with this standard are suitable for use at ambient temperature not normally exceeding 25 °C but occasionally reaching 35 °C.

In locations where special conditions prevail, such as in ships, vehicles and the like and in hazardous locations, for example, where explosions are liable to occur, special constructions may be required.

NOTE 3 This standard is not intended to cover devices which are designed to be incorporated in appliances or are intended to be delivered together with a specific appliance and which are within the scope of IEC 60730 or IEC 61058-1.

Examples of designs of electronic switches and functions are shown in annex AA.

NOTE 4 Electronic switches without a mechanical switch in the main circuit do not provide a “full off-state”. Therefore, the circuit on the load side should be considered to be live.

2 Normative references

This clause of part 1 applies except as follows.

Addition:

IEC 60065:2001, *Audio, video and similar electronic apparatus – Safety requirements*

IEC 60085:1984, *Thermal evaluation and classification of electrical insulation*

IEC 60127 (all parts), *Miniature fuses*

IEC 60227-5:1997, *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V – Part 5: Flexible cables (cords)*¹⁾

IEC 60317 (all parts), *Specifications for particular types of winding wires*

IEC 60317-0-1:1997, *Specifications for particular types of winding wires – Part 0: General requirements – Section 1: Enamelled round copper wire*¹⁾

IEC 60384-14:1993, *Fixed capacitors for use in electronic equipment – Part 14: Sectional specification: Fixed capacitors for electromagnetic interference suppression and connection to the supply mains*

IEC 60664-1:2007, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60664-3, *Insulation coordination for equipment within low-voltage systems – Part 3: Use of coating, potting or moulding for protection against pollution*

IEC 60669-2-2:2006, *Switches for household and similar fixed electrical installations – Part 2-2: Particular requirements – Electromagnetic remote-control switches (RCS)*

IEC 60669-2-3:2006, *Switches for household and similar fixed electrical installations – Part 2-3: Particular requirements - Time-delay switches (TDS)*

IEC 60730 (all parts), *Automatic electrical controls for household and similar use*

IEC 60998-2-1, *Connecting devices for low-voltage circuits for household and similar purposes – Part 2-1: Particular requirements for connecting devices as separate entities with screw-type clamping units*

IEC 61000-2-2:2002, *Electromagnetic compatibility (EMC) – Part 2-2: Environment – Compatibility levels for low-frequency conducted disturbances and signalling in public low-voltage power supply systems*

IEC 61000-3-2:2000, *Electromagnetic compatibility (EMC) – Part 3-2: Limits – Limits for harmonic current emissions (equipment input current $\leq 16\text{A}$ per phase)*¹⁾

IEC 61000-3-3:1994, *Electromagnetic compatibility (EMC) – Part 3: Limits – Section 3: Limitation of voltage fluctuations and flicker in low-voltage supply systems for equipment with rated current $\leq 16\text{A}$* ¹⁾

IEC 61000-4-2:1995, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 2: Electrostatic discharge immunity test*¹⁾

IEC 61000-4-3:2002, *Electromagnetic compatibility (EMC) – Part 4-3: Testing and measurement techniques – Radiated, radio-frequency, electromagnetic field immunity test*

¹⁾ A consolidated version of this standard exists.

IEC 61000-4-4:1995, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 4: Electrical fast transient/burst immunity test*

IEC 61000-4-5:1995, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 5: Surge immunity test¹⁾*

IEC 61000-4-6:1996, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 6: Immunity to conducted disturbances, induced by radio-frequency*

IEC 61000-4-8:1993, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 8: Power frequency magnetic field immunity test¹⁾*

IEC 61000-4-11:1994, *Electromagnetic compatibility (EMC) – Part 4: Testing and measurement techniques – Section 11: Voltage dips, short interruptions and voltage variations immunity tests¹⁾*

IEC 61032, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61558-2-6, *Safety of power transformers, power supply units and similar – Part 2: Particular requirements for safety isolating transformers for general use*

CISPR 14 (all parts), *Electromagnetic compatibility – Requirements for household appliances, electric tools and similar apparatus*

CISPR 15:2000, *Limits and methods of measurement of radio disturbance characteristics of electrical lighting and similar equipment*

ISO 306:1994, *Plastics – Thermoplastic materials – Determination of Vicat softening temperature (VST)*

ITeH STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60669-2-1:2002+AMD1:2008 CSV](https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv)

3 Definitions

<https://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv>

This clause of part 1 applies with the following additions.

Addition, after the first paragraph:

The term “electronic switch” is used as a general term to cover both electronic switching and control devices.

3.101

rated load

load assigned to the electronic switch by the manufacturer

3.102

minimum load

lowest load at which the electronic switch still operates correctly

3.103

minimum current

lowest current at which the electronic switch still operates correctly

3.104

electromechanically operated contact mechanism

component which operates the parts used to open and close the circuit electromechanically

¹⁾ A consolidated version of this standard exists.

3.105**semiconductor switching device**

switching device designed to make or break the current in an electric circuit by means of the controlled conductivity of a semiconductor in that circuit

NOTE 1 In a circuit where the current passes through zero (periodically or otherwise) the effect of “not making” the current following such a zero value is equivalent to breaking the current.

NOTE 2 Typical examples of semiconductor switching devices are:

- electronic switching devices using the phase-cut-on principle to control the load by electronic switching on the current at any phase angle at or after zero crossing in each half-wave, for example, by a thyristor;
- electronic switches using the phase-cut-off principle to control the load by switching off the current at any phase angle after zero crossing in each half-wave, for example, by a transistor in a diode bridge.

3.106**electronic momentary contact switch**

electronic switch with an electromechanical switching mechanism or a semiconductor switching device which returns automatically to the initial state after operation

3.107**mechanical control unit**

unit directly adjustable by mechanical means (for example, potentiometer) which controls the output via electronic components

3.108**electronic output control unit**

unit adjustable by other than mechanical means (for example, sensing unit), containing electronic components and controlling the output via electronic components

3.109**electronic extension unit**

unit permitting the control of an electronic switch from a distance

[IEC 60669-2-1:2002+AMD1:2008 CSV](http://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-f234e61264f5/iec-60669-2-1-2002-amd1-2008-csv)

<http://standards.iteh.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-f234e61264f5/iec-60669-2-1-2002-amd1-2008-csv>

3.110**protective impedance**

impedance connected between live parts and accessible conductive parts, of such value that the current, in normal use and under likely fault conditions in the electronic switch, is limited to a safe value, and which is so constructed that the reliability is maintained throughout the life of the electronic switch.

3.111**external flexible cable**

cable, a part of which is external to the electronic output control unit.

NOTE Such cable may either be a supply cable or a connecting cable between separate parts of an accessory.

3.112**RCS****remote controlled switch**

switch intended to be operated from a distance

3.112.1**electromagnetic RCS**

RCS provided with a coil which is operated by means of impulses or which may be permanently energized by means of a control circuit

NOTE These devices are covered by IEC 60669-2-2.

3.112.2**electronic RCS**

electronic switch providing the function, markings and connection configuration of an RCS according to IEC 60669-2-2, but containing electronic components and/or a combination of electronic components and a coil or coils, which is operated by means of an electronic extension unit or units

NOTE This electronic RCS may for example be used as a look alike replacement for RCS according to IEC 60669-2-2.

3.113**rated control voltage**

the voltage assigned to the external control circuit by the manufacturer

3.114**switching circuit**

the circuit which contains the parts which allow the rated current to flow through the RCS or TDS

3.115**control circuit**

the circuit which includes electrical parts to actuate the switching mechanism

3.116**control mechanism**

mechanism which includes all the parts which are intended for the operation of the RCS or TDS

3.117**incorporated hand-operated device**

device incorporated in the switch which allows the switching circuit to be operated, directly or indirectly. This device is not intended for the normal operation of the RCS or TDS

3.118**rated control current**

current required for the initiation of the electronic RCS assigned to the control circuit by the manufacturer

3.119**bistable electronic RCS**

electronic RCS containing a control mechanism which, when not initiated electrically or actuated mechanically, remains stable in its operating position and will change its operating position on initiation or actuation

3.120**monostable electronic RCS**

electronic RCS containing a control mechanism which, on electrical initiation or mechanical actuation, changes the operating position of the switch which remains in this condition while the electronic RCS is initiated or actuated, and returns to the position prior to initiation or actuation of the electronic RCS after initiation or actuation is discontinued

3.121**priority electronic RCS**

electronic RCS used to operate directly or indirectly a first load circuit or group of load circuits the use of which at times can be dispensed with, and where the control circuit of the electronic RCS is influenced by or connected to a second circuit or group of circuits (priority or circuits) which when energized will thus initiate the control circuit of the electronic RCS to de-energize the first load circuit or circuits for the time during which the second circuit or group of circuits is energized

NOTE The electronic RCS may have a means for adjusting the sensitivity of the electronic RCS control circuit to initiate the electronic RCS depending on the total load or current delivered to any part of the circuits (priority switch with current coil) or be sensitive to the voltage (priority switch with voltage coil) applied to the second load or group of loads.

3.122

TDS

time delayed switch

switch provided with a time-delay device which operates for a certain time (the delay time). It may be either manually actuated and/or remotely electrically initiated

3.123

electronic TDS

electronic switch providing the function, markings and connection configuration of a TDS according to IEC 60669-2-3, but containing electronic components

NOTE This electronic TDS may for example be used as a look alike replacement for TDS according to IEC 60669-2-3.

3.124

delay time

period during which the switching circuit(s) is (are) kept closed. Any time taken for the decreasing of the voltage (e.g. to reduce the light) at the end of the delay period is included within the delay time

3.125

delay device

all components which have an influence on the delay time. The delay time may be adjustable

iTech STANDARD PREVIEW
(standards.itech.ai)

4 General requirements

[IEC 60669-2-1:2002+AMD1:2008 CSV](http://standards.itech.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv)

This clause of part 1 applies standards.itech.ai/catalog/standards/sist/3a80f535-7cc6-4495-b0eb-e234e64264c5/iec-60669-2-1-2002amd1-2008-csv

5 General notes on tests

This clause of part 1 applies except as follows.

5.4 Addition

The number of test specimens is shown in table 101.

Table 101 – Number of specimens

Type of electronic switch	Number for general tests	Additional specimens for clause or subclause					
		18.2	19.101	19.102	24	26	101 and 102
Marked with one rated current and							
– one rated voltage	3	3 ^a	3 ^a	3 ^a	3	3	3 ^c
– two rated voltages	6	6 ^a	6 ^a	6 ^a	6	6	6 ^{b,c}
^a Only for electronic switches with mechanical and electromechanical switching devices; only the complete contact mechanism may be submitted. ^b It may be necessary to provide three additional specimens for the test of 101.3. ^c When the tests of Clause 26 have been passed successfully, the specimens can be used for these tests.							