

# INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –  
Part 3-12: Data-link layer service definition – Type 12 elements**

IEC 61158-3-12:2010

<https://standards.iteh.ai/catalog/standards/sist/457990e-de3f-4b52-85c4-e192dd78a15f/iec-61158-3-12-2010>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)  
Tel.: +41 22 919 02 11  
Fax: +41 22 919 03 00



IEC 61158-3-12

Edition 2.0 2010-07

# INTERNATIONAL STANDARD

**Industrial communication networks – Fieldbus specifications –  
Part 3-12: Data-link layer service definition – Type 12 elements**

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

PRICE CODE



ICS 25.04.40; 35.100.20; 35.110

ISBN 978-2-88912-077-2

## CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
1.1 Overview.....	7
1.2 Specifications.....	7
1.3 Conformance.....	7
2 Normative references.....	8
3 Terms, definitions, symbols, abbreviations and conventions.....	8
3.1 Reference model terms and definitions.....	8
3.2 Service convention terms and definitions.....	9
3.3 Data-link service terms and definitions.....	10
3.4 Symbols and abbreviations.....	13
3.5 Common conventions.....	14
4 Data-link layer services and concepts.....	15
4.1 Operating principle.....	15
4.2 Topology.....	16
4.3 Data-link layer overview.....	16
4.4 Error detection overview.....	17
4.5 Parameter and process data handling introduction.....	17
4.6 Node reference model.....	17
4.7 Operation overview.....	18
4.8 Addressing.....	20
4.9 Slave classification.....	22
4.10 Structure of the communication layer in the slave.....	22
5 Communication services.....	23
5.1 Overview.....	23
5.2 Read services.....	24
5.3 Write services.....	27
5.4 Combined read/write services.....	29
5.5 Network services.....	33
5.6 Mailbox.....	34
6 Local interactions.....	39
6.1 Read local.....	39
6.2 Write local.....	39
6.3 Event local.....	40
Figure 1 – Mapping of logical data in an Ethernet frame consisting of a single Type 12 DLPDU.....	16
Figure 2 – Type 12 data-link reference model.....	18
Figure 3 – Type 12 segments in open mode.....	19
Figure 4 – Type 12 segment in direct mode.....	19
Figure 5 – Addressing mode overview.....	20
Figure 6 – Fieldbus memory management unit overview.....	21
Figure 7 – Layering of communication.....	23
Figure 8 – Flow of Type 12 service primitives.....	24

Figure 9 – Successful mailbox write sequence.....	35
Figure 10 – Successful mailbox read sequence .....	35
Table 1 – Auto-increment physical read (APRD) .....	24
Table 2 – Configured-address physical read (FPRD).....	25
Table 3 – Broadcast read (BRD).....	26
Table 4 – Logical read (LRD).....	26
Table 5 – Auto-increment physical write (APWR).....	27
Table 6 – Configured-address physical write (FPWR) .....	27
Table 7 – Broadcast write (BWR) .....	28
Table 8 – Logical write (LWR) .....	29
Table 9 – Auto-increment physical read/write (APRW) .....	29
Table 10 – Configured-address physical read/write (FPRW).....	30
Table 11 – Broadcast read/write (BRW).....	31
Table 12 – Logical read/write (LRW).....	31
Table 13 – Auto-increment physical read / multiple write (ARMW).....	32
Table 14 – Configured-address physical read / multiple write (FRMW) .....	32
Table 15 – Provide network variable (PNV).....	33
Table 16 – Mailbox write.....	36
Table 17 – Mailbox read update.....	37
Table 18 – Mailbox read .....	38
Table 19 – Read local .....	39
Table 20 – Write local .....	39
Table 21 – Event local.....	40

# INTERNATIONAL ELECTROTECHNICAL COMMISSION

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 3-12: Data-link layer service definition – Type 12 elements

#### FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE 1 Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the profile parts. Use of the various protocol types in other combinations may require permission of their respective intellectual-property-right holders.

International Standard IEC 61158-3-12 has been prepared by subcommittee 65C: Industrial networks of IEC technical committee 65: Industrial-process measurement, control and automation.

This second edition cancels and replaces the first edition published in 2007. This edition constitutes a technical revision.

The main changes with respect to the previous edition are listed below:

- editorial improvements.

The text of this standard is based on the following documents:

FDIS	Report on voting
65C/604/FDIS	65C/618/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE 2 The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.



iTeh STANDARD PREVIEW  
(standards.iteh.ai)

IEC 61158-3-12:2010

<https://standards.iteh.ai/catalog/standards/sist/457990e-de3f-4b52-85c4-e192dd78a15f/iec-61158-3-12-2010>



# INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

## Part 3-12: Data-link layer service definition – Type 12 elements

### 1 Scope

#### 1.1 Overview

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 12 fieldbus data-link layer in terms of

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take;
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 12 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model;
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

#### 1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously-existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

#### 1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition standard. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfills the Type 12 data-link layer services defined in this standard.

## 2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 8802-3, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

IEEE 802.1D, *IEEE Standard for Local and metropolitan area networks – Media Access Control (MAC) Bridges*; available at <<http://www.ieee.org>>

## 3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

### 3.1 Reference model terms and definitions

This standard is based in part on the concepts developed in ISO/IEC 7498-1 and ISO/IEC 7498-3 and makes use of the following terms defined therein.

<b>3.1.1 DL-address</b>	[7498-3]
<b>3.1.2 DL-connectionless-mode transmission</b>	[7498-1]
<b>3.1.3 correspondent (N)-entities</b>	[7498-1]
<b>correspondent DL-entities (N=2)</b>	
<b>correspondent Ph-entities (N=1)</b>	
<b>3.1.4 DL-duplex-transmission</b>	[7498-1]
<b>3.1.5 (N)-entity</b>	[7498-1]
<b>DL-entity (N=2)</b>	
<b>Ph-entity (N=1)</b>	
<b>3.1.6 (N)-layer</b>	[7498-1]
<b>DL-layer (N=2)</b>	
<b>Ph-layer (N=1)</b>	
<b>3.1.7 layer-management</b>	[7498-1]
<b>3.1.8 peer-entities</b>	[7498-1]
<b>3.1.9 primitive name</b>	[7498-3]
<b>3.1.10 DL-protocol</b>	[7498-1]
<b>3.1.11 DL-protocol-data-unit</b>	[7498-1]

<b>3.1.12 DL-relay</b>	[7498-1]
<b>3.1.13 reset</b>	[7498-1]
<b>3.1.14 responding-DL-address</b>	[7498-3]
<b>3.1.15 routing</b>	[7498-1]
<b>3.1.16 segmenting</b>	[7498-1]
<b>3.1.17 (N)-service</b>	[7498-1]
DL-service (N=2)	
Ph-service (N=1)	
<b>3.1.18 (N)-service-access-point</b>	[7498-1]
DL-service-access-point (N=2)	
Ph-service-access-point (N=1)	
<b>3.1.19 DL-service-data-unit</b>	[7498-1]
<b>3.1.20 DL-simplex-transmission</b>	[7498-1]
<b>3.1.21 DL-subsystem</b>	[7498-1]
<b>3.1.22 systems-management</b>	[7498-1]
<b>3.1.23 DLS-user</b>	[7498-1]
<b>3.1.24 DLS-user-data</b>	[7498-1]

## **3.2 Service convention terms and definitions**

This standard also makes use of the following terms defined in ISO/IEC 10731 as they apply to the data-link layer:

<b>3.2.1 acceptor</b>
<b>3.2.2 asymmetrical service</b>
<b>3.2.3 confirm (primitive); requestor.deliver (primitive)</b>
<b>3.2.4 deliver (primitive)</b>
<b>3.2.5 DL-service-primitive; primitive</b>
<b>3.2.6 DL-service-provider</b>
<b>3.2.7 DL-service-user</b>
<b>3.2.8 DL-user-optional-facility</b>
<b>3.2.9 indication (primitive); acceptor.deliver (primitive)</b>
<b>3.2.10 request (primitive); requestor.submit (primitive)</b>
<b>3.2.11 requestor</b>
<b>3.2.12 response (primitive); acceptor.submit (primitive)</b>
<b>3.2.13 submit (primitive)</b>
<b>3.2.14 symmetrical service</b>

### 3.3 Data-link service terms and definitions

#### 3.3.1

##### **application**

function or data structure for which data is consumed or produced

#### 3.3.2

##### **application objects**

multiple object classes that manage and provide a run time exchange of messages across the network and within the network device

#### 3.3.3

##### **basic slave**

slave device that supports only physical addressing of data

#### 3.3.4

##### **bit**

unit of information consisting of a 1 or a 0. This is the smallest data unit that can be transmitted

#### 3.3.5

##### **client**

- 1) object which uses the services of another (server) object to perform a task
- 2) initiator of a message to which a server reacts

#### 3.3.6

##### **connection**

logical binding between two application objects within the same or different devices

#### 3.3.7

##### **cyclic**

events which repeat in a regular and repetitive manner

#### 3.3.8

##### **cyclic redundancy check (CRC)**

residual value computed from an array of data and used as a representative signature for the array

#### 3.3.9

##### **data**

generic term used to refer to any information carried over a fieldbus

#### 3.3.10

##### **data consistency**

means for coherent transmission and access of the input- or output-data object between and within client and server

#### 3.3.11

##### **device**

physical entity connected to the fieldbus composed of at least one communication element (the network element) and which may have a control element and/or a final element (transducer, actuator, etc.)

#### 3.3.12

##### **distributed clocks**

method to synchronize slaves and maintain a global time base

**3.3.13****DL-segment, link, local link**

single DL-subnetwork in which any of the connected DLEs may communicate directly, without any intervening DL-relaying, whenever all of those DLEs that are participating in an instance of communication are simultaneously attentive to the DL-subnetwork during the period(s) of attempted communication

**3.3.14****error**

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

**3.3.15****event**

instance of a change of conditions

**3.3.16****fieldbus memory management unit**

function that establishes one or several correspondences between logical addresses and physical memory

**3.3.17****fieldbus memory management unit entity**

single element of the fieldbus memory management unit: one correspondence between a coherent logical address space and a coherent physical memory location

**3.3.18****frame**

denigrated synonym for DLPDU

**3.3.19****full slave**

slave device that supports both physical and logical addressing of data

**3.3.20****interface**

shared boundary between two functional units, defined by functional characteristics, signal characteristics, or other characteristics as appropriate

**3.3.21****master**

device that controls the data transfer on the network and initiates the media access of the slaves by sending messages and that constitutes the interface to the control system

**3.3.22****mapping**

correspondence between two objects in that way that one object is part of the other object

**3.3.23****medium**

cable, optical fibre, or other means by which communication signals are transmitted between two or more points

NOTE "media" is used as the plural of medium.

**3.3.24****message**

ordered series of octets intended to convey information