

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Energy management system application program interface (EMS-API) –
Part 456: Solved power system state profiles**

**Interface de programmation d'application pour système de gestion d'énergie
(EMS-API) –
Partie 456: Profils d'état de réseaux électriques résolus**

<https://standards.iteh.ai/standards/iec/61970-456:2013>

<https://standards.iteh.ai/standards/iec/61970-456:2013>



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2013 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.
Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente. un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE



**Energy management system application program interface (EMS-API) –
Part 456: Solved power system state profiles**

**Interface de programmation d'application pour système de gestion d'énergie
(EMS-API) –
Partie 456: Profils d'état de réseaux électriques résolus**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX

W

ICS 33.200

ISBN 978-2-83220-756-7

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

FOREWORD.....	4
INTRODUCTION.....	6
1 Scope.....	7
2 Normative references	7
3 Profile information	8
4 Overview	8
5 Use cases	9
5.1 General.....	9
5.2 EMS state estimation.....	9
5.3 ENTSO-E Process: Day-ahead congestion forecast.....	10
5.4 System planning studies process.....	11
5.5 Harmonization of planning and operations models.....	12
6 Architecture.....	12
6.1 General.....	12
6.2 Profile architecture	12
6.3 Profiles and datasets for EMS network analysis.....	15
6.4 Profiles and datasets in a planning power flow.....	16
6.5 Model authority sets and instance level data modularization.....	17
6.5.1 General.....	17
6.5.2 EMS instance modularization.....	17
6.5.3 Planning instance modularization.....	18
6.6 Principles of instance modularization.....	19
7 Applying the standard to business problems.....	21
7.1 EMS network analysis integration with external consumers	21
7.2 Planning network analysis integration with external consumers.....	23
8 Data model with CIMXML examples.....	24
8.1 Measurement interfaces 2 and 3.....	24
8.2 Topology interface 4.....	24
8.3 State variables interfaces 5a and 5b state estimation	26
9 Topology profile.....	30
9.1 General.....	30
9.2 Concrete classes.....	30
9.2.1 Terminal.....	30
9.2.2 TopologicalNode.....	31
9.3 Abstract classes – IdentifiedObject.....	31
10 StateVariables profile	32
10.1 General.....	32
10.2 Concrete classes.....	32
10.2.1 TopologicalIsland	32
10.2.2 SvInjection	32
10.2.3 SvPowerFlow.....	33
10.2.4 SvShortCircuit	33
10.2.5 SvShuntCompensatorSections.....	33
10.2.6 SvTapStep.....	34
10.2.7 SvVoltage.....	34

10.3 Abstract classes	34
10.3.1 StateVariable.....	34
10.3.2 ActivePower	34
10.3.3 AngleRadians	35
10.3.4 ApparentPower.....	35
10.3.5 ReactivePower	35
10.3.6 Voltage.....	35
Bibliography.....	36
Figure 1 – TSO sends a case to be merged with the overall model	11
Figure 2 – Profile relationships	13
Figure 3 – Instance example of the CIM connectivity model	14
Figure 4 – EMS datasets by CIM profiles	15
Figure 5 – Planning power flow datasets by CIM profile	16
Figure 6 – State estimation case sequence.....	17
Figure 7 – Instance modularization applied in an EMS.....	18
Figure 8 – Instance modularization applied to planning power flow models	19
Figure 9 – Model merge process.....	20
Figure 10 – EMS datasets to an external client.....	21
Figure 11 – EMS boundary dataset example.....	22
Figure 12 – Bus-branch Integration architecture.....	23
Figure 13 – Bus-branch modeling of bus coupler and line transfer	23
Figure 14 – CIM topology model.....	24
Figure 15 – Topology solution interface.....	25
Figure 16 – CIM state variable solution model.....	27
Figure 17 – State solution interface example	29
Table 1 – Profiles defined in this document.....	8

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**ENERGY MANAGEMENT SYSTEM APPLICATION
PROGRAM INTERFACE (EMS-API) –**

Part 456: Solved power system state profiles

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61970-456 has been prepared by IEC technical committee 57: Power systems management and associated information exchange.

The text of this standard is based on the following documents:

FDIS	Report on voting
57/1327/FDIS	57/1342/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61970 series, under the general title: *Energy management system application program interface (EMS-API)*, can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

IMPORTANT – The 'colour inside' logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this document using a colour printer.

iTech Standards
(<https://standards.itih.ai>)
Document Preview

[IEC 61970-456:2013](https://standards.itih.ai/standards/iec/61970-456:2013)

<https://standards.itih.ai/standards/iec/61970-456:2013>

ENERGY MANAGEMENT SYSTEM APPLICATION PROGRAM INTERFACE (EMS-API) –

Part 456: Solved power system state profiles

1 Scope

This part of IEC 61970 belongs to the IEC 61970-450 to IEC 61970-499 series that, taken as a whole, defines at an abstract level the content and exchange mechanisms used for data transmitted between control centers and/or control center components.

The purpose of this part of IEC 61970 is to rigorously define the subset of classes, class attributes, and roles from the CIM necessary to describe the result of state estimation, power flow and other similar applications that produce a steady-state solution of a power network, under a set of use cases which are included informatively in this standard.

This standard is intended for two distinct audiences, data producers and data recipients, and may be read from those two perspectives. From the standpoint of model export software used by a data producer, the standard describes how a producer may describe an instance of a network case in order to make it available to some other program. From the standpoint of a consumer, the standard describes what that importing software must be able to interpret in order to consume solution cases.

There are many different use cases for which use of this standard is expected and they differ in the way that the standard will be applied in each case. Implementers should consider what use cases they wish to cover in order to know the extent of different options they must cover. As an example, this standard will be used in some cases to exchange starting conditions rather than solved conditions, so if this is an important use case, it means that a consumer application needs to be able to handle an unsolved state as well as one which has met some solution criteria.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 61970-452, *Energy Management System Application Program Interface (EMS-API) – Part 452: CIM Static Transmission Network Model Profiles*¹

IEC 61970-453, *Energy Management System Application Program Interface (EMS-API) – Part 453: Diagram Layout Profile*

IEC 61970-552, *Energy Management System Application Program Interface (EMS-API) – Part 552: CIM XML Model Exchange Format*²

¹ To be published.

² To be published.

3 Profile information

The profiles defined in this document are based on the UML version CIM14v14.

The profiles are listed in Table 1.

Table 1 – Profiles defined in this document

Name	Version	URI	Revision date
StateVariables	1	http://iec.ch/TC57/61970-456/StateVariables/CIM14/1	2010-03-24
Topology	1	http://iec.ch/TC57/61970-456/Topology/CIM14/1	2010-03-24

4 Overview

This document describes an interface standard in which CIM/XML payloads are used to transfer results created during typical steady-state network analysis processes (e.g. state estimation or power flow solutions). Major requirements/objectives driving the design of this standard include:

- Power flow solution algorithms and output are virtually the same whether run in operations or planning contexts. State estimator output shares a common core with power flow. A single standard is desired so as to minimize software development and enable use cases that cross between environments.
- While some users of this standard might only be interested in the output state, the more general situation is that users continue to perform follow-on analyses (e.g. voltage stability) and require both the input on which the solution was based and the output result.
- Real life analytical processes often involve a series of solutions in which most of the input data remains the same from one solution to the next, and the standard must support these processes in a way that does not repeat data unnecessarily.

In order to meet these requirements, this standard depends on modularizing the potentially voluminous overall input and output data into subsets that would each be realized as smaller, separate CIM/XML payloads. An instance of one of these subsets is referred to herein as a 'dataset'.

Two types of partitioning into datasets are utilized. In the first, the data is modularized according to what kind of data is produced (which generally corresponds with what kind of application produces the data). CIM 'profiles' (subsets of the complete CIM) define the classes and attributes that make up of each kind of modularization. The second type of partitioning is by 'model authority set' (MAS), which divides data into sets of object instances according to which utility or entity in an interconnection is responsible for the data. This partitioning occurs at the instance level and produces multiple datasets governed by the same profile that combine to form the complete set of data for that profile. Understanding the partitioning approach is critical to understanding how to use this standard to implement a particular business scenario.

This standard is flexible and designed to satisfy a wide range of analytical scenarios in the planning and operating business environments. We expect that where parties are using it to collaborate in some business process, those parties will often want to create additional business agreements that describe any restrictions and customizations of the standard that are deemed necessary for their process. In most cases, these additional agreements will be local agreements and will not be IEC industry standards.

The CIM/XML formatting of partitioned payloads is defined in IEC 61970-552. This method of formatting has the useful characteristic that valid XML describing a complete model could be achieved simply by concatenating the XML for each partition. Thus 'merge' and 'extract' of pieces of the modeling require no separate 'stitching' instructions and is conceptually a very simple process. IEC 61970-552 also describes how payload headers provide information as to how payloads fit together.

How to read this document:

- Clause 5, "Use cases", gives examples of business problems that this standard is intended to address.
- Clause 6, "Architecture", summarizes how the model partitioning works and describes how the parts described in this document work with parts described in other IEC 61970 series standards.
- Clause 7, "Applying the standard to business problems", describes how to go about applying the standard to your particular business problem.
- Clause 9, "Topology profile" defines the kinds of datasets controlled by this standard. (This section is auto-generated from CIMTool and is where you see the CIM modeling detail.)

5 Use cases

5.1 General

Clause 5 presents some of the business problems that were considered in the design of this standard and discusses how the standard is expected to provide value to the industry.

5.2 EMS state estimation

EMS operations typically run state estimator automatically, usually triggered either by occurrence of certain events or by a time period. Periods of 10 min or more used to be the norm, but currently many state estimator installations are running with much shorter periods approaching 5 s and nearly the same periodicity as SCADA (supervisory control and data acquisition) and consequently rendering event based triggering of state estimator important.

The state estimator's job is to create the best view of the state of the system, based on the latest available snapshot of the SCADA measurements. The resulting steady state solution of the power system is used as input data for a number of important functions:

- A traditional EMS is usually configured by the EMS vendor with contingency analysis running on the result of the state estimator. While a standard is usually not necessary for applications from the same vendor, there is industry interest in being able to run alternate algorithms for either state estimation or contingency analysis.
- A growing number of other analytical functions that were not originally part of the EMS are also using the state estimator result as the starting point for real-time analysis (e.g. voltage stability).
- Where market systems exist, they normally require real-time exchange of state estimation result from the EMS to the market system, and these systems often are supplied by different vendors.
- Users are interested in being able to connect advanced user interface and situation awareness modules from different vendors into an EMS, and these modules need to acquire state estimator data.
- It is desirable to be able to run historical analysis as well as real-time analysis from state estimator results. This requires estimator results can be archived efficiently, and users shall be able to import results into network planning tool environments that are normally not supplied by the EMS vendor.

All of these situations require an efficient standard method of producing state estimator results and making them available to other applications.

If the complete set of input data and output data were stored for a large interconnection model running on, say, a 10 s period, it would produce a great deal of data and pose a considerable challenge to any real-time exchange. However, there are some obvious characteristics of this problem that may be exploited to reduce the data burden.

- The network model is by far the largest part of the data. It changes infrequently and when it does change, the changes are a small set of data. Only the initialization of the system actually requires a complete large model.
- The topology of the system changes more frequently (when switching devices change position), but still is relatively infrequent and again the changes are small compared to the complete topology.
- Analog measurement input changes completely each run, but in many of the use cases, this data is not required by the consumer. Analog data may also usually be approximated from an analog history if it is not stored.
- Solution state variables change at each run.

What is required of the standard in order for each kind of business exchange to take advantage of these characteristics is that the network model and the topology may be updated only when they change. It is also valuable if updates can be represented in incremental form, rather than by re-transmission of a full model. Consumers of the data then are able to initialize themselves with a full network model and topology when they start, but only receive updates if there were changes. This reduces the data volume problem from Gbytes/solution and Tbytes/day to a more manageable Mbytes/solution and Gbytes/day.

5.3 ENTSO-E³ Process: Day-ahead congestion forecast

A daily analytical operational process called day ahead congestion forecast (DACF) is currently applied in the ENTSO-E regional group continental Europe. In this process,

- each TSO prepares a power flow case covering exactly its own territory representing each hour of the following day (based on day-ahead market outcomes). These cases are transferred to a central server;
- the full set of submitted cases may be checked for mutual compatibility. (i.e. do the boundary exchange conditions match);
- once all cases are submitted, each TSO downloads from the central server the cases posted by their neighboring TSOs. These are combined with their own models to form a set of study models on which they can analyze the congestion in their region for the next day;
- congestion result cases may be exchanged among TSOs, as the situation warrants.

This work is carried out primarily with planning tools running bus-branch models (although an obvious possible variation on the process would be to generate cases with EMS tools).

Even though the DACF process is not a real-time process like state estimation, it is quite similar in that a sequence of cases is produced representing periodic intervals. The solution values will change at each case, but the network model will change rarely and the topology will change occasionally. Conserving file size is a concern, and that concern is addressed if the standard allows the network model and topology to be exchanged incrementally.

DACF raises another set of requirements, however. Unlike the state estimator scenarios, which feature complete transfer of a solution, the DACF involves a lot of merging and extracting of pieces of solutions. In Figure 1, TSO A runs power flows to develop a picture of

³ European network of transmission system operator-electricity.

its territory for the following day. This would be done with models that include representations of neighboring TSOs. They shall post, however, only the part of the model representing their own territory, and this shall be a stand-alone solved power flow. (In ENTSO-E, boundaries between TSOs are, by agreement, always at the mid-point of tie-lines, and single TSO cases are formed with equivalent injections at each tie-line mid-point.) At the central site, or at any TSO, submitted internal cases shall be able to be reliably and automatically re-combined to form models with coverage appropriate to whatever task is at hand.




Figure 1 – TSO sends a case to be merged with the overall model

The octagons in Figure 1 represent datasets. The colors of the sets have the following meanings.

- magenta - data described by state variables profile;
- green - data described by the topology profile;
- blue - data described by the equipment profile.

Refer also to Figure 2.

5.4 System planning studies process

There are many synchronous interconnections worldwide (such as ENTSO-E discussed above) that require cooperative construction of future models by its members in order to support planning of the interconnection. Typically, “base cases” are constructed representing future time frames by combining submittals from each interconnection member, a process that closely resembles that depicted in Figure 1 for operational analysis. Instead of day-ahead, a planning case may represent years ahead; instead of daily update, a planning case must be reconstructed as plans change; instead of a known functioning power system, a planning case is not real yet. But in terms of process and in terms of data requirements, the assembly of base cases for planning is the same as in Figure 1, and it is the objective of this standard to

support both construction of base cases and the exchange of solution cases that necessarily occurs among members during the analysis based on these cases.

5.5 Harmonization of planning and operations models

Network analysis is universally carried out with what is known as ‘bus-branch’ modeling, where most or all zero impedance switching devices are eliminated to form logical buses, and where load, generation and regulation parameters have been selected for a single point in time. However, there are significant differences in the way that network models are handled in operations and planning contexts.

- Planners tend to work extensively with a few selected bus-branch ‘cases’. For example, they will set up the conditions that represent a summer peak load for a future network, and then study variations on that case. Planning tools typically provide for direct entry of buses and single point in time parameters.
- Operations environments (EMS) require the ability to set up bus-branch cases automatically for any point in time. They typically begin with a network model with switching detail, and with schedules for time-varying parameters – and then the EMS will have applications that compute the bus topology from switch status, and compute specific parameters from time-varying schedules.

Our goal here is to create a standard that can support the following situations effectively:

- a) power system modeling where planning and operations are managing their models independently;
- b) consolidated modeling, where a single source supports both planning and operations;
- c) initialization of planning cases from operations results, regardless of whether modeling is consolidated;
- d) initialization of operations models from planning models;
- e) construction of external operations models from models of neighboring systems;
- f) construction of interconnection planning models from models of the constituent systems.

Most of the requirements derived from the above list bear more strongly on the static modeling of the power network, which is covered in IEC 61970-452. From the standpoint of solution exchange, it is simply important to remain consistent with all these requirements.

6 Architecture

6.1 General

The main architectural feature of this standard is data modularization:

- modularization by data model (CIM) profiles (usually reflects the application that produces the data);
- modularization by grouping of instance data into model authority sets (MAS) (usually reflects regional responsibility).

6.2 Profile architecture

Figure 2 shows the profiles that are covered by the IEC 61970-450 to 61970-499 series specifications and depicts the relationships between them. The profiles are defined in different IEC 61970-450 specifications where each specification defines a group of profiles:

- Static network model profiles defined in IEC 61970-452
 - equipment profile. The static modeling information describing power system physical elements and their electrical connections;
 - schedules profile. The time-varying specifications for power system quantities;