



Edition 2.0 2011-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Low-voltage switchgear and controlgear assemblies – EW Part 2: Power switchgear and controlgear assemblies (Standards.iten.al)

Ensembles d'appareillage à basse tension – <u>IEC 61439-2:2011</u> Partie 2: Ensembles d'appareillage de puissonce_{164-dec2-4040-9d9c-} da1f127fc986/iec-61439-2-2011





THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur. Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office 3, rue de Varembé CH-1211 Geneva 20 Switzerland Email: inmail@iec.ch Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Catalogue of IEC publications: www.iec.ch/searchpub ARD PREVIEW

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

IEC Just Published: <u>www.iec.ch/online news/justpub</u>
 Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email. <u>IEC 61439-22011</u>

Electropedia: www.electropedia.org/ds.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9c-The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical

Vocabulary online.

Customer Service Centre: <u>www.iec.ch/webstore/custserv</u>

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: <u>csc@iec.ch</u> Tel.: +41 22 919 02 11 Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue des publications de la CEI: <u>www.iec.ch/searchpub/cur_fut-f.htm</u>

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

Just Published CEI: <u>www.iec.ch/online_news/justpub</u>

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

Electropedia: <u>www.electropedia.org</u>

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

Service Clients: <u>www.iec.ch/webstore/custserv/custserv_entry-f.htm</u>

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: <u>csc@iec.ch</u> Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00





Edition 2.0 2011-08

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Low-voltage switchgear and controlgear assemblies – EW Part 2: Power switchgear and controlgear assemblies

Ensembles d'appareillage à bass<u>e tension 2011</u> Partie 2: Ensembles d'appareillage de puissance 64-dec2-4040-9d9cda1f127fc986/iec-61439-2-2011

INTERNATIONAL ELECTROTECHNICAL COMMISSION

COMMISSION ELECTROTECHNIQUE INTERNATIONALE

PRICE CODE CODE PRIX

Т

ICS 29.130.20

ISBN 978-2-88912-605-7

CONTENTS

FO	REWORD	.3
1	Scope	.5
2	Normative references	.5
3	Terms and definitions	.6
4	Symbols and abbreviations	.7
5	Interface characteristics	.7
6	Information	. 8
7	Service conditions	.8
8	Constructional requirements	. 8
9	Performance requirements	11
10	Design verification	11
11	Routine verification	12
Anr	nex AA (informative) Forms of internal separation (see 8.101)	16
Anr mai	nex BB (informative) Items subject to agreement between the ASSEMBLY nufacturer and the user	19
Bib	liography	23
	iTeh STANDARD PREVIEW	
Fig	ure AA.1 – Symbols used in Figures AA.2 and AA.3.	16
Fig	ure AA.2 – Forms 1 and 2	17
Fig	ure AA.3 – Forms 3 and 4	18
	https://standards.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9c-	
Tab	ble 101 – Values of assumed loading	12
Tab	ble 102 – Test voltages across the open contacts of equipment suitable for isolation	12
Tab	ble 103 – Electrical conditions for the different positions of withdrawable parts	13
Tab	ble 104 – Forms of internal separation	14
Tab use	ole BB.1 – Items subject to agreement between the ASSEMBLY manufacturer and the r	19

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 2: Power switchgear and controlgear assemblies

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committee; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- https://standards.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9c 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 61439-2 has been prepared by subcommittee 17D: Low-voltage switchgear and controlgear assemblies, of IEC technical committee 17: Switchgear and controlgear.

This second edition cancels and replaces the first edition published in 2009. It constitutes a technical revision.

This second edition includes the following significant technical changes with respect to the last edition of IEC 61439-2:

- clarification of the scope;
- revision of requirements for withdrawable and removable parts;
- revision of mechanical impact test (10.2.6);
- extension of Table 101;

- review of Table BB.1 to reflect modified requirements and verifications;
- general editorial review.

The text of this standard is based on the following documents:

FDIS	Report on voting
17D/440/FDIS	17D/445/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This standard is to be read in conjunction with IEC 61439-1. The provisions of the general rules dealt with in IEC 61439-1 (hereinafter referred to as Part 1) are only applicable to this standard insofar as they are specifically cited. When this standard states "addition", "modification" or "replacement", the relevant text in Part 1 is to be adapted accordingly.

Subclauses that are numbered with a 101 (102, 103, etc.) suffix are additional to the same subclause in Part 1.

Tables and figures in this Part 2 that are new are numbered starting with 101.

New annexes in this Part 2 are lettered AA, BB, etc.

(standards.iteh.ai)

In this standard, terms written in small capitals are defined in Clause 3.

IEC 61439-2:2011

NOTE Throughout the term ASSEMBLY (see 4) 1(1 of Part 1) is used for a low-voltage switchgear and controlgear assembly $f_{127fc986/iec}-61439-2-2011$

A list of all parts of the IEC 61439 series, under the general title *Low-voltage switchgear and controlgear assemblies* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR ASSEMBLIES –

Part 2: Power switchgear and controlgear assemblies

1 Scope

NOTE 1 Throughout this part, the abbreviation PSC-ASSEMBLY (see 3.1.101) is used for a power switchgear and controlgear ASSEMBLY.

This part of IEC 61439 defines the specific requirements of power switchgear and controlgear assemblies (PSC-ASSEMBLIES) as follows:

- ASSEMBLIES for which the rated voltage does not exceed 1 000 V in case of a.c. or 1 500 V in case of d.c.;
- stationary or movable ASSEMBLIES with or without enclosure;
- ASSEMBLIES intended for use in connection with the generation, transmission, distribution and conversion of electric energy, and for the control of electric energy consuming equipment;
- ASSEMBLIES designed for use under special service conditions, for example in ships and in rail vehicles provided that the other relevant specific requirements are complied with;
 (standards.iteh.ai)
 - NOTE 2 Supplementary requirements for ASSEMBLIES in ships are covered by IEC 60092-302.
- ASSEMBLIES designed for electrical <u>39-equipment</u> of machines. Supplementary requirements for <u>ASSEMBLIES</u> forming part of a machine are covered by the IEC 60204 series.
 datf127fc986/iec-61439-2-2011

This standard applies to all ASSEMBLIES whether they are designed, manufactured and verified on a one-off basis or fully standardised and manufactured in quantity.

The manufacture and/or assembly may be carried out other than by the original manufacturer (see 3.10.1).

This standard does not apply to individual devices and self-contained components, such as motor starters, fuse switches, electronic equipment, etc. which will comply with the relevant product standards. This standard does not apply to the specific types of ASSEMBLIES covered by other parts of IEC 61439. For ASSEMBLIES not covered by other parts this part applies.

2 Normative references

This clause of Part 1 is applicable except as follows.

Addition:

IEC 60947-3:2008, Low-voltage switchgear and controlgear – Part 3: Switches, disconnectors, switch-disconnectors and fuse-combination units

IEC 61140, Protection against electric shock – Common aspects for installation and equipment

IEC 61439-1:2011, Low-voltage switchgear and controlgear assemblies – Part 1: General rules 1

3 Terms and definitions

This clause of Part 1 is applicable except as follows.

3.1 General terms

Additional definitions:

3.1.101

power switchgear and controlgear assembly PSC-ASSEMBLY

low-voltage switchgear and controlgear assembly used to distribute and control energy for all types of loads, intended for industrial, commercial and similar applications where operation by ordinary persons is not intended

NOTE It is not excluded for a PSC-ASSEMBLY to be located in an area accessible to ordinary persons.

3.1.102

test situation

condition of a PSC-ASSEMBLY or part of it in which the relevant main circuits are open on its supply side but not necessarily isolated whilst the associated auxiliary circuits are connected, allowing operation tests of the incorporated devices

3.1.103

(standards.iteh.ai)

form of internal separation

classification of physical separation within a PSC-ASSEMBLY https://standards.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9c-

3.2 Constructional units of ASSEMBLIES

Replacement of the title:

3.2 Constructional units of PSC-ASSEMBLIES

Additional definitions:

3.2.101

withdrawable part

removable part intended to be moved from the connected position to the isolated position and to a test position, if any, whilst remaining mechanically attached to the PSC-ASSEMBLY

3.2.102

test position

position of a withdrawable part in which the relevant main circuits are open on its supply side but not necessarily isolated and in which the auxiliary circuits are connected allowing operation tests of the incorporated devices, the withdrawable part remaining mechanically attached to the PSC-ASSEMBLY

NOTE The opening may also be achieved without any mechanical movement of the withdrawable part by operation of a suitable device.

¹ To be published.

3.2.103

isolated position

position of a withdrawable part in which an isolating distance is established in main and auxiliary circuits on its supply side, the withdrawable part remaining mechanically attached to the PSC-ASSEMBLY

NOTE The isolating distance may also be established without any mechanical movement of the withdrawable part by operation of a suitable device.

3.2.104

isolating distance (of a withdrawable part)

clearance between open contacts meeting the safety requirements specified for disconnectors

[IEC 60050-441:1984, 441-17-35, modified]

Addition:

3.101 Electrical connections of functional units

3.101.1

disconnectable connection

connection which is connected or disconnected by manual operation of the connecting means without a tool

3.101.2

withdrawable connection h STANDARD PREVIEW

connection which is connected or disconnected by bringing the functional unit into the connected or isolated position (standards.iten.al)

3.102 Gangways within PSC-ASSEMBLIES61439-2:2011

https://standards.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9cda1f127fc986/jec-61439-2-2011

3.102.1

operating gangway within a PSC-ASSEMBLIES

space to be used by the operator for the proper operation and supervision of the $\ensuremath{\mathsf{PSC}}$ - $\ensuremath{\mathsf{ASSEMBLY}}$

3.102.2

maintenance gangway within a PSC-ASSEMBLIES

space which is accessible to authorized personnel only and primarily intended for use when servicing the installed equipment

4 Symbols and abbreviations

This clause of Part 1 is applicable.

5 Interface characteristics

This clause of Part 1 is applicable except as follows.

5.4 Rated diversity factor (RDF)

Addition:

In the absence of an agreement between the ASSEMBLY manufacturer and user concerning the actual load currents, the assumed loading of the outgoing circuits of the ASSEMBLY or group of outgoing circuits may be based on the values in Table 101.

5.6 Other characteristics

Replacement of item I):

 the type of construction – fixed, removable or withdrawable parts (see 8.5.1 and 8.5.2 of Part 1);

Addition:

- m) the form of internal separation (see 8.101);
- n) the types of electrical connections of functional units (see 8.5.101).

6 Information

This clause of Part 1 is applicable except as follows.

6.1 ASSEMBLY designation marking

Replacement of the title and item d):

6.1 **PSC-ASSEMBLY designation marking**

d) IEC 61439-2;

7 Service conditionseh STANDARD PREVIEW

This clause of Part 1 is applicable tandards.iteh.ai)

8 Constructional requirements https://standards.iten.avcatalog/standards/sist/90b8b464-dec2-4040-9d9c-

da1f127fc986/iec-61439-2-2011 This clause of Part 1 is applicable except as follows.

8.2 Degree of protection provided by an ASSEMBLY enclosure

Replacement of the title:

8.2 Degree of protection provided by a PSC-ASSEMBLY enclosure

8.2.1 Protection against mechanical impact

Replacement of text:

Where a degree of protection provided by a PSC-ASSEMBLY enclosure against mechanical impact is declared by the original manufacturer this shall be verified in accordance with IEC 62262 (see 10.2.6).

Additional subclause:

8.2.101 PSC-ASSEMBLY with withdrawable parts

The degree of protection indicated for PSC-ASSEMBLIES normally applies to the connected position (see 3.2.3) of withdrawable parts. The ASSEMBLY manufacturer shall indicate the degree of protection obtained in the other positions and during the transfer between positions.

PSC-ASSEMBLIES with withdrawable parts may be so designed that the degree of protection applying to the connected position is also maintained in the test and isolated positions and during transfer from one position to another.

If, after the removal of a withdrawable part, it is not possible to maintain the original degree of protection e.g. by closing a door, an agreement shall be reached between the ASSEMBLY manufacturer and user as to what measures shall be taken to ensure adequate protection. Information provided by the ASSEMBLY manufacturer may take the place of such an agreement.

8.3.2 Clearances

Addition:

For withdrawable parts, the isolation provided in the isolated position shall at least comply with the requirements in the relevant specification for disconnectors (see IEC 60947-3). This applies with the equipment in new condition, taking account of the manufacturing tolerances and anticipated changes in dimensions due to wear.

The isolating distance between the withdrawable unit main contacts and their associated fixed contacts in the isolated position shall be capable of withstanding the test voltage for the declared impulse withstand voltage as specified in Table 102.

8.4.3.2.2 Requirements for earth continuity providing protection against the consequences of faults within the ASSEMBLY

Replacement of the title:

8.4.3.2.2 Requirements for earth continuity providing protection against the consequences of faults within the PSC-ASSEMBLY

Replacement of last paragraph: (standards.iteh.ai)

When removable or withdrawable parts are equipped with a metal supporting surface, these surfaces shall be considered sufficient for ensuring earth continuity of protective circuits provided that the pressure exerted on them is sufficiently high. The continuity of the protective circuit of a withdrawable part shall remain effective from the connected position to the isolated position inclusively.

8.4.6.1 Devices to be operated or components to be replaced by ordinary persons

This subclause of Part 1 is not applicable.

8.4.6.2 Requirements related to accessibility in service by authorized persons

Additional subclause:

8.4.6.2.101 Operating and maintenance gangways within a PSC-ASSEMBLY

Operating and maintenance gangways (see 3.102.1 and 3.102.2) within an ASSEMBLY shall comply with the requirements for basic protection as specified in IEC 61140. The design and construction of such gangways shall be agreed upon between ASSEMBLY manufacturer and user.

Recesses within a PSC-ASSEMBLY of limited depth, in the order of 1 m, are not considered to be gangways.

8.5.2 Removable parts

Replacement of the title:

8.5.2 Removable and withdrawable parts

Replacement of text:

The removable and withdrawable parts shall be so constructed that their electrical equipment can be safely removed and/or isolated from or connected to the main circuit whilst this circuit is live. The removable and withdrawable parts may be provided with an insertion interlock (see 3.2.5 of Part 1).

Clearances and creepage distances (see 8.3 of Part 1 and 8.3.2 above) shall be complied with in the different positions as well as during transfer from one position to another.

Additional subclauses:

8.5.2.101 Withdrawable parts

Withdrawable parts shall have in addition an isolated position (see 3.2.103) and may have a test position (see 3.2.102), or a test situation (see 3.1.102). They shall be distinctly located in these positions. These positions shall be clearly discernible.

In PSC-ASSEMBLIES with withdrawable parts all live parts shall be protected in such a manner that they cannot unintentionally be touched when the door, if any, is open and the withdrawable part is withdrawn from the connected position or removed. Where an obstacle or shutter is used they shall meet the requirements of 8.4.6.2.5 of Part 1.

For the electrical conditions associated with the different positions of withdrawable parts, see Table 103.

8.5.2.102 Interlocking and padlocking of removable and withdrawable parts

Unless otherwise specified the removable and withdrawable parts shall be fitted with a device, which ensures that the apparatus can only be removed/withdrawn and/or re-inserted after its main circuit has been interrupted. IEC 61439-2:2011

https://standards.iteh.ai/catalog/standards/sist/90b8b464-dec2-4040-9d9c-

In order to prevent unauthorized operation the removable and withdrawable parts or their associated ASSEMBLY location may be provided with a lockable means to secure them in one or more of their positions.

Addition:

8.5.101 Description of the types of electrical connections of functional units

The types of electrical connections of functional units within PSC-ASSEMBLIES or parts of PSC-ASSEMBLIES can be denoted by a three-letter code:

- the first letter denotes the type of electrical connection of the main incoming circuit;
- the second letter denotes the type of electrical connection of the main outgoing circuit;
- the third letter denotes the type of electrical connection of the auxiliary circuits.

The following letters shall be used:

- F for fixed connections (see 3.2.6 of Part 1);
- D for disconnectable connections (see 3.101.1);
- W for withdrawable connections (see 3.101.2).

Addition:

8.101 Internal separation of PSC-ASSEMBLIES

Typical arrangements of internal separation by barriers or partitions are described in Table 104 and are classified as forms (for examples, see Annex AA).

The form of separation and higher degrees of protection shall be the subject of an agreement between ASSEMBLY manufacturer and user.

Internal separation may be used to attain one or more of the following conditions between functional units, separate compartments or enclosed protected spaces:

- protection against contact with hazardous parts. The degree of protection shall be at least IP XXB (see 8.4.2.3);
- protection against the passage of solid foreign bodies. The degree of protection shall be at least IP 2X.

NOTE 1 The degree of protection IP 2X covers the degree of protection IP XXB. Separation may be achieved by means of partitions or barriers (metallic or non-metallic), insulation of live parts or the integral housing of a device e.g. a moulded case circuit breaker.

See 8.4.2.3 of Part 1 with regard to stability and durability of barriers and partitions.

See 8.4.6.2 of Part 1 and above with regard to accessibility for maintenance on isolated functional units.

NOTE 2 The internal separation described is not intended to guarantee the integrity of the ASSEMBLY in the event of an arcing fault.

9 Performance requirements

This clause of Part 1 is applicable.

(standards.iteh.ai)

10 Design verification

IEC 61439-2:2011

This clause of Parth1pis//applicable.exceptgasufollowst/90b8b464-dec2-4040-9d9cda1f127fc986/iec-61439-2-2011

10.2.6 Mechanical impact

Replacement:

When a mechanical impact test is performed, it shall be carried out according to 9.6 of IEC 62208:2002.

10.3 Degree of protection of ASSEMBLIES

Addition:

The degree of protection associated with withdrawable parts as specified in accordance with 8.2.101 and associated with internal separation in accordance with 8.101 shall be verified in accordance with IEC 60529.

10.9.3.2 Impulse withstand voltage test

Addition:

The impulse withstand voltage capability of the isolating distance between the withdrawable units' main contacts and their associated fixed contacts shall be verified to confirm compliance with 8.3.2.

10.13 Mechanical operation

Addition:

In the case of withdrawable parts, the operating cycle includes any physical movements from the connected to the isolated position and back to the connected position.

11 Routine verification

This clause of Part 1 is applicable except as follows.

11.8 Mechanical operation

Replacement:

Verification shall include the checking of interlocking and locking arrangements associated with removable and withdrawable parts.

Type of load	Assumed loading factor
Distribution – 2 and 3 circuits	0,9
Distribution – 4 and 5 circuits	0,8
Distribution – 6 to 9 circuits	0,7
Distribution – 10 or more circuits	0,6
Electric actuator	
Motors ≤ 100 kW	0,8
Motors > 100 kW	

Table 101 – Values of assumed loading

IEC 61439-2:2011

Table 102 – Test voltages across the open contacts of equipment suitable for isolation

			Test volt	tages and	correspo	nding alt	itudes du	iring test		
withstand voltage		U _{1,2/50} , a	a.c. peak kV	and d.c.			i	a.c. r.m.s kV		
U _{imp} kV	Sea level	200 m	500 m	1 000 m	2 000 m	Sea level	200 m	500 m	1 000 m	2 000 m
0,33	1,8	1,7	1,7	1,6	1,5	1,3	1,2	1,2	1,1	1,06
0,5	1,8	1,7	1,7	1,6	1,5	1,3	1,2	1,2	1,1	1,06
0,8	1,8	1,7	1,7	1,6	1,5	1,3	1,2	1,2	1,1	1,06
1,5	2,3	2,3	2,2	2,2	2,0	1,6	1,6	1,55	1,55	1,42
2,5	3,5	3,5	3,4	3,2	3,0	2,47	2,47	2,40	2,26	2,12
4	6,2	6,0	5,8	5,6	5,0	4,38	4,24	4,10	3,96	3,54
6	9,8	9,6	9,3	9,0	8,0	7,00	6,80	6,60	6,40	5,66
8	12,3	12,1	11,7	11,1	10,0	8,70	8,55	8,27	7,85	7,07
12	18,5	18,1	17,5	16,7	15,0	13,10	12,80	12,37	11,80	10,60

	and the same of the discussion.		Posi	tion	
CIrcuit	METING OF CONTRECTION Leh STANDAR	Connected position (see 3.2.3 of Part 1)	Test situation/position (see 3.1.102/3.2.102)	Isolated position (see 3.2.103)	Removed position (see 3.2.4 of Part 1)
Incoming main circuit	Incoming line plug and socket or other connection	.iteh.ai)		\bigcirc	\bigcirc
Outgoing main circuit https://	Outgoing line plug and 1439- socket or other connection stacinitiesteh ai/catalog/standards	2:2011 /sist/90b8b464-dec2-4040-9d90	or	or O a	\bigcirc
Auxiliary circuit	Plug and socket of similar connection facilities	1439-2-2011		0	0
Condition of circuits within wi	thdrawable parts	Live	Live Auxiliary circuits ready for operational testing	Dead if no backfeed is present	0
Condition of outgoing PSC-ASS circuits	EMBLY terminals of main	Live	Live or not disconnected ^b	Dead if no backfeed is present	Dead if no backfeed is present
			The requirements of 8.4.5 of	Part 1 shall be complied with.	
Earth continuity shall be in a ^a Depending on design.	cordance with 8.4.3.2.2 and ma	aintained until the isolating dist	ance is established.		
^b Depending on the terminal	s being fed from alternative sou	irces of supply such as a stand	by supply.		
= connected					
= isolated					
= open, but not nec	sssarily isolated				

Table 103 – Electrical conditions for the different positions of withdrawable parts