

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Low-voltage fuses – **STANDARD PREVIEW**
Part 1: General requirements
(standards.iteh.ai)

Fusibles basse tension – **IEC 60269-1:2006+AMD1:2009 CSV**
Partie 1: Exigences générales
<https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv>



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2009 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland
Email: inmail@iec.ch
Web: www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: www.iec.ch/searchpub

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: www.iec.ch/online_news/justpub

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

- Electropedia: www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: www.iec.ch/webstore/custserv

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: csc@iec.ch
Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: www.iec.ch/searchpub/cur_fut-f.htm

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: www.iec.ch/online_news/justpub

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: www.iec.ch/webstore/custserv/custserv_entry-f.htm

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: csc@iec.ch
Tél.: +41 22 919 02 11
Fax: +41 22 919 03 00



IEC 60269-1

Edition 4.1 2009-07

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Low-voltage fuses – **STANDARD PREVIEW**
Part 1: General requirements
(standards.iteh.ai)

Fusibles basse tension – [IEC 60269-1:2006+AMD1:2009 CSV](https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv)
Partie 1: Exigences générales

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.50

ISBN 978-2-88910-086-6

CONTENTS

FOREWORD.....	5
INTRODUCTION.....	7
1 General	8
1.1 Scope and object.....	8
1.2 Normative references	9
2 Terms and definitions	10
2.1 Fuses and their component parts	10
2.2 General terms.....	11
2.3 Characteristic quantities	14
3 Conditions for operation in service	17
3.1 Ambient air temperature (T_a)	17
3.2 Altitude.....	17
3.3 Atmospheric conditions.....	17
3.4 Voltage.....	18
3.5 Current.....	18
3.6 Frequency, power factor and time constant	18
3.7 Conditions of installation.....	18
3.8 Utilization category	18
3.9 Discrimination of fuse-links.....	19
4 Classification	19
5 Characteristics of fuses	19
5.1 Summary of characteristics.....	19
5.2 Rated voltage	20
5.3 Rated current	20
5.4 Rated frequency (see 6.1 and 6.2)	20
5.5 Rated power dissipation of a fuse-link and rated acceptable power dissipation of a fuse-holder	21
5.6 Limits of time-current characteristics.....	21
5.7 Breaking range and breaking capacity.....	23
5.8 Cut-off current and I^2t characteristics	24
6 Markings.....	24
6.1 Markings of fuse-holders	24
6.2 Markings of fuse-links.....	25
6.3 Marking symbols.....	25
7 Standard conditions for construction	25
7.1 Mechanical design	25
7.2 Insulating properties and suitability for isolation.....	26
7.3 Temperature rise, power dissipation of the fuse-link and acceptable power dissipation of a fuse-holder	27
7.4 Operation	28
7.5 Breaking capacity	29
7.6 Cut-off current characteristic.....	29
7.7 I^2t characteristics	29
7.8 Overcurrent discrimination of fuse-links	30
7.9 Protection against electric shock.....	30

ITC STANDARD PREVIEW
 (standards.iteh.ai)

IEC 60269-1:2006+AMD1:2009 CSV
<https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv>

7.10	Resistance to heat.....	33
7.11	Mechanical strength.....	33
7.12	Resistance to corrosion	33
7.13	Resistance to abnormal heat and fire	33
7.14	Electromagnetic compatibility.....	33
8	Tests.....	34
8.1	General	34
8.2	Verification of the insulating properties and of the suitability for isolation	39
8.3	Verification of temperature rise and power dissipation	41
8.4	Verification of operation	44
8.5	Verification of the breaking capacity.....	49
8.6	Verification of the cut-off current characteristics.....	55
8.7	Verification of I^2t characteristics and overcurrent discrimination.....	55
8.8	Verification of the degree of protection of enclosures	56
8.9	Verification of resistance to heat.....	56
8.10	Verification of non-deterioration of contacts	56
8.11	Mechanical and miscellaneous tests	57
	Annex A (informative) Measurement of short-circuit power factor	69
	Annex B (informative) Calculation of pre-arcing I^2t values for "gG", "gM", "gD" and "gN" fuse-links and calculation of operating I^2t values at reduced voltage.....	72
	Annex C (informative) Calculation of cut-off current-time characteristic.....	74
	Annex D (informative) Effect of change of ambient temperature and surroundings on the performance of fuse-links.....	78
	Annex E (normative) Particular requirements for fuse-bases with screwless-type terminals for external copper conductors.....	79
	Figure 1 – Diagram illustrating the means of verification of the time-current characteristic, using the results of the tests at the "gate" currents (example).....	60
	Figure 2 – Overload curve and time-current characteristic for "a" fuse-links	61
	Figure 3 – Time current zone for aM fuses.....	62
	Figure 4 – General presentation of the cut-off characteristics for a series of a.c. fuse-links.....	63
	Figure 5 – Typical diagram of the circuit used for breaking capacity test (see 8.5).....	64
	Figure 6 – Interpretation of oscillograms taken during the a.c. breaking-capacity tests (see 8.5.7)	65
	Figure 7 – Interpretation of oscillograms taken during the d.c. breaking-capacity tests (see 8.5.7)	66
	Figure 8 – Glow-wire and position of the thermocouple	67
	Figure 9 – Test apparatus (example)	68
	Figure A.1 – Determination of circuit-impedance for calculation of power factor in accordance with method I	71
	Figure C.1 – Cut-off current characteristic as a function of actual pre-arcing time	77
	Figure E.1 – Connecting samples	84
	Figure E.2 – Examples of terminals	85

Table 1 – Standard values of a.c. rated voltages for fuses	20
Table 2 – Conventional time and current for "gG" and "gM" fuse-links	22
Table 3 – Gates for specified pre-arcing times of "gG" and "gM" fuse-links	22
Table 4 – Gates for "aM" fuse-links (all rated currents).....	23
Table 5 – Temperature rise limits $\Delta T = (T - T_a)$ for contacts and terminals.....	27
Table 6 – Maximum arc voltage	29
Table 7 – Pre-arcing I^2t values at 0,01 s for "gG" and "gM" fuse-links.....	30
Table 8 – Rated impulse withstand voltage	31
Table 9 – Minimum clearances in air	31
Table 10 – Minimum creepage distances	32
Table 11 – Survey of complete tests on fuse-links and number of fuse-links to be tested	36
Table 12 – Survey of tests on fuse-links of smallest rated current of homogeneous series and number of fuse-links to be tested.....	37
Table 13 – Survey of tests on fuse-links of rated currents between the largest and the smallest rated current of a homogeneous series and number of fuse-links to be tested	38
Table 14 – Survey of complete tests on fuse-holders and number of fuse-holders to be tested.....	38
Table 15 – Test voltage.....	40
Table 16 – Test voltage across the poles for the verification of the suitability for isolation	41
Table 17 – Cross-sectional area of copper conductors for tests corresponding to Subclauses 8.3 and 8.4	43
Table 18 – Cross-section areas of the copper conductors for the test of "aM" fuses	46
Table 19 – Table for test in Subclause 8.4.3.5.....	48
Table 20 – Values for breaking-capacity tests on a.c. fuses	51
Table 21 – Values for breaking capacity tests on d.c. fuses	52
Table E.1 – Connectable conductors	81
Table E.2 – Cross-sections of copper conductors connectable to terminals.....	81
Table E.3 – Pull forces	83

INTERNATIONAL ELECTROTECHNICAL COMMISSION

LOW-VOLTAGE FUSES –

Part 1: General requirements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC provides no marking procedure to indicate its approval and cannot be rendered responsible for any equipment declared to be in conformity with an IEC Publication.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60269-1 has been prepared by subcommittee 32B: Low-voltage fuses, of IEC technical committee 32: Fuses.

The general re-organization of the IEC 60269 series has led to the creation of this new edition.

This consolidated version of IEC 60269-1 consists of the fourth edition (2006) [documents 32B/483/FDIS and 32B/490/RVD] and its amendment 1 (2009) [documents 32B/534/FDIS and 32B/540/RVD].

The technical content is therefore identical to the base edition and its amendment and has been prepared for user convenience.

It bears the edition number 4.1.

A vertical line in the margin shows where the base publication has been modified by amendment 1.

IEC 60269 consists of the following parts, under the general title *Low-voltage fuses*:

Part 1: General requirements

NOTE This part includes IEC 60269-1 (third edition, 1998) and parts of IEC 60269-2 (second edition, 1986) and IEC 60269-3 (second edition, 1987).

Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to I

NOTE This part includes parts of IEC 60269-2 (second edition, 1986) and all of IEC 60269-2-1 (fourth edition, 2004).

Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F

NOTE This part includes parts of IEC 60269-3 (second edition, 1987) and all of IEC 60269-3-1 (second edition, 2004).

Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices

NOTE This part includes IEC 60269-4 (third edition, 1986) and IEC 60269-4-1 (first edition, 2002).

Part 5: Guidance for the application of low-voltage fuses

NOTE Currently IEC/TR 61818 (2003).

For reasons of convenience, when a part of this publication has come from other publications, a remark to this effect has been inserted in the text.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the maintenance result date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

(standards.iteh.ai)

[IEC 60269-1:2006+AMD1:2009 CSV](https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv)

<https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv>

INTRODUCTION

A reorganization of the different parts of the IEC 60269 series has been carried out, in order to simplify its use, especially by the laboratories which test the fuses.

IEC 60269-1, IEC 60269-2, IEC 60269-3 and IEC 60269-3-1 have been integrated into either the new part 1 or the new parts 2 or 3, according to the subjects considered, so that the clauses which deal exclusively with “fuses for authorized persons” are separated from the clauses dealing with “fuses for unauthorized persons”.

As far as IEC 60269-4 and IEC 60269-4-1 are concerned, they have been integrated into the new part 4 which deals with the fuse-links used for semiconductor protection.

iTeh STANDARD PREVIEW **(standards.iteh.ai)**

[IEC 60269-1:2006+AMD1:2009 CSV](https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv)

<https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv>

LOW-VOLTAGE FUSES –

Part 1: General requirements

1 General

1.1 Scope and object

This part of IEC 60269 is applicable to fuses incorporating enclosed current-limiting fuse-links with rated breaking capacities of not less than 6 kA, intended for protecting power-frequency a.c. circuits of nominal voltages not exceeding 1 000 V or d.c. circuits of nominal voltages not exceeding 1 500 V.

Subsequent parts of this standard, referred to herein, cover supplementary requirements for such fuses intended for specific conditions of use or applications.

Fuse-links intended to be included in fuse-switch combinations according to IEC 60947-3 should also comply with the following requirements.

NOTE 1 For "a" fuse-links, details of performance (see 2.2.4) on d.c. circuits should be subject to agreement between user and manufacturer.

NOTE 2 Modifications of, and supplements to, this standard required for certain types of fuses for particular applications – for example, certain fuses for rolling stock, or fuses for high-frequency circuits – will be covered, if necessary, by separate standards.

NOTE 3 This standard does not apply to miniature fuses, these being covered by IEC 60127.

The object of this standard is to establish the characteristics of fuses or parts of fuses (fuse-base, fuse-carrier, fuse-link) in such a way that they can be replaced by other fuses or parts of fuses having the same characteristics provided that they are interchangeable as far as their dimensions are concerned. For this purpose, this standard refers in particular to

- the following characteristics of fuses:
 - their rated values;
 - their insulation;
 - their temperature rise in normal service;
 - their power dissipation and acceptable power dissipation;
 - their time/current characteristics;
 - their breaking capacity;
 - their cut-off current characteristics and their I^2t characteristics.
- type test for verification of the characteristics of fuses;
- the marking of fuses.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60038:1983, *IEC standard voltages*

IEC 60050(441):1984, *International Electrotechnical Vocabulary (IEV) – Chapter 441: Switchgear, controlgear and fuses*
Amendment 1 (2000)

IEC 60269-2, *Low-voltage fuses – Part 2: Supplementary requirements for fuses for use by authorized persons (fuses mainly for industrial application) – Examples of standardized systems of fuses A to I)*

IEC 60269-3, *Low-voltage fuses – Part 3: Supplementary requirements for fuses for use by unskilled persons (fuses mainly for household or similar application) – Examples of standardized systems of fuses A to F*

IEC 60269-4, *Low-voltage fuses – Part 4: Supplementary requirements for fuse-links for the protection of semiconductor devices*

IEC 60269-5, *Low-voltage fuses – Part 5: Guidance for the application of low-voltage fuses*

IEC 60364-3:1993, *Electrical installations of buildings – Part 3: Assessment of general characteristics*

IEC 60364-5-52:2001, *Electrical installations of buildings – Part 5-52: Selection and erection of electrical equipment – Wiring system*

IEC 60529:1989, *Degrees of protection provided by enclosures (Code IP)*

IEC 60584-1:1995, *Thermocouples – Part 1: Reference tables*

IEC 60617, *Graphical symbols for diagrams*

IEC 60664-1:2002, *Insulation coordination for equipment within low-voltage systems – Part 1: Principles, requirements and tests*

IEC 60695-2-10:2000, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 0: Glow-wire test methods – General*

IEC 60695-2-11:2000, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 1: Glow-wire end-product test and guidance*

IEC 60695-2-12:2000, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 2: Glow-wire flammability test on materials*

IEC 60695-2-13:2000, *Fire hazard testing – Part 2: Test methods – Section 1/sheet 3: Glow-wire ignitability test on materials*

ISO 3:1973, *Preferred numbers – Series of preferred numbers*

ISO 478:1974, *Paper – Untrimmed stock sizes for the ISO-A series – ISO primary range*

ISO 593:1974, *Paper – Untrimmed stock size for the ISO-A series – ISO supplementary range*

ISO 4046:1978, *Paper, board, pulp and related terms – Vocabulary – Bilingual edition*

2 Terms and definitions

NOTE For general definitions concerning fuses, see also IEC 60050-441.

For the purposes of this document, the following terms and definitions apply.

2.1 Fuses and their component parts

2.1.1

fuse

device that by the fusing of one or more of its specially designed and proportioned components opens the circuit in which it is inserted by breaking the current when this exceeds a given value for a sufficient time. The fuse comprises all the parts that form the complete device

[IEV 441-18-01]

2.1.2

fuse-holder

combination of the fuse-base with its fuse-carrier

NOTE Where, in this standard, the term "fuse-holder" is used, it covers fuse-bases and/or fuse-carriers, if no clearer distinction is necessary.

[IEV 441-18-14]

2.1.2.1

fuse-base (fuse-mount)

fixed part of a fuse provided with contacts and terminals

[IEV 441-18-02]

NOTE Where applicable, covers are considered as part of the fuse-base.

2.1.2.2

fuse-carrier

movable part of a fuse designed to carry a fuse-link

[IEV 441-18-13]

2.1.3

fuse-link

part of a fuse including the fuse-element(s), intended to be replaced after the fuse has operated

[IEV 441-18-09]

2.1.4

fuse-contact

two or more conductive parts designed to ensure circuit continuity between a fuse-link and the corresponding fuse-holder

2.1.5

fuse-element

part of the fuse-link designed to melt under the action of current exceeding some definite value for a definite period of time

[IEV 441-18-08]

NOTE The fuse-link may comprise several fuse-elements in parallel.

iTeh STANDARD PREVIEW
(standards.iteh.ai)

[IEC 60269-1:2006+AMD1:2009 CSV](https://standards.iteh.ai/catalog/standards/sis/6b40b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv)

<https://standards.iteh.ai/catalog/standards/sis/6b40b7fa-c93c-4d88-b1d0-3626b23ca591/iec-60269-1-2006amd1-2009-csv>

2.1.6**indicating device (indicator)**

part of a fuse provided to indicate whether the fuse has operated

[IEV 441-18-17]

2.1.7**striker**

mechanical device forming part of a fuse-link which, when the fuse operates, releases the energy required to cause operation of other apparatus or indicators or to provide interlocking

[IEV 441-18-18]

2.1.8**terminal**

conductive part of a fuse provided for electric connection to external circuits

NOTE Terminals may be distinguished according to the kind of circuits for which they are intended (for example, main terminal, earth terminal, etc.) and also according to their design (for example, screw terminal, plug terminal, etc.).

2.1.9**dummy fuse-link**

test fuse-link with defined power dissipation and dimensions

2.1.10**test rig**

defined test fuse-base

iTeh STANDARD PREVIEW
(standards.iteh.ai)

2.1.11**gauge-piece**

additional part of a fuse-base intended to achieve a degree of non-interchangeability

<https://standards.iteh.ai/catalog/standards/sist/6b49b7fa-c93c-4d88-b1d0-2604f37c517e/iec-60269-1-2006-amd1-2009>

2.1.12**linked fuse-carrier**

a fuse-carrier which is mechanically linked to the fuse-base and gives a defined insertion and withdrawal movement to the fuse-link

[This definition was definition 2.1.12 in IEC 60269-2-1, Section I, which has been withdrawn.]

2.2 General terms**2.2.1****enclosed fuse-link**

fuse-link in which the fuse-element(s) is (are) totally enclosed, so that during operation within its rating it cannot produce any harmful external effects, for example, due to development of an arc, the release of gas or the ejection of flame or metallic particles

[IEV 441-18-12]

2.2.2**current-limiting fuse-link**

fuse-link that during and by its operation in a specified current range, limits the current to a substantially lower value than the peak value of the prospective current

[IEV 441-18-10]

2.2.3

"g" fuse-link

(full-range breaking-capacity fuse-link, formerly general purpose fuse-link)

current-limiting fuse-link capable of breaking under specified conditions all currents, which cause melting of the fuse-element up to its rated breaking capacity

2.2.4

"a" fuse-link

(partial-range breaking-capacity fuse-link, formerly back-up fuse-link)

current-limiting fuse-link capable of breaking under specified conditions all currents between the lowest current indicated on its operating time-current characteristic ($k_2 I_n$ in Figure 2) and its rated breaking capacity

NOTE "a" fuse-links are generally used to provide short-circuit protection. Where protection is required against over-currents less than $k_2 I_n$ in Figure 2, they are used in conjunction with another suitable switching device designed to interrupt such small overcurrents.

2.2.5

temperatures

2.2.5.1

ambient air temperature

T_a

the temperature of the air surrounding the fuse (at a distance of about 1 m from the fuse or its enclosure, if any)

2.2.5.2

fluid environment temperature (standards.iteh.ai)

T_e

temperature of the fluid cooling the fuse-components (contact, terminal, etc.). It is the sum of the ambient air temperature T_a and the temperature rise ΔT_e with respect to the ambient temperature of the internal fluid in contact with the fuse-components (contact, terminal, etc.) if the latter is in an enclosure. If it is not in an enclosure, it is assumed that T_e is equal to T_a

2.2.5.3

fuse-component temperature

T

fuse-component (contact, terminal, etc.) temperature T is that of the relevant part

2.2.6

overcurrent discrimination

coordination of the relevant characteristics of two or more overcurrent protective devices such that, on the occurrence of overcurrents within stated limits, the device intended to operate within these limits does so, while the other(s) do(es) not

2.2.7

fuse system

family of fuses following the same physical design principles with respect to the shape of the fuse-links, type of contact, etc.

2.2.8

size

specified set of dimensions of fuses within a fuse system. Each individual size covers a given range of rated currents for which the specified dimensions of the fuses remain unchanged

2.2.9

homogeneous series of fuse-links

series of fuse-links, within a given size, deviating from each other only in such characteristics that for a given test, the testing of one or a reduced number of particular fuse-links of that series may be taken as representative for all the fuse-links of the homogeneous series

NOTE The characteristics by which the fuse-links of a homogeneous series may deviate and details on which of the fuse-links shall be tested are specified in association with the tests concerned (see Tables 12 and 13).

[IEV 441-18-34, modified]

2.2.10

utilization category (of a fuse-link)

combination of specified requirements related to the conditions in which the fuse-link fulfils its purpose, selected to represent a characteristic group of practical applications (see 5.7.1)

2.2.11

fuses for use by authorized persons

(formerly called fuses for industrial application)

fuses intended to be used in installations where the fuse-links are accessible to and intended to be replaced by authorized persons only

NOTE 1 Non-interchangeability and protection against accidental contact with live parts need not necessarily be ensured by constructional means.

NOTE 2 Authorized person is understood to have the meaning defined for categories BA 4 "instructed"¹ and BA 5 "skilled"² in IEC 60364-3.

2.2.12

fuses for use by unskilled persons (formerly called fuses for domestic and similar applications)

fuses intended to be used in installations where the fuse-links are accessible to, and can be replaced by, unskilled persons

NOTE For these fuses, protection against direct contact with live parts is recommended and non-interchangeability may be required, if necessary

2.2.13

non-interchangeability

limitations on shape and/on dimensions with the object of avoiding in a specific fuse-base the inadvertent use of fuse-links having electrical properties other than those ensuring the desired degree of protection

[IEV 441-18-33]

¹ Instructed: Persons adequately advised or supervised by skilled persons to enable them to avoid dangers which electricity may create (operating and maintenance staff).

² Skilled: Persons with technical knowledge or sufficient experience to enable them to avoid dangers which electricity may create (engineers and technicians).