

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 3-22: Data-link layer service definition – Type 22 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 3-22: Définition des services de couche liaison de données – Eléments
de Type 22**



THIS PUBLICATION IS COPYRIGHT PROTECTED
Copyright © 2010 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.
If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.
Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

Useful links:

IEC publications search - www.iec.ch/searchpub

The advanced search enables you to find IEC publications by a variety of criteria (reference number, text, technical committee,...).

It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available on-line and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary (IEV) on-line.

Customer Service Centre - webstore.iec.ch/csc/iec-

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Liens utiles:

Recherche de publications CEI - www.iec.ch/searchpub

La recherche avancée vous permet de trouver des publications CEI en utilisant différents critères (numéro de référence, texte, comité d'études,...).

Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

Just Published CEI - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications de la CEI. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (VEI) en ligne.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Industrial communication networks – Fieldbus specifications –
Part 3-22: Data-link layer service definition – Type 22 elements**

**Réseaux de communication industriels – Spécifications des bus de terrain –
Partie 3-22: Définition des services de couche liaison de données – Eléments
de Type 22**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

PRICE CODE
CODE PRIX



ICS 25.040.40; 35.100.20; 35.110

ISBN 978-2-88912-857-0

**Warning! Make sure that you obtained this publication from an authorized distributor.
Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.**

CONTENTS

| | |
|--|----|
| FOREWORD..... | 4 |
| INTRODUCTION..... | 6 |
| 1 Scope..... | 7 |
| 1.1 Overview..... | 7 |
| 1.2 Specifications..... | 7 |
| 1.3 Conformance..... | 7 |
| 2 Normative References..... | 8 |
| 3 Terms, definitions, symbols, abbreviations and conventions..... | 8 |
| 3.1 Reference model terms and definitions..... | 8 |
| 3.2 Service convention terms and definitions..... | 10 |
| 3.3 Data-link service terms and definitions..... | 11 |
| 3.4 Symbols and abbreviations..... | 13 |
| 3.5 Common conventions..... | 15 |
| 4 Data-link layer services and concepts..... | 16 |
| 4.1 Operating principle..... | 16 |
| 4.2 Communication models..... | 16 |
| 4.3 Topology..... | 18 |
| 4.4 Addressing..... | 19 |
| 4.5 Gateway..... | 20 |
| 4.6 Interaction models..... | 20 |
| 4.7 Synchronization concept..... | 20 |
| 5 Communication services..... | 21 |
| 5.1 Overview..... | 21 |
| 5.2 Communication management services..... | 23 |
| 5.3 Cyclic data channel service (CDC)..... | 27 |
| 5.4 Message channel services (MSC)..... | 28 |
| 5.5 Time synchronization..... | 29 |
| 5.6 Media independent interface (MII) management services..... | 32 |
| Bibliography..... | 34 |
| Figure 1 – RTFL device reference model..... | 17 |
| Figure 2 – RTFN device reference model..... | 18 |
| Figure 3 – Logical double line in a physical tree topology..... | 18 |
| Figure 4 – Logical double line in a physical line topology..... | 19 |
| Figure 5 – Addressing modes..... | 19 |
| Figure 6 – Time sequence diagram for time SYNC_START service..... | 21 |
| Figure 7 – Synchronized timing signals without offset..... | 21 |
| Figure 8 – Synchronized timing signals with offset..... | 21 |
| Table 1 – Summary of DL-services and primitives..... | 22 |
| Table 2 – DL-Network verification service (NV)..... | 23 |
| Table 3 – DL-RTFN scan network read service (RTFNSNR)..... | 23 |
| Table 4 – DL-RTFN connection establishment DLL service (RTFNCE)..... | 24 |

| | |
|---|----|
| Table 5 – DL-RTFN connection release service (RTFNCR) | 24 |
| Table 6 – DL-RTFL control service (RTFLCTL) | 25 |
| Table 7 – DL-RTFL configuration service (RTFLCFG) | 25 |
| Table 8 – DL-Read configuration data service (RDCD) | 26 |
| Table 9 – CDC send service (CDCS) | 28 |
| Table 10 – MSC send service (MSCS) | 28 |
| Table 11 – MSC send broadcast service (MSCSB)..... | 29 |
| Table 12 – MSC read service (MSCR) | 29 |
| Table 13 – DL-DelayMeasurement start service (DMS)..... | 30 |
| Table 14 – DL-DelayMeasurement read service (DMR)..... | 30 |
| Table 15 – DL-PCS configuration service (PCSC)..... | 30 |
| Table 16 – DL-Sync master configuration service (SYNC_MC) | 31 |
| Table 17 – DL-Sync start service (SYNC_START) | 31 |
| Table 18 – DL-Sync stop service (SYNC_STOP)..... | 32 |
| Table 19 – DL-MII read service (MIIR) | 32 |
| Table 20 – DL-MII write service (MIIW)..... | 33 |

iTeh STANDARD PREVIEW
(standards.iteh.ai)

IEC 61158-3-22:2010

[https://standards.iteh.ai/catalog/standards/sist/4a90-a48e-41b5-ac82-edf3c1ad822b/iec-](https://standards.iteh.ai/catalog/standards/sist/4a90-a48e-41b5-ac82-edf3c1ad822b/iec-61158-3-22-2010)

61158-3-22-2010

Withstand

INTERNATIONAL ELECTROTECHNICAL COMMISSION

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-22: Data-link layer service definition – Type 22 elements

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as “IEC Publication(s)”). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

NOTE 1 Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the profile parts. Use of the various protocol types in other combinations may require permission of their respective intellectual-property-right holders.

International Standard IEC 61158-3-22 has been prepared by subcommittee 65C: Industrial networks, of IEC technical committee 65: Industrial process measurement, control and automation.

This standard cancels and replaces IEC/PAS 61158-3-22 published in 2009. This first edition constitutes a technical revision.

This bilingual version published in 2012-01 corresponds to the English version published in 2010-08.

The text of this standard is based on the following documents:

| FDIS | Report on voting |
|--------------|------------------|
| 65C/604/FDIS | 65C/618/RVD |

Full information on the voting for the approval of this International Standard can be found in the report on voting indicated in the above table.

The French version has not been voted upon.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

A list of all parts of the IEC 61158 series, published under the general title *Industrial communication networks – Fieldbus specifications*, can be found on the IEC web site.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "http://webstore.iec.ch" in the data related to the specific publication. At this date, the publication will be:

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

NOTE The revision of this standard will be synchronized with the other parts of the IEC 61158 series.

<https://standards.iec.ch/sata/standards/iec/61158-3-22-2010>

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.



iTeh STANDARD PREVIEW
(standards.iteh.ai)

<https://standards.iteh.ai/catalog/standards/sist/52e24a90-a48e-41b5-ac82-edf3c1ad822b/iec-61158-3-22-2010>

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-22: Data-link layer service definition – Type 22 elements

1 Scope

1.1 Overview

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 22 fieldbus data-link layer in terms of:

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take; and
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to:

- the Type 22 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model; and
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously-existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including:

- a) the sizes and octet ordering of various multi-octet service parameters; and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor do they constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition standard. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfils the Type 22 data-link layer services defined in this standard.

2 Normative References

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO/IEC 7498-1, *Information technology – Open Systems Interconnection – Basic Reference Model: The Basic Model*

ISO/IEC 7498-3, *Information technology – Open Systems Interconnection – Basic Reference Model: Naming and addressing*

ISO/IEC 10731, *Information technology – Open Systems Interconnection – Basic Reference Model – Conventions for the definition of OSI services*

ISO/IEC 8802-3:2000, *Information Technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications.*

3 Terms, definitions, symbols, abbreviations and conventions

For the purposes of this document, the following terms, definitions, symbols, abbreviations and conventions apply.

3.1 Reference model terms and definitions

This standard is based in part on the concepts developed in ISO/IEC 7498-1 and ISO/IEC 7498-3, and makes use of the following terms defined therein:

| | |
|--|------------------|
| DL-address | [ISO/IEC 7498-3] |
| called-DL-address | [ISO/IEC 7498-3] |
| calling-DL-address | [ISO/IEC 7498-3] |
| DL-connection | [ISO/IEC 7498-1] |
| DL-connection-end-point | [ISO/IEC 7498-1] |
| DL-connection-end-point-identifier | [ISO/IEC 7498-1] |
| DL-connection-mode transmission | [ISO/IEC 7498-1] |
| DL-connectionless-mode transmission | [ISO/IEC 7498-1] |
| correspondent (N)-entities | [ISO/IEC 7498-1] |
| correspondent DL-entities (N=2) | |
| correspondent Ph-entities (N=1) | |
| decentralized multi-end-point-connection | [ISO/IEC 7498-1] |
| DL-duplex-transmission | [ISO/IEC 7498-1] |

| | |
|-----------------------------------|------------------|
| (N)-entity | [ISO/IEC 7498-1] |
| DL-entity (N=2) | |
| Ph-entity (N=1) | |
| DL-facility | [ISO/IEC 7498-1] |
| flow control | [ISO/IEC 7498-1] |
| (N)-layer | [ISO/IEC 7498-1] |
| DL-layer (N=2) | |
| Ph-layer (N=1) | |
| layer-management | [ISO/IEC 7498-1] |
| DL-local-view | [ISO/IEC 7498-3] |
| multi-endpoint-connection | [ISO/IEC 7498-1] |
| DL-name | [ISO/IEC 7498-3] |
| naming-(addressing)-domain | [ISO/IEC 7498-3] |
| peer-entities | [ISO/IEC 7498-1] |
| primitive name | [ISO/IEC 7498-3] |
| DL-protocol | [ISO/IEC 7498-1] |
| DL-protocol-connection-identifier | [ISO/IEC 7498-1] |
| DL-protocol-data-unit | [ISO/IEC 7498-1] |
| DL-relay | [ISO/IEC 7498-1] |
| reassembling | [ISO/IEC 7498-1] |
| reset | [ISO/IEC 7498-1] |
| responding-DL-address | [ISO/IEC 7498-3] |
| routing | [ISO/IEC 7498-1] |
| segmenting | [ISO/IEC 7498-1] |
| (N)-service | [ISO/IEC 7498-1] |
| DL-service (N=2) | |
| Ph-service (N=1) | |
| (N)-service-access-point | [ISO/IEC 7498-1] |
| DL-service-access-point (N=2) | |
| Ph-service-access-point (N=1) | |
| DL-service-access-point-address | [ISO/IEC 7498-3] |

| | |
|----------------------------------|------------------|
| DL-service-connection-identifier | [ISO/IEC 7498-1] |
| DL-service-data-unit | [ISO/IEC 7498-1] |
| DL-simplex-transmission | [ISO/IEC 7498-1] |
| DL-subsystem | [ISO/IEC 7498-1] |
| systems-management | [ISO/IEC 7498-1] |
| DL-user-data | [ISO/IEC 7498-1] |

3.2 Service convention terms and definitions

This standard also makes use of the following terms defined in ISO/IEC 10731 as they apply to the data-link layer:

- acceptor
- asymmetrical service
- confirm (primitive);
 - requestor.deliver (primitive)
- deliver (primitive)
- DL-confirmed-facility
- DL-facility
- DL-local-view
- DL-mandatory-facility
- DL-non-confirmed-facility
- DL-provider-initiated-facility
- DL-provider-optional-facility
- DL-service-primitive,
 - primitive
- DL-service-provider
- DL-service-user
- DL-user-optional-facility
- indication (primitive);
 - acceptor.deliver (primitive)
- multi-peer
- request (primitive);
 - requestor.submit (primitive)
- requestor
- response (primitive);
 - acceptor.submit (primitive)
- submit (primitive)
- symmetrical service

3.3 Data-link service terms and definitions

3.3.1

acyclic data

data which is transferred from time to time for dedicated purposes

3.3.2

cell

synonym for a single DL-segment which uses RTFL communication model

3.3.3

communication cycle

fixed time period between which the root device issues empty frames for cyclic communication initiation in which data is transmitted utilizing CDC and MSC

3.3.4

cycle time

duration of a communication cycle

3.3.5

cyclic

events which repeat in a regular and repetitive manner

3.3.6

cyclic communication

periodic exchange of frames

3.3.7

cyclic data

data which is transferred in a regular and repetitive manner for dedicated purposes

3.3.8

cyclic data channel (CDC)

one or more frames, which are reserved for cyclic data

3.3.9

data

generic term used to refer to any information carried over a fieldbus

3.3.10

device

physical entity connected to the fieldbus

3.3.11

DL-segment

single DL-subnetwork in which any of the connected DLEs may communicate directly, without any intervening DL-relaying, whenever all of those DLEs that are participating in an instance of communication are simultaneously attentive to the DL-subnetwork during the period(s) of attempted communication

3.3.12

error

discrepancy between a computed, observed or measured value or condition and the specified or theoretically correct value or condition

3.3.13

extended link

DL-subnetwork, consisting of the maximal set of links interconnected by DL-relays, sharing a single DL-name (DL-address) space, in which any of the connected DL-entities may communicate, one with another, either directly or with the assistance of one or more of those intervening DL-relay entities

NOTE An extended link may be composed of just a single link.

3.3.14

frame

denigrated synonym for DLPDU

3.3.15

gateway

device acting as a linking element between different protocols

3.3.16

interface

shared boundary between two functional units, defined by functional characteristics, signal characteristics, or other characteristics as appropriate

3.3.17

link

synonym for DL-segment

3.3.18

logical double line

sequence of root device and all ordinary devices processing the communication frame in forward and backward direction

3.3.19

master clock

global time base for the PCS mechanism

3.3.20

message

ordered sequence of octets intended to convey data

3.3.21

message channel

MSC

one or more DPUs (frames), which are reserved for acyclic data

3.3.22

network

set of devices connected by some type of communication medium, including any intervening repeaters, bridges, routers and lower-layer gateways

3.3.23

open network

any network based on IEC 8802.3 with no further restrictions

3.3.24

ordinary device

OD

slave in the communication system, which utilizes RTFL for cyclic and acyclic data interchange with other ODs in the same logical double line

3.3.25**precise clock synchronization****PCS**

mechanism to synchronize clocks of RTFL devices and maintain a global time base

3.3.26**process data**

data designated to be transferred cyclically or acyclically for the purpose of processing

3.3.27**protocol**

convention about the data formats, time sequences, and error correction in the data exchange of communication systems

3.3.28**root device****RD**

master in the communication system, which organises, initiates and controls the RTFL cyclic and acyclic data interchange for one logical double line

3.3.29**real time frame line****RTFL**

communication model communicating in a logical double line

3.3.30**real time frame network****RTFN**

communication model communicating in a switched network

3.3.31**switch**

MAC bridge as defined in IEEE 802.1D

3.3.32**timing signal**

time-based indication of the occurrence of an event, commonly as an interrupt signal, used for DL-user synchronization

3.3.33**topology**

physical network architecture with respect to the connection between the stations of the communication system

3.4 Symbols and abbreviations

| | |
|------|-------------------------------|
| CDC | Cyclic data channel |
| CDCS | Cyclic data channel send |
| DA | Device address |
| DL- | Data-link layer (as a prefix) |
| DLL | DL-layer |
| DLS | DL-service |