

# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

Luminaires – **iTeh STANDARD PREVIEW**  
Part 2-2: Particular requirements – Recessed luminaires  
(standards.iteh.ai)

Luminaires – **Partie 2-2: Règles particulières – Luminaires encastrés**  
IEC 60598-2-2:2011  
<https://standards.iteh.ai/catalog/standards/sist/a7849910-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011>



## THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2011 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester.

If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de la CEI ou du Comité national de la CEI du pays du demandeur.

Si vous avez des questions sur le copyright de la CEI ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de la CEI de votre pays de résidence.

IEC Central Office  
3, rue de Varembe  
CH-1211 Geneva 20  
Switzerland  
Email: [inmail@iec.ch](mailto:inmail@iec.ch)  
Web: [www.iec.ch](http://www.iec.ch)

### About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

### About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

- Catalogue of IEC publications: [www.iec.ch/searchpub](http://www.iec.ch/searchpub)

The IEC on-line Catalogue enables you to search by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, withdrawn and replaced publications.

- IEC Just Published: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Stay up to date on all new IEC publications. Just Published details twice a month all new publications released. Available on-line and also by email.

[IEC 60598-2-2:2011](mailto:IEC.60598-2-2:2011)

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

The world's leading online dictionary of electronic and electrical terms containing more than 20 000 terms and definitions in English and French, with equivalent terms in additional languages. Also known as the International Electrotechnical Vocabulary online.

- Customer Service Centre: [www.iec.ch/webstore/custserv](http://www.iec.ch/webstore/custserv)

If you wish to give us your feedback on this publication or need further assistance, please visit the Customer Service Centre FAQ or contact us:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tel.: +41 22 919 02 11

Fax: +41 22 919 03 00

### A propos de la CEI

La Commission Electrotechnique Internationale (CEI) est la première organisation mondiale qui élabore et publie des normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

### A propos des publications CEI

Le contenu technique des publications de la CEI est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

- Catalogue des publications de la CEI: [www.iec.ch/searchpub/cur\\_fut-f.htm](http://www.iec.ch/searchpub/cur_fut-f.htm)

Le Catalogue en-ligne de la CEI vous permet d'effectuer des recherches en utilisant différents critères (numéro de référence, texte, comité d'études,...). Il donne aussi des informations sur les projets et les publications retirées ou remplacées.

- Just Published CEI: [www.iec.ch/online\\_news/justpub](http://www.iec.ch/online_news/justpub)

Restez informé sur les nouvelles publications de la CEI. Just Published détaille deux fois par mois les nouvelles publications parues. Disponible en-ligne et aussi par email.

- Electropedia: [www.electropedia.org](http://www.electropedia.org)

Le premier dictionnaire en ligne au monde de termes électroniques et électriques. Il contient plus de 20 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans les langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International en ligne.

- Service Clients: [www.iec.ch/webstore/custserv/custserv\\_entry-f.htm](http://www.iec.ch/webstore/custserv/custserv_entry-f.htm)

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions, visitez le FAQ du Service clients ou contactez-nous:

Email: [csc@iec.ch](mailto:csc@iec.ch)

Tél.: +41 22 919 02 11

Fax: +41 22 919 03 00



# INTERNATIONAL STANDARD

# NORME INTERNATIONALE

Luminaires – **iTeh STANDARD PREVIEW**  
Part 2-2: Particular requirements – Recessed luminaires  
(standards.itih.ai)

Luminaires – **IEC 60598-2-2:2011**  
Partie 2-2: Règles particulières – Luminaires encastrés  
f27291fe8f7fiec-60598-2-2-2011

INTERNATIONAL  
ELECTROTECHNICAL  
COMMISSION

COMMISSION  
ELECTROTECHNIQUE  
INTERNATIONALE

PRICE CODE  
CODE PRIX

H

ICS 29.140.50

ISBN 978-2-88912-772-6

## CONTENTS

FOREWORD.....	3
2.1 Scope.....	5
2.2 Normative references .....	5
2.3 General test requirements .....	5
2.4 Definitions .....	5
2.5 Classification of luminaires .....	5
2.6 Marking .....	5
2.7 Construction.....	5
2.8 Creepage distances and clearances .....	5
2.9 Provision for earthing .....	6
2.10 Terminals .....	6
2.11 External and internal wiring .....	6
2.12 Protection against electric shock .....	6
2.13 Endurance tests and thermal tests .....	6
2.14 Resistance to dust and moisture.....	7
2.15 Insulation resistance and electric strength.....	7
2.16 Resistance to heat, fire and tracking .....	7
Annex A (informative) Measurement of ambient temperature in an installation .....	8
Table 1 – Operating temperature of cable.....	7

iTeh STANDARD PREVIEW

(standards.iteh.ai)

[IEC 60598-2-2:2011](https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011)

<https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011>

## INTERNATIONAL ELECTROTECHNICAL COMMISSION

## LUMINAIRES –

Part 2-2: Particular requirements –  
Recessed luminaires

## FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60598-2-2 has been prepared by subcommittee 34D: Luminaires, of IEC technical committee 34: Lamps and related equipment.

This third edition cancels and replaces the second edition published in 1996 and its Amendment 1 (1997), of which it constitutes a technical revision. The changes introduced by this new edition are those required to maintain consistency with later versions of IEC 60598-1 that have been published since the previous edition of this standard.

The text of this standard is based on the following documents:

FDIS	Report on voting
34D/1030/FDIS	34D/1038/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

This publication shall be read in conjunction with IEC 60598-1: *Luminaires – Part 1: General requirements and tests*. It was established on the basis of the seventh edition (2008) of that standard.

A list of all the parts in the IEC 60598 series, published under the general title *Luminaires* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC web site under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

## iTeh STANDARD PREVIEW (standards.iteh.ai)

[IEC 60598-2-2:2011](#)

<https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011>

## LUMINAIRES –

### Part 2-2: Particular requirements – Recessed luminaires

#### 2.1 Scope

This part of IEC 60598 specifies requirements for recessed luminaires incorporating electric light sources for operation from supply voltages up to 1 000 V. This section does not apply to air-handling or liquid-cooled luminaires.

#### 2.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60227 (all parts), *Polyvinyl chloride insulated cables of rated voltages up to and including 450/750 V*

IEC 60245 (all parts), *Rubber insulated cables – Rated voltages up to and including 450/750 V*

IEC 60598-1, *Luminaires – Part 1: General requirements and tests*  
<https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011>

#### 2.3 General test requirements

The provisions of section 0 of IEC 60598-1 apply. The tests described in each appropriate section of part 1 shall be carried out in the order listed in this section of part 2.

A procedure measuring ambient temperature in an installation is given in Annex A.

#### 2.4 Definitions

For the purposes of this document, the definitions of Section 1 of IEC 60598-1 apply.

#### 2.5 Classification of luminaires

Luminaires shall be classified in accordance with the provisions of Section 2 of IEC 60598-1.

#### 2.6 Marking

The provisions of Section 3 of IEC 60598-1 apply.

#### 2.7 Construction

The provisions of Section 4 of IEC 60598-1 apply.

#### 2.8 Creepage distances and clearances

The provisions of Section 11 of IEC 60598-1 apply.

## 2.9 Provision for earthing

The provisions of Section 7 of IEC 60598-1 apply.

## 2.10 Terminals

The provisions of Sections 14 and 15 of IEC 60598-1 apply.

## 2.11 External and internal wiring

The provisions of Section 5 of IEC 60598-1 apply.

Flexible cables or cords used as a means of connection to the supply, when supplied by the luminaire manufacturer, shall be at least equal in their mechanical and electrical properties to those specified in IEC 60227 or IEC 60245 and shall be capable of withstanding without deterioration the highest temperature to which they may be exposed under normal conditions of use. Materials other than p.v.c. and rubber are suitable if the above requirements are met.

*Compliance shall be checked by the tests specified in 2.13.*

NOTE The use of flexible cables and cords with recessed luminaires is appropriate for the following reasons:

- 1) The flexible cable or cord cannot be easily touched as it is normally out of reach within the recess.
- 2) To facilitate installation of the luminaire into the recess.
- 3) To permit the adjustment of settable and adjustable recessed luminaires.

## 2.12 Protection against electric shock

The provisions of Section 8 of IEC 60598-1 apply.

The parts of the luminaire and components within the ceiling space or cavity shall provide the same degree of protection against electric shock as the luminaire parts below the ceiling space.

NOTE The ceiling space or cavity is regarded as accessible for installation and maintenance, and the barriers do not provide adequate protection against electric shock.

*Compliance is checked by inspection.*

## 2.13 Endurance tests and thermal tests

The provisions of Section 12 of IEC 60598-1 apply together with the requirements of 2.13.1.

**2.13.1** Wiring, for connection to the supply, which passes into or can touch the luminaire shall not reach unsafe temperature.

*Compliance shall be checked by the following tests:*

*The luminaire is connected to the supply using the cable provided with the luminaire or using a cable in accordance with the marking on the luminaire or, if not marked, as specified in the manufacturer's instruction sheet; otherwise PVC cable complying with IEC 60227 is used.*

*The hottest point is found (along the internal route or on the outer surface of the luminaire) with which the cable is likely to lie in contact during normal service. The cable is lightly held in contact at this point and the temperature of the insulation at the point of contact is measured as described in Annex K of IEC 60598-1.*

*The operating temperature of the cable shall not exceed the limits given in Table 1.*



*Luminaires with an IP classification greater than IP20 shall be subjected to the relevant tests of Clauses 12.4, 12.5, 12.6 and 12.7 of Section 12 of IEC 60598-1 after the test(s) of Clause 9.2 but before the test(s) of Clause 9.3 of Section 9 of IEC 60598-1 specified in Clause 2.14 of this section of IEC 60598-2.*

**Table 1 – Operating temperature of cable**

Designation of cable	Limit of operating temperature
Cable (including sleeves) provided with the luminaire	The maximum temperature specified in Table 12.2 of IEC 60598-1
Cable not provided with the luminaire:	
a) luminaires with cable temperature marking	The marked temperature
b) luminaires without cable temperature marking	The maximum temperature specified in Table 12.2 of IEC 60598-1 for ordinary PVC not subject to mechanical stress

#### **2.14 Resistance to dust and moisture**

The provisions of Section 9 of IEC 60598-1 apply.

For luminaires with an IP classification greater than IP20, the order of the tests specified in Section 9 of IEC 60598-1 shall be as specified in Clause 2.13 of this section of IEC 60598-2.

#### **2.15 Insulation resistance and electric strength**

The provisions of Section 10 of IEC 60598-1 apply.

#### **2.16 Resistance to heat, fire and tracking**

The provisions of Section 13 of IEC 60598-1 apply.

## Annex A (informative)

### Measurement of ambient temperature in an installation

Considerable care is needed in deciding whether a recessed luminaire is operating within its thermal limits in an existing lighting installation. It is even more difficult to predict whether a luminaire will be satisfactory in a proposed installation and a "mock-up" is usually required. In the past, there have been instances of overheating of luminaires, for example, overheating owing to the presence of heating services above the ceiling plane.

The following procedure is for measuring the ambient temperature in which the luminaire operate. The  $t_a$  rating of the luminaire should be at least equal to this ambient temperature. The ambient temperature is measured in the plane of the ceiling (or other mounting surface) at the mid-point of a typical cavity. It is important that all other luminaires in the installation and all other services which may affect the thermal conditions of the luminaire are operating. The cavity is covered above the measuring point to prevent a non-typical interchange of air and so that the cover may absorb extraneous heat which would be absorbed by the luminaire.

NOTE It may be convenient to insert for this purpose the shell of the luminaire.

The test recess used to measure operating temperatures of recessed luminaires is intended to represent the most onerous closed recess (without other heat source) which is likely to be experienced in service. A recessed luminaire should not be installed in a cavity with a volume smaller than that of the test recess, unless the manufacturer of the luminaire has verified that operation will be satisfactory.

The test recess may also approximate to the thermal conditions above a suspended ceiling if the larger air volume is offset by heat-emitting services. In a particular installation, more onerous thermal conditions than this may exist and it is, therefore, essential to carry out a practical check. Conversely, the space above the ceiling may have free air movement and no heat-emitting services; for such an installation, the  $t_a$  rating of the luminaire as determined in the test recess incorporates a temperature margin and the  $t_a$  rating may be exceeded if the manufacturer of the luminaire has verified that operation in the particular installation will be satisfactory.

During tests, to determine or check a  $t_a$  rating for a luminaire, measurements of ambient temperature are made inside the draught-proof enclosure and outside the test recess in accordance with Annex K of IEC 60598-1.

---

**iTeh STANDARD PREVIEW**  
**(standards.iteh.ai)**

[IEC 60598-2-2:2011](https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011)

<https://standards.iteh.ai/catalog/standards/sist/a78490f0-7804-4e6c-ad4f-f27291fe8f7f/iec-60598-2-2-2011>